



November 12, 2021

VIA E-FILING

Jonathan P. Nase

Direct Phone 717-773-4191
Direct Fax 215-372-2340
jnase@cozen.com

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor – Filing Room
Harrisburg, PA 17120

Re: TANYA J. MCCLOSKEY, ACTING CONSUMER ADVOCATE V. HIDDEN VALLEY UTILITY SERVICES, L.P. – WATER, DOCKET NO. C-2014-2447138

TANYA J. MCCLOSKEY, ACTING CONSUMER ADVOCATE V. HIDDEN VALLEY UTILITY SERVICES, L.P. – WASTEWATER, DOCKET NO. C-2014-2447169

HIDDEN VALLEY UTILITY SERVICES, L.P. – STATUS REPORT ON COMPLIANCE WITH ORDER ENTERED JANUARY 18, 2018 AND RECONSIDERED MAY 3, 2018

Dear Secretary Chiavetta:

Enclosed for filing with the Pennsylvania Public Utility Commission is the 60-day status report required by Ordering Paragraph No. 17 of the Commission's Order in the above-referenced matters. All parties to this proceeding are being served as shown on the attached Certificate of Service.

Please contact me if you have any questions regarding this filing. Thank you.

Sincerely,

COZEN O'CONNOR

By: Jonathan P. Nase
Counsel for *Hidden Valley Utility Services, L.P.*

JPN:kmg
Enclosure

cc: Hon. Katrina L. Dunderdale
Per Certificate of Service
Paul Diskin, Director, Bureau of Technical Utility Services
James Kettler

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Tanya J. McCloskey, Acting Consumer Advocate	:	
	:	
	:	Docket No. C-2014-2447138
v.	:	
	:	
Hidden Valley Utility Services, L.P. – Water	:	
	:	
and	:	
	:	
Tanya J. McCloskey, Acting Consumer Advocate	:	
	:	
	:	Docket No. C-2014-2447169
v.	:	
	:	
Hidden Valley Utility Services, L.P. – Wastewater	:	

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true copy of the foregoing correspondence filing the **November 2021 Status Report** upon the parties, listed below, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a party).

VIA E-MAIL AND FIRST CLASS MAIL:

Erin L. Gannon, Esq.
Office of Consumer Advocate
555 Walnut Street
Forum Place, 5th Floor
Harrisburg, PA 17101-1923
EGannon@paoca.org
Counsel for *Office of Consumer Advocate*

Allison Kaster, Esq.
Pennsylvania Public Utility Commission
Bureau of Investigation and Enforcement
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
akaster@pa.gov
Counsel for *Bureau of Investigation and Enforcement*

Sharon Howard-Frieri
P.O. Box 4126
1174 Gristmill Court
Hidden Valley PA 15502
sharonhoward.frieri@yahoo.com

Robert J. Kollar, CPA and
Kellie A. Kuhleman
1374 Langport Dr.
Pittsburgh, PA 15241
bob@kkacpas.com

Terry L. Fought
780 Cardinal Drive
Harrisburg, PA 17111
foughtbusiness@gmail.com
Consultant for
Office of Consumer Advocate

DATED: November 12, 2021



Jonathan P. Nase, Esquire
Counsel for *Hidden Valley Utility Services, L.P.*

**Hidden Valley Utility Services, L.P (“HVUS”) Compliance Timeline
per May 3, 2018 PUC Order on Reconsideration in
Docket Nos. C-2014-2447138 and C-2014-2447169**

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
1-19-18	HVUS will pay all electric and telephone bills timely and execute forms authorizing Penelec to provide monthly billing and payment information for HVUS accounts to the OCA.	15.	HVUS is paying all electric and telephone bills timely. On May 9, 2018, HVUS authorized Penelec to provide monthly billing and payment information for HVUS accounts to the OCA.
1-19-18	HVUS will have a spare pump and motor available for Well No. 1 within 72 hours of the primary pump and motor becoming inoperable.	22.	HVUS has confirmed with its supplier that pumps and motors necessary for well #1 can be available within 72 hours of notice. ¹
1-19-18	HVUS will maintain an operable, installed second high lift pump.	24.	The second high lift pump is installed and operational. The pump was installed in Dec. 2014, and a new electric check valve was installed in February 2015. Therefore, the second high lift pump has been operational since February 2015.
1-19-18	HVUS will provide an annual update of telephone service numbers, including copies of bills, so that customers can reliably contact HVUS.	15.	Customer bills include the following working telephone numbers for HVUS: (814) 443-0825 (877) 523-8181. In addition, in April, 2018, HVUS obtained the following toll-free number, which was listed in the customer notice of its rate

¹ This paragraph applies until a permanent solution to the iron and manganese problem is in place. As discussed below, the water treatment plant is now operational.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
			<p>increase in R-2018-3001306 and R-2018-3001307: (833) HVUS800 On May 18, 2018, HVUS provided a copy of phone bills from the previous year to verify compliance. On July 16, 2019, HVUS provided its annual update of telephone service numbers to the Commission, including copies of bills. On May 15, 2020, HVUS provided its annual update of telephone service numbers to the Commission, including copies of bills. On May 14, 2021, HVUS provided its annual update of telephone service numbers to the Commission, including copies of bills.</p>
3-19-18	HVUS will consult with OCA re modifications to its consumer bills.	12.	A new invoice format was sent to the OCA on March 15, 2018. The OCA made recommendations, which were adopted by HVUS.
3-19-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the January 18, 2018 order.	17.	HVUS attempted to file on March 19, 2018, but used the wrong docket numbers. The status report was re-filed on April 11, 2018.
4-18-18	<p>HVUS will file with the Commission a report from an engineer regarding its water system, including a schedule to replace/test customer meters to obtain compliance by April 30, 2019. Copies are to be provided to TUS and OCA within 14 days of receipt. If the means to address iron and manganese is treatment of water from Wells 1 and 2, HVUS</p>	6, 7 and 23	<p>The engineer’s report was filed with the Commission on April 18, 2018. A copy was provided to TUS and OCA that same day. With regard to water meter testing and replacement, 52 Pa. Code § 65.8 requires periodic testing of water meters. HVUS is in compliance with this regulation.</p>

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
	will install instrumentation to control the on/off cycle of Well 2. ²		HVUS has installed a water treatment plant (“WTP”) to address the iron and manganese in the water. Jefferson Township, Somerset County issued a Certificate of Use and Occupancy for the WTP on May 28, 2021 and the Pennsylvania Department of Environmental Protection (“DEP”) issued an Operation Permit authorizing the operation of the WTP on June 17, 2021. HVUS has not received any customer complaints about brown water since the WTP went on-line. The construction included the installation of instrumentation to control the on/off cycle of Well 2.
4-18-18	HVUS will file with the Commission a report from an engineer regarding its wastewater system. Copies are to be provided to TUS and OCA within 14 days.	9. and 10.	The report was filed with the Commission on April 18, 2018. A copy was provided to TUS and OCA that same day.
4-18-18	HVUS will modify its billing practices to ensure that all bills are compliant with Commission rules, regulations and orders. A copy of the revised bill form is to be submitted to the PUC for review by BCS and TUS.	12. and 13.	A revised bill was submitted to BCS and TUS on April 18, 2018. On April 24, 2018, BCS provided recommendations, which HVUS agreed to implement. HVUS notified the OCA of BCS’s recommendations and HVUS’s agreement to implement them. HVUS used a modified billing format starting with the 3 rd Quarter billing cycle of 2018 and has further modified its bill format for the 2 nd Quarter billing cycle of 2019.

² The Commission’s Order is unclear when HVUS is required to install the instrumentation.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
4-18-18	HVUS will modify practices to comply with its tariff, the Code, the Commission’s regulations and orders.	16.	HVUS is constantly modifying its practices to comply with the Code, the Commission’s regulations and orders.
5-18-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	The Status Report was filed with the Commission on May 18, 2018.
6-30-18	HVUS will replace 1,500 feet of 3-inch line to the Heights and 1,000 feet of 2-inch line to Valley View.	5.a.	The line to the Heights was completed approximately June 8, 2016. A 6” diameter pipe to Valley View was installed by October 20, 2016. In addition, a loop was constructed at Lake Road, which was completed by November 14, 2016.
6-30-18	HVUS will begin conducting semi-annual customer meetings.	5.b.	A customer meeting was held on May 19, 2018 with approximately 125 customers in attendance. Representatives from the OCA were present at the meeting.
7-17-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this Status Report on July 17, 2018.
7-17-18	HVUS will amend any prior reports to the PUC containing incorrect information and ensure that it is filing reports with correct information.	14.	HVUS submitted revised annual PUC reports to the Commission on July 17, 2018. Further corrected reports were filed on or about June 27, 2019 as required by the Commission’s Order at Docket Nos. R-2018-3001306 and R-2018-3001307.
9-17-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this Status Report on September 17, 2018.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
11-16-18	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this Status Report on November 16, 2018.
12-31-18	HVUS will conduct another semi-annual customer meeting.	5.b.	HVUS conducted a semi-annual customer meeting on December 22, 2018.
12-31-18	HVUS will conduct a pressure survey in compliance with 52 Pa. Code § 65.6(d). HVUS shall install booster pumping stations if pressure is inadequate.	22.	HVUS conducted a pressure survey in May, 2018 and another pressure survey in December, 2018. Based on those results, HVUS will not install booster pumping stations.
1-16-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	5.b.	HVUS filed this Status report on January 16, 2019.
1-31-19	HVUS will comply with all recommendations in the engineer’s wastewater report.	11.	On January 31, 2019, HVUS’s engineer filed a verified status report indicating the tasks that were completed, the tasks that were removed from the engineer’s wastewater report (and the reasons for removing each task from the report), and the tasks that remained outstanding. On February 14, 2020, HVUS’s engineer filed a verified status report indicating that all remaining items on the engineer’s report had been completed.
1-31-19 (or when all repairs required by the order have been made)	HVUS will file a final status report with copies to the OCA and TUS.	19.	The status reports described in the preceding paragraph were filed with the Commission on the dates indicated and copies were provided to the OCA and TUS.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
3-18-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	The required status report was filed on March 18, 2019.
March 31, 2019 or 60 days after the final status report	TUS will investigate the water quality and the water and wastewater services being provided by HVUS. If the repairs have not been made or the water quality is inadequate, OALJ will hold an evidentiary hearing in which the burden of proof will be on HVUS.	20.	TUS staff was scheduled for a site visit in mid-March 2019, but cancelled that visit.
4-18-19	Within 1 year of the date of the engineer’s report on the water system, HVUS will comply with all recommendations in the engineer’s water report.	8.	On October 18, 2018, HVUS filed a Petition for Amendment seeking to modify this deadline. By Opinion and Order entered January 17, 2019, the Commission denied this Petition. HVUS filed a Petition for Review with the Commonwealth Court of Pennsylvania on February 19, 2019, asking the Court to modify the deadline. This appeal was quashed by order of May 15, 2019 and the matter was remanded for hearings. A hearing was held on May 20, 2020, briefs and reply briefs have been filed. The record was reopened in February 2021, and additional evidence was submitted between March 1 and September 14, 2021. With regard to the status of the WTP, see pages 2-3 above.
5-17-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on May 16, 2019.
6-30-19	HVUS will conduct another customer meeting.	5.b.	This meeting was held on June 8, 2019.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
7-16-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on July 16, 2019.
9-16-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on September 16, 2019.
11-15-19	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on November 15, 2019.
12-31-19	HVUS will conduct another customer meeting.	5.b.	This meeting was held on December 21, 2019.
12-31-19	HVUS will conduct a pressure survey in compliance with 52 Pa. Code § 65.6(d). HVUS shall install booster pumping stations if pressure is inadequate.	22.	HVUS conducted a pressure survey during 2019. Based on those results, HVUS will not install booster pumping stations.
1-14-20	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on January 14, 2020.
3-16-20	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on March 16, 2020.
5-15-20	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on May 15, 2020.
6-30-20	HVUS will conduct another customer meeting.	5.b.	HVUS filed a Petition requesting an extension of time to hold this meeting in person, but that Petition was denied. HVUS held a virtual customer meeting on July 15, 2020 due to the COVID-19 Pandemic. HVUS management met on-site every other week from approximately October 2020 to June 2021

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
			with a subcommittee of the Board of Directors of the Hidden Valley Foundation, Inc. (“Foundation”) regarding the status of the WTP project.
7-14-20	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on July 14, 2020.
9-14-2020	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on September 14, 2020.
11-13-2020	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on November 13, 2020.
12-31-2020	HVUS will conduct another customer meeting.	5.b.	HVUS management met with customers via Zoom on November 18, 2020.
12-31-2020	HVUS will conduct a pressure survey in compliance with 52 Pa. Code § 65.6(d). HVUS shall install booster pumping stations if pressure is inadequate.	22.	HVUS conducted a pressure survey during May, 2020. Based on those results, HVUS will not install booster pumping stations.
1-12-2021	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed this status report on January 12, 2021
3-15-2021	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	This status report was filed early, on March 1, 2021.
5-14-2021	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order	17.	HVUS filed the status report on May 14, 2021.
6-30-21	HVUS will conduct another customer meeting.	5.b.	HVUS management postponed this meeting so it could report to homeowners on the

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
			performance of the WTP (which became operational on June 18, 2021). Consistent with past practice, HVUS worked with the Foundation to coordinate the customer meeting with the homeowners’ meeting, but was only able to meet with members of the Foundation’s Board of Directors (“Board”) prior to June 30, 2021. As discussed above, however, HVUS management met on-site every other week from approximately October 2020 to June 2021 with a subcommittee of the Board of the Foundation regarding the status of the WTP project, and they kept all customers informed through the Foundation’s Facebook page (Life at Hidden Valley). For an example, see attached Facebook post from September 24, 2021.
7-13-21	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed the status report on July 13, 2021.
9-13-21	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	HVUS filed the status report on September 13, 2021.
11-12-21	HVUS will file a status report with the PUC, the OCA and TUS, on compliance with the May 3, 2018 order.	17.	This document is the required status report.
12-31-21	HVUS will conduct another customer meeting.	5.b.	HVUS management will meet with the Board of the Foundation on Friday, November 19, 2021. All community members can attend this meeting.

Task to be completed on or before	Task	Source – Ordering Paragraph	Status
TBD	When HVUS complies with all ordering paragraphs, the Secretary’s Bureau will close the complaint proceedings.	27	

September 24 ·

WATER COMMITTEE IMPROVES HVF REPORTING ...

As reported previously, the Hidden Valley Water Committee has provided important over-site to the implementation of the new water treatment facility constructed by the Hidden Valley Utilities Service (HVUS). The new treatment facility is specifically designed to remove iron manganese elements from the water which caused a brown color at times.

If you have flushed your home's system, including your water heater, of untreated water, any further presence of brown water may indicate a leak in the delivery system rather than presence of iron manganese. If you experience brown water at this point, please be sure to notify HVUS. This will assist them with providing a fix as soon as possible.

The Water Committee has established a dedicated email address to enable homeowners to contact HVUS easily & efficiently regarding any water-related matters, whether brown water, suspected leaks, or other concerns.

To contact HVUS, please use email address Watermatters@hvftoday.com. Your message will automatically be directed to HVUS for an appropriate response. And your message will both notify HVUS of the concern & the Foundation so they can document all water related complaints

