



January 13, 2022

Office of Consumer Advocate
555 Walnut Street
Forum Place, 5th Floor
Harrisburg, PA 17101-1923

Bureau of Investigation & Enforcement
Commonwealth Keystone Building
PO Box 3265
Harrisburg, PA 17105-3265

Office of Small Business Advocate
Commerce Building, Suite 202
300 North 2nd Street
Harrisburg, PA 17101

RE: Annual Valve Exercising Report; Columbia Water Company
Docket No. R-2017-2598203

Dear Sir or Madam:

In compliance with the Order entered on March 1, 2018 at Docket No. R-2017-2598203, Columbia Water Company submits the following annual valve exercising report for the period ending 12/31/21.

| | |
|---|--|
| Number of system isolation valves: | 2,904 |
| Number of valves exercised: | 356 |
| Number of critical isolation valves: | 135 |
| Number of critical valves exercised: | 10 |
| Number of valves that could not be exercised: | 1 |
| Remedial steps taken: | The valve was replaced with a new valve. |

If you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in blue ink, appearing to read "David Lewis", is written over the typed name.

David T. Lewis, P.E.
Vice President and
General Manager

Cc: Rosemary Chiavetta, Secretary, Pa Public Utility Commission

Columbia Water Company

220 Locust Street ■ P.O. Box 350 ■ Columbia, PA 17512
Phone: 717-684-2188 ■ Fax: 717-684-4566