
Garrett P. Lent
Associate

glent@postschell.com
717-612-6032 Direct
717-731-1979 Direct Fax

January 19, 2022

VIA ELECTRONIC FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

Re: Letter of Notification of PPL Electric Utilities Corporation, Filed Pursuant To 52 Pa. Code Chapter 57 Subchapter G, For Approval of The Rebuild of The Double-Circuit Manor-Millwood 230 kV/Face Rock-Millwood 69 kV Transmission Lines Connecting The Manor 230-69 kV Substation And The Millwood 230-69 kV Substation In Conestoga Township, Manor Township, And Pequea Township, Lancaster County, Pennsylvania
Docket No. A 2021-3029689

Dear Secretary Chiavetta:

Enclosed for filing is the following Supplemental Response of PPL Electric Utilities Corporation to the data requests of The Bureau of Technical Utility Services dated November 24, 2021, in the above-referenced proceeding:

Set I No. A-1 (SUPPLEMENTAL)

Respectfully submitted,



Garrett P. Lent

GPL/dmc
Enclosures

Rosemary Chiavetta, Secretary
January 19, 2022
Page 2

cc: Jordan Van Order (*via email only*)

**PPL Electric Utilities Corporation
Response to the Data Request of
The Bureau of Technical Utility Services
Dated January 18, 2022
Docket No. A-2021-3029689**

A-1 Reference the Letter of Notification. Please provide the statement required by 52 Pa. Code § 57.72(d)(iv).

PPL

Response As indicated on Letter of Notification page 1, PPL Electric filed this Letter of Notification pursuant to 52 Pa. Code § 57.72(d)(1)(i), as this project is proposed to be located entirely on an existing transmission line right-of-way, so long as the size, character design or configuration of the proposed HV line does not substantially alter the right-of-way. See *also* Letter of Notification ¶ 33. Furthermore, as demonstrated in Attachment 2, Table 2-1, the number of structures located in the existing ROW will not change, and the height of the structures will not substantially change. In addition, the proposed monopole structures will be constructed in generally the same location as the existing lattice towers. Attachment 2, p. 3.

PPL

Supplemental Response

The Letter of Notification was filed on November 24, 2021. See Cover Letter; see *also* Letter of Notification, page 20. In addition, pursuant to Section 57.72(d)(4)(iv) of the Commission's regulations, the Commission will review and, by order, approve or disapprove a letter of notification. If the Commission approves a letter of notification, the HV line shall be located and constructed without the application process set forth in this subchapter G of Chapter 57. If the Commission does not approve the letter of notification, its order shall direct PPL Electric to comply with the application process set forth in this subchapter.

VERIFICATION

I, JOSEPH B. LOOKUP, being the Director of Asset Management at PPL Electric Utilities Corporation, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect PPL Electric Utilities Corporation to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: 01/18/2022


Joseph B. Lookup (Jan 18, 2022 16:53 EST)

Joseph B. Lookup