



**Emily M. Farah**  
Counsel, Regulatory

411 Seventh Avenue  
Mail drop 15-7  
Pittsburgh, PA 15219

Tel: 412-393-6431  
efarah@duqlight.com

April 1, 2022

**VIA ELECTRONIC FILING**

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building, 2<sup>nd</sup> Floor  
400 North Street  
Harrisburg, PA 17120

**Re: Municipal Contract –Right of Way Agreement between Duquesne Light Company  
and The County of Beaver  
Docket No. U-2022-\_\_\_\_\_**

Dear Secretary Chiavetta:

Enclosed for review and approval in accordance with 66 Pa.C.S. § 507 and 52 Pa. Code § 3.101, is a Right of Way Agreement dated March 24, 2022 between Duquesne Light Company (“Duquesne Light” or the “Company”) and the County of Beaver (“County”). The County granted to Duquesne Light a Right of Way on its property situated on Brady’s Run Road in the Township of Brighton, Beaver County, which provides the right to install, use, own, operate, maintain, repair, renew and remove an electrical line.

Should you have any questions regarding the enclosed right of way, please contact Dan Antosik at 412-393-8628.

Respectfully Submitted,

A handwritten signature in blue ink, appearing to read "Emily M. Farah", is written over a printed name and ID number.

Emily M. Farah  
Attorney ID#322559

Enclosure





Pole Map: B0211  
Circuit: D23784-1


② DL#701421  
-- 30' 1

DESIGN 1-CALL #20220211222

DLC CANNOT MOVE POLE TO EDGE OF R/W  
DUE TO SEVERE IMPACT ON LINE ANGLE AND  
WOULD REQUIRE ADDITIONAL PRIVATE PROPERTY  
R/W TO BE OBTAINED.



Current Portion of  
Circuit: D23784-1



Proposed Portion of  
Circuit: D23784-1

① DL#372312  
-- 25 kVA XFMR  
(120/240V)  
(OH 10-44)  
SITE #6

③ DL#200036  
25 kVA XFMR --  
(120/240V)  
(OH 10-44)  
SITE #6  
-- 23D FLAT CORNER  
(OH 7-38)  
-- 18M L.G. (23D)  
10M L.G. 10M L.G. (SEC.)

(701023)  
④ DL#354424  
40' 3 50' 2  
-- 8' DXD  
(OH 7-20-A)  
-- 3 - 25kVA XFMRs  
(277/480V)  
(OH 10-82)  
NEW SITE #127  
CN CN  
-- 18M A.G.  
-- D.H. ANCHOR

NOTE: POLE ON P/P  
VZ TO TRANSFER  
NJUNS #4981192  
DESIGN 1-CALL #20220211222

**BEAVER COUNTY**  
**55-143-0106.000**

-- / 3 - #2 AL

<b>DLC</b> DUQUESNE LIGHT CO. DISTRIBUTION ENGINEERING			NEW SERVICE	
SCALE: NTS			139 BRADYS RUN RD	BRIGHTON TWP
DATE COMPL'D	DRAWN BY	FINAL APP. FOR ISSUE	DLCO TO INSTALL 3Ø XFMRs & SERVICE	
	B.Sell	APPROVED By Melissa Swanson at 2:42 pm, Jan 21, 2022	PP#:	REL. NO. 899285

REV. 0