

Tori L. Giesler, Esq.
(610) 921-6658
(330) 315-9263 (Fax)

May 6, 2022

VIA E-FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

**Re: Completed Restoration of Momentary and Sustained Interruptions –
Pennsylvania Electric Company; Docket No. M-2021-3023564**

Dear Secretary Chiavetta:

Pursuant to 52 Pa. Code § 67.1, Pennsylvania Electric Company (“Penelec”) submits written notification of completed restoration efforts following storm conditions that began on April 19, 2022 that caused multiple service interruptions in the Penelec service territory.

Attached please find the details relative to the impact of this recent outage event and the restoration activities that took place. It should be noted that the review and approval process of this outage information is still in progress at the time of filing this report and as such, all outage information contained in this report should be considered preliminary.

If you have any questions, please contact me at (610) 921-6658.

Sincerely,



Tori L. Giesler

Enclosures

- c: Dan Searfoorce - PaPUC Bureau of Technical Utility Services (via electronic mail)
Derek Ruhl - PaPUC Bureau of Technical Utility Services (via electronic mail)
John Van Zant - PaPUC Bureau of Technical Utility Services (via electronic mail)
Harry Bidelsbach – PaPUC Bureau of Technical Utility Services (via electronic mail)

ELECTRIC UTILITY REPORT OF OUTAGE TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU
P O BOX 3265
HARRISBURG, PA 17105-3265

1. Reporting Utility: Pennsylvania Electric Company ("Penelec")
Address: 800 Cabin Hill Road
Greensburg, PA 15601

2. Name and title of person making report:

Scott Wyman President, Pennsylvania Operations
(Name) *(Title)*

3. Telephone number: (724) 838-6150
(Telephone Number)

4. Date and time report was made to Commission:

April 19, 2022 0715
(Date) *(Time)*

5. Interruption or Outage:

(a) Number of customers affected: 48,934 (Represents 8.4% of Penelec's total customers).

(b) Approximate number of outage cases and trouble cases for each county affected during event: See response to 5(c).

(c) Approximate number of outages for each county affected during the event:

County	Outages	Outage Cases	Trouble Cases
Bedford	45	2	1
Blair	32	5	25
Bradford	9,625	150	103
Cambria	24	5	24
Clarion	17	2	2
Clearfield	47	7	6
Crawford	260	4	5
Cumberland	133	1	1
Erie	212	22	49
Huntingdon	20	3	5
Indiana	7	5	9
Jefferson	54	6	6
Lycoming	3	1	0
Mckean	48	4	6
Mifflin	44	4	4
Perry	2	1	0
Potter	7	2	4
Somerset	903	11	6
Sullivan	4,796	67	39
Susquehanna	14,226	247	420
Tioga	3,693	66	21
Venango	71	5	7
Warren	2,823	12	8
Wayne	2,728	51	74
Wyoming	9,114	98	127
Total	48,934	781	952

(d) Approximate number of outage cases exceeding 6 or more hours in duration: 517

(e) A listing of each outage case exceeding 6 or more hours in duration:
See Attachment A.

(f) Reason for the interruption or outages: Beginning Monday afternoon, April 18, 2022, a spring snowstorm producing a mix of rain, freezing rain, and heavy, wet snow moved from west to east across Pennsylvania including Penelec service territory. On Tuesday afternoon, April 19, 2022, as the storm continued, a stationary snowband developed which stalled in Penelec's northeast service territory producing higher than predicted snow totals. Total snow amounts in Penelec's northeast territory reached nearly 15 inches. Wind gusts in Penelec's northeast service territory exceeded 40 miles per hour

on April 19, 2022. See Attachment B for the maximum wind gusts on April 19, 2022 and snow totals for April 18 and 19, 2022.

Damage as a result of the high winds and snow included downed trees/power lines, damaged and broken poles/crossarms, and damaged equipment. The Montrose, Mansfield, Towanda, and Warren districts were the hardest hit areas. Approximately 24% of the total outages that occurred were tree related. Restoration activities were impacted by the poor travel conditions at the onset of the storm.

Preliminary data indicate the reliability impact of the storm was 91.8 minutes of SAIDI, 0.08 of SAIFI, and an overall storm CAIDI of 1,087.6 minutes.

- (g) Projected time of restoration: It was estimated that the majority of customers in the Mansfield district would be restored by 2300 on April 20, 2022; Towanda district by 1400 on April 21, 2022; and Montrose district by 1400 on April 22, 2022.

See Attachment C for the restoration curve and Attachment D for the order restoration graphs.

- (h) The number of utility workers, contract workers, and workers received as mutual aid assigned specifically to the repair work by general function:

Company	# of Workers	General Function
Penelec	113	Line Workers
Met-Ed	64	FirstEnergy Affiliate
West Penn	36	FirstEnergy Affiliate
Penn Power	6	FirstEnergy Affiliate
Subtotal	219	
Henkels & McCoy	19	Line Contractor
J.W. Didado	13	Line Contractor
Main Lite	12	Line Contractor
Miller Brothers	17	Line Contractor
NG Gilbert	41	Line Contractor
Thayer	7	Line Contractor
Thompson	21	Line Contractor
Valiant Energy Service	12	Line Contractor
Houghland LLC	5	Line Contractor
Subtotal	147	
Asplundh	26	Forestry Contractor
Lewis Tree	13	Forestry Contractor
Davey Resources	8	Forestry Contractor

Company	# of Workers	General Function
PennLine Services	25	Forestry Contractor
TreeSmiths	50	Forestry Contractor
Subtotal	122	
Penelec	53	Hazard Responders
FirstEnergy Service Co.	4	Hazard Responders
Met-Ed	20	Hazard Responders
West Penn Power	24	Hazard Responders
Penn Power	2	Hazard Responders
JCP&L	22	Hazard Responders
Subtotal	125	
Penelec	10	Supporting Roles
Subtotal	10	
Grand Total	623	

- (i) The date and time of the first information of a service interruption: April 19, 2022 at 0010.
- (j) The date and time that repair crews were assembled: Crews were on duty with additional crews called in to support restoration.
- (k) The actual time that service was restored to the last affected customer: April 22, 2022 at 2020.
- (l) A general description of the physical damage sustained by the utility facilities as a result of the interruption/outage:

Equipment	Number
Primary Spans Down	335
Secondary Spans Replaced	50
Crossarms Replaced	163
Cutouts Replaced	67
Poles Replaced	29
Transformers Replaced	16
Wire & Cable Replaced (feet)	28,602

- (m) If the interruption/outage event was weather-related, the utility’s weather reports, outlooks, or scenarios for the day before and the day of the interruption/outage event:

See Attachment E for the weather forecast reports.

- (n) If the interruption/outage event caused approximate outages that exceed 10% or more of the number of customers in the utility's entire service territory, rank the event in terms of the number and duration of outages and provide 2 comparable events, including the number and duration of outages for those comparable events.

The outages that were a result of this event did not exceed 10% or more of customers in the utility's entire service territory.

Remarks: The storm statistics contained in this report are preliminary. The review and approval of the storm statistics were still in progress as of the time this report was filed.

Attachment A: A listing of each outage case exceeding six or more hours in duration, including the following information¹:

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11994569-1	Susquehanna	5	5,406	04/19/2022 0206	04/22/2022 2012
11992185-1	Susquehanna	11	5,354	04/19/2022 0157	04/22/2022 1911
11990726-1	Susquehanna	6	5,326	04/19/2022 0206	04/22/2022 1852
11993745-1	Susquehanna	58	5,297	04/19/2022 0028	04/22/2022 1645
11993577-1	Susquehanna	18	5,283	04/19/2022 0046	04/22/2022 1649
11994582-1	Susquehanna	1	5,279	04/19/2022 0326	04/22/2022 1925
11994092-2	Wayne	16	5,243	04/19/2022 0113	04/22/2022 1636
11993810-1	Susquehanna	30	5,200	04/19/2022 0138	04/22/2022 1618
11993649-1	Susquehanna	1	5,197	04/19/2022 0138	04/22/2022 1615
11993857-1	Susquehanna	103	5,197	04/19/2022 0138	04/22/2022 1615
11993649-1	Susquehanna	4	5,197	04/19/2022 0138	04/22/2022 1615
11993567-1	Susquehanna	70	5,194	04/19/2022 0138	04/22/2022 1612
11994604-1	Susquehanna	1	5,180	04/19/2022 0306	04/22/2022 1726
11993568-1	Susquehanna	19	5,177	04/19/2022 0138	04/22/2022 1555
11988319-4	Susquehanna	51	5,146	04/19/2022 0104	04/22/2022 1450
11988319-6	Susquehanna	37	5,111	04/19/2022 0306	04/22/2022 1617
11991386-1	Wayne	5	5,084	04/19/2022 0606	04/22/2022 1850
11991852-1	Bradford	4	5,069	04/19/2022 0145	04/22/2022 1414
11990600-2	Wayne	17	5,052	04/19/2022 0233	04/22/2022 1445
11993479-1	Susquehanna	3	5,022	04/19/2022 0212	04/22/2022 1354
11993787-1	Wyoming	11	5,018	04/19/2022 0052	04/22/2022 1230
11993571-2	Susquehanna	11	4,967	04/19/2022 0138	04/22/2022 1225
11989744-1	Wyoming	9	4,946	04/19/2022 0449	04/22/2022 1515
11994019-1	Wyoming	11	4,923	04/19/2022 0324	04/22/2022 1327
11993468-1	Susquehanna	9	4,893	04/19/2022 0212	04/22/2022 1145
11993476-1	Susquehanna	2	4,893	04/19/2022 0212	04/22/2022 1145
11992790-2	Susquehanna	1	4,881	04/19/2022 1009	04/22/2022 1930
11989247-2	Susquehanna	16	4,861	04/19/2022 0807	04/22/2022 1708
11993911-1	Wyoming	2	4,854	04/19/2022 0236	04/22/2022 1130
11994213-1	Susquehanna	16	4,847	04/19/2022 0513	04/22/2022 1400
11993819-1	Susquehanna	2	4,838	04/19/2022 0836	04/22/2022 1714

¹ When applicable, the individual restoration steps for an order are provided for those customers that were out of service for 6 hours or more.

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11990526-1	Wyoming	4	4,809	04/19/2022 0333	04/22/2022 1142
11990971-1	Wyoming	13	4,804	04/19/2022 0314	04/22/2022 1118
11992499-1	Susquehanna	5	4,791	04/19/2022 0326	04/22/2022 1117
11992590-2	Wayne	10	4,779	04/19/2022 0526	04/22/2022 1305
11993763-1	Susquehanna	33	4,775	04/19/2022 0341	04/22/2022 1116
11991191-1	Susquehanna	10	4,763	04/19/2022 0157	04/22/2022 0920
11994315-1	Wyoming	2	4,630	04/19/2022 0750	04/22/2022 1300
11994315-1	Wyoming	1	4,630	04/19/2022 0750	04/22/2022 1300
11994315-1	Wyoming	2	4,630	04/19/2022 0750	04/22/2022 1300
11992723-1	Susquehanna	1	4,611	04/19/2022 0952	04/22/2022 1443
11993027-1	Wyoming	6	4,608	04/19/2022 0940	04/22/2022 1428
11992708-2	Susquehanna	10	4,592	04/19/2022 0728	04/22/2022 1200
11991451-1	Wyoming	8	4,572	04/19/2022 0438	04/22/2022 0850
11993817-2	Bradford	3	4,562	04/19/2022 0638	04/22/2022 1040
11993519-2	Wayne	13	4,544	04/19/2022 1001	04/22/2022 1345
11989966-2	Wyoming	12	4,536	04/19/2022 0759	04/22/2022 1135
11992084-1	Wayne	2	4,475	04/19/2022 1005	04/22/2022 1240
11992790-2	Susquehanna	9	4,385	04/19/2022 1009	04/22/2022 1114
11993029-1	Wayne	7	4,345	04/19/2022 0940	04/22/2022 1005
11994026-1	Wayne	12	4,295	04/19/2022 1102	04/22/2022 1037
11991787-1	Susquehanna	1	4,284	04/19/2022 1138	04/22/2022 1102
11991460-1	Susquehanna	2	4,171	04/19/2022 0159	04/21/2022 2330
11987915-1	Wyoming	164	4,158	04/19/2022 0052	04/21/2022 2210
11988319-4	Susquehanna	12	4,150	04/19/2022 1420	04/22/2022 1130
11990227-2	Wayne	1	4,139	04/19/2022 1411	04/22/2022 1110
11987908-3	Susquehanna	4	4,095	04/19/2022 0049	04/21/2022 2104
11987908-3	Susquehanna	7	4,095	04/19/2022 0049	04/21/2022 2104
11987908-1	Susquehanna	65	4,095	04/19/2022 0049	04/21/2022 2104
11991069-2	Wyoming	2	4,090	04/19/2022 2043	04/22/2022 1653
11989130-1	Susquehanna	6	4,081	04/19/2022 0329	04/21/2022 2330
11988100-1	Susquehanna	2	4,058	04/19/2022 0017	04/21/2022 1955
11991465-1	Susquehanna	34	4,020	04/19/2022 0050	04/21/2022 1950
11988678-1	Susquehanna	10	4,005	04/19/2022 0445	04/21/2022 2330
11988270-1	Bradford	10	3,967	04/19/2022 0121	04/21/2022 1928
11988973-1	Susquehanna	2	3,956	04/19/2022 0404	04/21/2022 2200
11992018-1	Susquehanna	6	3,930	04/19/2022 0134	04/21/2022 1904
11987928-2	Wyoming	114	3,930	04/19/2022 0104	04/21/2022 1834

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11990072-3	Susquehanna	65	3,929	04/19/2022 0031	04/21/2022 1800
11990600-2	Wayne	13	3,927	04/19/2022 0233	04/21/2022 2000
11989478-1	Susquehanna	485	3,903	04/19/2022 0056	04/21/2022 1759
11992519-1	Wyoming	1	3,901	04/19/2022 1902	04/22/2022 1203
11991501-1	Wyoming	2	3,857	04/19/2022 0314	04/21/2022 1931
11990280-1	Susquehanna	5	3,851	04/19/2022 0549	04/21/2022 2200
11990443-1	Susquehanna	16	3,843	04/19/2022 0212	04/21/2022 1815
11992004-2	Susquehanna	23	3,820	04/19/2022 0105	04/21/2022 1645
11991663-1	Susquehanna	76	3,812	04/19/2022 0208	04/21/2022 1740
11991864-1	Susquehanna	1	3,812	04/19/2022 0157	04/21/2022 1729
11992164-1	Wyoming	11	3,800	04/19/2022 0225	04/21/2022 1745
11988020-1	Susquehanna	172	3,797	04/19/2022 0138	04/21/2022 1655
11992170-1	Susquehanna	17	3,791	04/19/2022 0121	04/21/2022 1632
11991285-1	Sullivan	2	3,788	04/19/2022 0339	04/21/2022 1847
11992764-1	Susquehanna	6	3,787	04/19/2022 2153	04/22/2022 1300
11992345-1	Susquehanna	13	3,786	04/19/2022 0326	04/21/2022 1832
11991453-2	Wyoming	7	3,785	04/19/2022 1856	04/22/2022 1001
11992628-1	Susquehanna	43	3,778	04/19/2022 0341	04/21/2022 1839
11988215-1	Susquehanna	48	3,774	04/19/2022 0258	04/21/2022 1752
11988160-2	Bradford	10	3,773	04/19/2022 0226	04/21/2022 1719
11992822-2	Susquehanna	199	3,772	04/19/2022 0121	04/21/2022 1613
11991038-1	Wyoming	116	3,771	04/19/2022 0239	04/21/2022 1730
11993028-2	Susquehanna	12	3,770	04/19/2022 0338	04/21/2022 1828
11988287-1	Susquehanna	23	3,757	04/19/2022 0212	04/21/2022 1649
11988319-2	Susquehanna	11	3,751	04/19/2022 0306	04/21/2022 1737
11990261-1	Wayne	19	3,749	04/19/2022 0233	04/21/2022 1702
11990094-1	Wayne	208	3,749	04/19/2022 0233	04/21/2022 1702
11990329-1	Susquehanna	102	3,745	04/19/2022 0258	04/21/2022 1723
11989247-2	Susquehanna	172	3,736	04/19/2022 0807	04/21/2022 2223
11989993-2	Susquehanna	11	3,723	04/19/2022 0348	04/21/2022 1751
11992794-1	Susquehanna	13	3,723	04/19/2022 1031	04/22/2022 0034
11991498-1	Susquehanna	13	3,704	04/19/2022 0326	04/21/2022 1710
11992612-1	Susquehanna	73	3,699	04/19/2022 0201	04/21/2022 1540
11991347-1	Wyoming	15	3,686	04/19/2022 0212	04/21/2022 1538
11988117-1	Susquehanna	133	3,681	04/19/2022 0212	04/21/2022 1533
11988110-1	Wyoming	225	3,680	04/19/2022 0212	04/21/2022 1532
11991579-1	Susquehanna	10	3,675	04/19/2022 0334	04/21/2022 1649

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11989419-2	Wayne	13	3,668	04/19/2022 0621	04/21/2022 1929
11991323-1	Wyoming	9	3,654	04/19/2022 0501	04/21/2022 1755
11988270-1	Bradford	38	3,650	04/19/2022 0638	04/21/2022 1928
11992879-1	Wyoming	40	3,649	04/19/2022 0212	04/21/2022 1501
11992574-3	Susquehanna	4	3,644	04/19/2022 0326	04/21/2022 1610
11987908-1	Susquehanna	209	3,636	04/19/2022 0049	04/21/2022 1325
11987908-2	Susquehanna	11	3,636	04/19/2022 0049	04/21/2022 1325
11987928-2	Wyoming	86	3,630	04/19/2022 0104	04/21/2022 1334
11992417-1	Bradford	28	3,619	04/19/2022 0226	04/21/2022 1445
11992525-1	Susquehanna	9	3,617	04/19/2022 0326	04/21/2022 1543
11991929-2	Susquehanna	46	3,617	04/19/2022 0334	04/21/2022 1551
11993818-1	Sullivan	4	3,605	04/19/2022 1225	04/22/2022 0030
11991864-1	Susquehanna	23	3,585	04/19/2022 0157	04/21/2022 1342
11992789-1	Susquehanna	28	3,572	04/19/2022 0326	04/21/2022 1458
11992424-4	Bradford	4	3,558	04/19/2022 0226	04/21/2022 1344
11991651-1	Susquehanna	2	3,555	04/19/2022 0208	04/21/2022 1323
11991655-1	Susquehanna	7	3,534	04/19/2022 0326	04/21/2022 1420
11992524-1	Susquehanna	10	3,529	04/19/2022 0141	04/21/2022 1230
11988123-1	Wyoming	194	3,528	04/19/2022 0212	04/21/2022 1300
11988287-1	Susquehanna	1	3,528	04/19/2022 0212	04/21/2022 1300
11991002-3	Wyoming	26	3,508	04/19/2022 0324	04/21/2022 1352
11992640-1	Susquehanna	55	3,505	04/19/2022 0131	04/21/2022 1156
11992673-1	Susquehanna	106	3,503	04/19/2022 0715	04/21/2022 1738
11991459-1	Susquehanna	3	3,502	04/19/2022 1308	04/21/2022 2330
11991285-1	Sullivan	2	3,490	04/19/2022 0246	04/21/2022 1256
11992436-1	Bradford	13	3,485	04/19/2022 0226	04/21/2022 1231
11992640-1	Susquehanna	24	3,485	04/19/2022 0131	04/21/2022 1136
11992640-1	Susquehanna	85	3,476	04/19/2022 0131	04/21/2022 1127
11991640-1	Susquehanna	15	3,470	04/19/2022 0157	04/21/2022 1147
11989310-1	Wyoming	2	3,454	04/19/2022 0856	04/21/2022 1830
11988109-2	Wyoming	33	3,450	04/19/2022 0212	04/21/2022 1142
11989378-4	Wyoming	11	3,448	04/19/2022 0501	04/21/2022 1429
11989564-2	Wayne	1	3,436	04/19/2022 1014	04/21/2022 1930
11989473-2	Susquehanna	9	3,435	04/19/2022 0932	04/21/2022 1847
11988956-1	Susquehanna	9	3,420	04/19/2022 0713	04/21/2022 1613
11991285-1	Sullivan	577	3,410	04/19/2022 0339	04/21/2022 1229
11992641-1	Susquehanna	1	3,405	04/19/2022 1025	04/21/2022 1910

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11992800-1	Sullivan	1	3,405	04/19/2022 0721	04/21/2022 1606
11991411-1	Susquehanna	49	3,384	04/19/2022 0229	04/21/2022 1053
11992710-1	Bradford	13	3,377	04/19/2022 0318	04/21/2022 1135
11992417-1	Bradford	11	3,374	04/19/2022 0226	04/21/2022 1040
11991051-1	Wyoming	3	3,360	04/19/2022 0940	04/21/2022 1740
11992826-1	Bradford	24	3,353	04/19/2022 0017	04/21/2022 0810
11991740-3	Wayne	1	3,329	04/20/2022 1011	04/22/2022 1740
11989410-1	Wayne	44	3,322	04/19/2022 0524	04/21/2022 1246
11992464-1	Susquehanna	20	3,315	04/19/2022 0559	04/21/2022 1314
11991901-2	Sullivan	8	3,312	04/19/2022 1025	04/21/2022 1737
11988921-1	Susquehanna	198	3,296	04/19/2022 0610	04/21/2022 1306
11993667-1	Susquehanna	11	3,289	04/19/2022 1406	04/21/2022 2055
11989362-1	Susquehanna	4	3,273	04/19/2022 0912	04/21/2022 1545
11991483-1	Susquehanna	2	3,257	04/20/2022 0728	04/22/2022 1345
11990131-3	Wayne	30	3,229	04/19/2022 0956	04/21/2022 1545
11990197-1	Wyoming	21	3,208	04/19/2022 1402	04/21/2022 1930
11989410-1	Wayne	24	3,206	04/19/2022 0524	04/21/2022 1050
11989442-3	Wyoming	8	3,187	04/19/2022 0941	04/21/2022 1448
11988100-1	Susquehanna	13	3,157	04/19/2022 0017	04/21/2022 0454
11991026-1	Wyoming	14	3,147	04/19/2022 1531	04/21/2022 1958
11991656-4	Susquehanna	3	3,104	04/20/2022 0925	04/22/2022 1309
11990157-1	Wayne	6	3,101	04/19/2022 1339	04/21/2022 1720
11988319-2	Susquehanna	68	3,077	04/19/2022 1420	04/21/2022 1737
11991852-1	Bradford	3	3,044	04/20/2022 1130	04/22/2022 1414
11992428-1	Bradford	7	3,042	04/19/2022 0226	04/21/2022 0508
11989908-1	Susquehanna	4	3,033	04/19/2022 0957	04/21/2022 1230
11990707-2	Wyoming	75	3,020	04/19/2022 0940	04/21/2022 1200
11993000-1	Wyoming	10	3,019	04/19/2022 0940	04/21/2022 1159
11988359-2	Bradford	7	3,018	04/19/2022 0339	04/21/2022 0557
11988215-1	Susquehanna	2	3,001	04/19/2022 0258	04/21/2022 0459
11992437-1	Bradford	16	2,997	04/19/2022 0226	04/21/2022 0423
11990541-2	Susquehanna	2	2,985	04/19/2022 1627	04/21/2022 1812
11990099-2	Wayne	48	2,982	04/19/2022 1122	04/21/2022 1304
11992602-1	Bradford	42	2,963	04/19/2022 0017	04/21/2022 0140
11990849-2	Wyoming	3	2,960	04/19/2022 1910	04/21/2022 2030
11991837-2	Susquehanna	1	2,889	04/20/2022 1102	04/22/2022 1111
11991370-1	Susquehanna	7	2,784	04/19/2022 1706	04/21/2022 1530

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11988269-1	Wyoming	21	2,763	04/19/2022 0201	04/21/2022 0004
11992298-2	Wyoming	2	2,701	04/20/2022 1612	04/22/2022 1313
11992490-1	Susquehanna	9	2,682	04/20/2022 1837	04/22/2022 1519
11988100-1	Susquehanna	2	2,678	04/19/2022 0017	04/20/2022 2055
11987874-1	Bradford	148	2,678	04/19/2022 0017	04/20/2022 2055
11987871-1	Bradford	114	2,678	04/19/2022 0017	04/20/2022 2055
11991153-1	Bradford	621	2,645	04/19/2022 0145	04/20/2022 2150
11991980-1	Wyoming	2	2,636	04/19/2022 1816	04/21/2022 1412
11991854-1	Susquehanna	169	2,630	04/19/2022 0342	04/20/2022 2332
11991465-1	Susquehanna	21	2,578	04/19/2022 0050	04/20/2022 1948
11989410-1	Wayne	127	2,575	04/19/2022 0524	04/21/2022 0019
11991517-1	Susquehanna	4	2,571	04/19/2022 0049	04/20/2022 1940
11988014-1	Susquehanna	203	2,555	04/19/2022 0131	04/20/2022 2006
11992341-2	Susquehanna	27	2,531	04/19/2022 0322	04/20/2022 2133
11988102-1	Susquehanna	144	2,529	04/19/2022 0141	04/20/2022 1950
11988014-1	Susquehanna	273	2,507	04/19/2022 0157	04/20/2022 1944
11988014-1	Susquehanna	11	2,500	04/19/2022 0157	04/20/2022 1937
11991207-1	Susquehanna	30	2,497	04/19/2022 0206	04/20/2022 1943
11992414-1	Bradford	11	2,494	04/19/2022 0226	04/20/2022 2000
11990770-1	Susquehanna	219	2,493	04/19/2022 0207	04/20/2022 1940
11988270-1	Bradford	32	2,486	04/19/2022 0638	04/21/2022 0004
11988142-1	Bradford	244	2,486	04/19/2022 0638	04/21/2022 0004
11999082-1	Wyoming	331	2,486	04/19/2022 0638	04/21/2022 0004
11991019-1	Susquehanna	122	2,477	04/19/2022 0121	04/20/2022 1838
11988142-1	Bradford	1	2,467	04/19/2022 0318	04/20/2022 2025
11988493-1	Susquehanna	78	2,443	04/19/2022 0326	04/20/2022 2009
11988493-1	Susquehanna	50	2,439	04/19/2022 0326	04/20/2022 2005
11992944-2	Susquehanna	54	2,438	04/20/2022 2222	04/22/2022 1500
11991446-1	Susquehanna	135	2,427	04/19/2022 0207	04/20/2022 1834
11988493-1	Susquehanna	357	2,424	04/19/2022 0326	04/20/2022 1950
11988305-1	Susquehanna	13	2,419	04/19/2022 0326	04/20/2022 1945
11988100-1	Susquehanna	1	2,412	04/19/2022 0206	04/20/2022 1818
11988215-1	Susquehanna	50	2,409	04/19/2022 0258	04/20/2022 1907
11991002-2	Wyoming	18	2,406	04/19/2022 0324	04/20/2022 1930
11988215-1	Susquehanna	123	2,396	04/19/2022 0258	04/20/2022 1854
11988100-1	Susquehanna	131	2,393	04/19/2022 0206	04/20/2022 1759
11988160-1	Bradford	326	2,379	04/19/2022 0226	04/20/2022 1805

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11988305-1	Susquehanna	18	2,370	04/19/2022 0326	04/20/2022 1856
11989070-1	Susquehanna	6	2,356	04/19/2022 0739	04/20/2022 2255
11992461-1	Susquehanna	11	2,355	04/19/2022 2228	04/21/2022 1343
11990452-1	Susquehanna	10	2,353	04/19/2022 0407	04/20/2022 1920
11990744-1	Susquehanna	2	2,323	04/19/2022 0302	04/20/2022 1745
11990452-1	Susquehanna	22	2,320	04/19/2022 0407	04/20/2022 1847
11988305-1	Susquehanna	128	2,317	04/19/2022 0326	04/20/2022 1803
11989410-1	Wayne	91	2,315	04/19/2022 0524	04/20/2022 1959
11990744-1	Susquehanna	2	2,307	04/19/2022 0302	04/20/2022 1729
11990073-1	Susquehanna	18	2,300	04/19/2022 0511	04/20/2022 1931
11991653-1	Susquehanna	64	2,295	04/19/2022 0326	04/20/2022 1741
11988305-1	Susquehanna	114	2,285	04/19/2022 0326	04/20/2022 1731
11990744-1	Susquehanna	8	2,280	04/19/2022 0302	04/20/2022 1702
11992180-1	Wyoming	22	2,275	04/19/2022 0501	04/20/2022 1856
11990493-1	Wyoming	5	2,272	04/19/2022 0608	04/20/2022 2000
11991669-2	Bradford	3	2,269	04/19/2022 0226	04/20/2022 1615
11988305-1	Susquehanna	693	2,259	04/19/2022 0326	04/20/2022 1705
11990972-1	Wyoming	71	2,235	04/19/2022 0440	04/20/2022 1755
11991430-1	Susquehanna	72	2,228	04/19/2022 0206	04/20/2022 1514
11988503-1	Susquehanna	307	2,219	04/19/2022 0326	04/20/2022 1625
11988181-1	Susquehanna	101	2,209	04/19/2022 0151	04/20/2022 1440
11992014-1	Susquehanna	3	2,205	04/19/2022 0157	04/20/2022 1442
11991448-1	Wyoming	19	2,205	04/19/2022 0438	04/20/2022 1723
11991286-2	Bradford	3	2,201	04/19/2022 0629	04/20/2022 1910
11988142-1	Bradford	5	2,201	04/19/2022 0318	04/20/2022 1559
11991083-1	Susquehanna	8	2,200	04/19/2022 0157	04/20/2022 1437
11990825-2	Bradford	1	2,178	04/19/2022 0419	04/20/2022 1637
11988305-1	Susquehanna	10	2,164	04/19/2022 0326	04/20/2022 1530
11988289-4	Wyoming	96	2,145	04/19/2022 0225	04/20/2022 1410
11990746-1	Susquehanna	8	2,134	04/19/2022 0540	04/20/2022 1714
11990985-1	Wyoming	76	2,133	04/19/2022 0314	04/20/2022 1447
11990763-1	Susquehanna	47	2,130	04/19/2022 0542	04/20/2022 1712
11988288-1	Susquehanna	1	2,126	04/19/2022 0304	04/20/2022 1430
11988288-1	Susquehanna	617	2,126	04/19/2022 0304	04/20/2022 1430
11991470-1	Bradford	16	2,106	04/19/2022 0318	04/20/2022 1424
11988063-2	Bradford	5	2,099	04/19/2022 0145	04/20/2022 1244
11991821-1	Susquehanna	160	2,097	04/19/2022 0326	04/20/2022 1423

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11989662-1	Wayne	11	2,092	04/19/2022 1043	04/20/2022 2135
11988627-1	Wayne	46	2,089	04/19/2022 0324	04/20/2022 1413
11988951-2	Bradford	1	2,087	04/19/2022 0633	04/20/2022 1720
11990222-1	Wyoming	28	2,078	04/19/2022 0502	04/20/2022 1540
11990575-2	Sullivan	18	2,075	04/19/2022 0238	04/20/2022 1313
11992986-1	Susquehanna	10	2,041	04/20/2022 2306	04/22/2022 0907
11990131-2	Wayne	1	2,034	04/19/2022 0956	04/20/2022 1950
11989245-1	Tioga	1	2,017	04/19/2022 0834	04/20/2022 1811
11989765-2	Wyoming	81	2,011	04/19/2022 0229	04/20/2022 1200
11991113-1	Bradford	88	2,010	04/19/2022 0126	04/20/2022 1056
11988722-1	Sullivan	104	2,010	04/19/2022 0126	04/20/2022 1056
11989089-2	Lycoming	3	2,005	04/19/2022 0801	04/20/2022 1726
11988160-1	Bradford	21	1,998	04/19/2022 0226	04/20/2022 1144
11991531-1	Bradford	4	1,978	04/19/2022 0501	04/20/2022 1359
11990100-1	Wayne	170	1,975	04/19/2022 0526	04/20/2022 1421
11991666-1	Bradford	8	1,964	04/19/2022 0446	04/20/2022 1330
11990073-1	Susquehanna	4	1,955	04/19/2022 1025	04/20/2022 1900
11990727-1	Bradford	37	1,948	04/19/2022 0226	04/20/2022 1054
11988215-1	Susquehanna	26	1,945	04/19/2022 0258	04/20/2022 1123
11990755-1	Susquehanna	3	1,937	04/19/2022 0807	04/20/2022 1624
11991901-1	Sullivan	15	1,926	04/19/2022 1025	04/20/2022 1831
11990743-1	Sullivan	12	1,922	04/19/2022 0233	04/20/2022 1035
11992792-2	Susquehanna	5	1,922	04/21/2022 0717	04/22/2022 1519
11991455-1	Bradford	8	1,919	04/19/2022 0332	04/20/2022 1131
11989301-1	Susquehanna	211	1,914	04/19/2022 1456	04/20/2022 2250
11993046-1	Susquehanna	1	1,903	04/21/2022 1107	04/22/2022 1850
11988915-2	Sullivan	9	1,891	04/19/2022 0339	04/20/2022 1110
11993463-1	Susquehanna	1	1,885	04/21/2022 0926	04/22/2022 1651
11988736-1	Bradford	11	1,878	04/19/2022 0422	04/20/2022 1140
11988913-1	Sullivan	53	1,875	04/19/2022 0325	04/20/2022 1040
11989238-2	Bradford	11	1,864	04/19/2022 0340	04/20/2022 1044
11988767-1	Bradford	22	1,862	04/19/2022 0438	04/20/2022 1140
11988502-1	Susquehanna	213	1,862	04/19/2022 0326	04/20/2022 1028
11990648-1	Wayne	4	1,852	04/19/2022 1719	04/21/2022 0011
11993864-1	Bradford	29	1,840	04/21/2022 0642	04/22/2022 1322
11990100-1	Wayne	8	1,840	04/19/2022 0526	04/20/2022 1206
11988066-1	Susquehanna	277	1,836	04/19/2022 0326	04/20/2022 1002

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11991009-1	Wyoming	41	1,818	04/19/2022 0438	04/20/2022 1056
11991338-1	Bradford	44	1,817	04/19/2022 0332	04/20/2022 0949
11989805-1	Wayne	4	1,813	04/19/2022 1127	04/20/2022 1740
11989750-1	Wyoming	9	1,789	04/19/2022 0241	04/20/2022 0830
11989781-4	Wyoming	2	1,760	04/21/2022 0438	04/22/2022 0958
11991922-1	Susquehanna	43	1,741	04/20/2022 1126	04/21/2022 1627
11991915-1	Bradford	3	1,732	04/19/2022 0754	04/20/2022 1246
11991767-1	Wyoming	1	1,719	04/20/2022 1021	04/21/2022 1500
11991947-1	Bradford	23	1,697	04/19/2022 0831	04/20/2022 1248
11990704-1	Sullivan	5	1,667	04/19/2022 1603	04/20/2022 1950
11989870-1	Wyoming	1	1,664	04/19/2022 1148	04/20/2022 1532
11988627-1	Wayne	50	1,653	04/19/2022 1040	04/20/2022 1413
11988288-1	Susquehanna	46	1,640	04/19/2022 1110	04/20/2022 1430
11990618-1	Tioga	1	1,640	04/19/2022 0724	04/20/2022 1044
11993044-1	Bradford	2	1,636	04/20/2022 1624	04/21/2022 1940
11990087-1	Wayne	28	1,636	04/19/2022 1254	04/20/2022 1610
11989232-1	Bradford	9	1,618	04/19/2022 0830	04/20/2022 1128
11990414-1	Wayne	12	1,580	04/19/2022 1201	04/20/2022 1421
11991676-1	Bradford	3	1,579	04/20/2022 0941	04/21/2022 1200
11991858-1	Susquehanna	1	1,577	04/19/2022 1026	04/20/2022 1243
11992881-2	Susquehanna	1	1,571	04/21/2022 0845	04/22/2022 1056
11990676-1	Wyoming	180	1,570	04/19/2022 0804	04/20/2022 1014
11990793-1	Sullivan	4	1,558	04/19/2022 0845	04/20/2022 1043
11989266-1	Bradford	27	1,543	04/19/2022 0755	04/20/2022 0938
11990577-3	Potter	4	1,540	04/19/2022 1645	04/20/2022 1825
11991290-1	Bradford	124	1,538	04/19/2022 0629	04/20/2022 0807
11992170-1	Susquehanna	46	1,527	04/20/2022 1505	04/21/2022 1632
11993330-2	Susquehanna	3	1,526	04/21/2022 1302	04/22/2022 1428
11990304-1	Bradford	16	1,516	04/19/2022 0909	04/20/2022 1025
11989175-3	Bradford	20	1,480	04/19/2022 0820	04/20/2022 0900
11988883-2	Tioga	223	1,474	04/19/2022 1930	04/20/2022 2004
11993583-1	Susquehanna	5	1,420	04/21/2022 1600	04/22/2022 1540
11994231-1	Susquehanna	4	1,418	04/21/2022 1232	04/22/2022 1210
11991397-1	Sullivan	141	1,404	04/19/2022 0818	04/20/2022 0742
11990627-2	Tioga	16	1,386	04/19/2022 1710	04/20/2022 1616
11992086-3	Sullivan	8	1,362	04/20/2022 1413	04/21/2022 1255
11994228-1	Susquehanna	2	1,357	04/21/2022 1317	04/22/2022 1154

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11990575-1	Sullivan	57	1,342	04/19/2022 0238	04/20/2022 0100
11993329-1	Sullivan	3	1,318	04/21/2022 1301	04/22/2022 1059
11993807-1	Wayne	12	1,300	04/21/2022 1932	04/22/2022 1712
11991357-1	Bradford	2	1,299	04/19/2022 1545	04/20/2022 1324
11989173-2	Bradford	37	1,293	04/19/2022 0812	04/20/2022 0545
11991765-1	Susquehanna	20	1,289	04/19/2022 1311	04/20/2022 1040
11987908-1	Susquehanna	1	1,271	04/19/2022 0049	04/19/2022 2200
11990764-2	Sullivan	19	1,263	04/19/2022 1842	04/20/2022 1545
11990619-1	Tioga	5	1,255	04/19/2022 0729	04/20/2022 0424
11990844-1	Bradford	1	1,251	04/19/2022 1903	04/20/2022 1554
11990832-2	Bradford	1	1,249	04/19/2022 1859	04/20/2022 1548
11993362-1	Susquehanna	1	1,239	04/21/2022 1327	04/22/2022 1006
11993362-1	Susquehanna	58	1,239	04/21/2022 1327	04/22/2022 1006
11991361-4	Bradford	2	1,228	04/19/2022 1932	04/20/2022 1600
11994523-1	Wayne	10	1,222	04/21/2022 1953	04/22/2022 1615
11992910-2	Wayne	26	1,211	04/20/2022 2039	04/21/2022 1650
11993753-3	Susquehanna	1	1,209	04/21/2022 1811	04/22/2022 1420
11991002-1	Wyoming	36	1,206	04/19/2022 0324	04/19/2022 2330
11990638-2	Tioga	1	1,197	04/19/2022 1715	04/20/2022 1312
11988100-1	Susquehanna	229	1,195	04/19/2022 0206	04/19/2022 2201
11992086-3	Sullivan	16	1,190	04/20/2022 1705	04/21/2022 1255
11991769-1	Bradford	1	1,177	04/20/2022 1021	04/21/2022 0558
11993770-2	Susquehanna	1	1,175	04/21/2022 1851	04/22/2022 1426
11988320-1	Bradford	258	1,165	04/19/2022 0332	04/19/2022 2257
11988142-1	Bradford	6	1,160	04/19/2022 0318	04/19/2022 2238
11991218-1	Sullivan	6	1,157	04/19/2022 2152	04/20/2022 1709
11988066-1	Susquehanna	26	1,157	04/19/2022 0157	04/19/2022 2114
11988160-1	Bradford	1	1,151	04/19/2022 0226	04/19/2022 2137
11991218-1	Sullivan	1	1,148	04/19/2022 2152	04/20/2022 1700
11991218-1	Sullivan	2	1,148	04/19/2022 2152	04/20/2022 1700
11991285-1	Sullivan	30	1,147	04/19/2022 0339	04/19/2022 2246
11989842-1	Wyoming	14	1,147	04/19/2022 0239	04/19/2022 2146
11993767-1	Susquehanna	3	1,143	04/21/2022 1842	04/22/2022 1345
11988542-3	Tioga	235	1,127	04/19/2022 0423	04/19/2022 2310
11987928-1	Wyoming	29	1,118	04/19/2022 0104	04/19/2022 1942
11994231-1	Susquehanna	1	1,110	04/21/2022 1740	04/22/2022 1210
11993789-1	Susquehanna	2	1,100	04/21/2022 1911	04/22/2022 1331

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11989036-1	Tioga	3	1,089	04/19/2022 0747	04/20/2022 0156
11992596-2	Wayne	2	1,086	04/20/2022 2109	04/21/2022 1515
11992596-2	Wayne	3	1,086	04/20/2022 2109	04/21/2022 1515
11988561-1	Bradford	39	1,082	04/19/2022 0243	04/19/2022 2045
11990618-1	Tioga	20	1,074	04/19/2022 1650	04/20/2022 1044
11989029-1	Susquehanna	5	1,022	04/19/2022 0743	04/20/2022 0045
11990772-1	Sullivan	3	1,009	04/19/2022 1813	04/20/2022 1102
11989872-1	Wyoming	159	1,007	04/19/2022 0519	04/19/2022 2206
11988190-1	Susquehanna	5	985	04/19/2022 0240	04/19/2022 1905
11988482-1	Susquehanna	397	985	04/19/2022 0240	04/19/2022 1905
11988376-1	Susquehanna	127	985	04/19/2022 0240	04/19/2022 1905
11990998-1	Potter	3	983	04/19/2022 0751	04/20/2022 0014
11991356-2	Bradford	3	981	04/19/2022 1609	04/20/2022 0830
11988376-1	Susquehanna	3	976	04/19/2022 0240	04/19/2022 1856
11988877-1	Bradford	128	970	04/19/2022 0629	04/19/2022 2239
11993821-1	Susquehanna	1	969	04/21/2022 2021	04/22/2022 1230
11991080-1	Tioga	10	966	04/19/2022 0610	04/19/2022 2216
11989553-1	Wyoming	249	956	04/19/2022 0340	04/19/2022 1936
11990465-1	Tioga	3	953	04/19/2022 0709	04/19/2022 2302
11989162-1	Tioga	4	948	04/19/2022 0412	04/19/2022 2000
11993785-1	Susquehanna	1	947	04/21/2022 1903	04/22/2022 1050
11988274-1	Wyoming	39	943	04/19/2022 0314	04/19/2022 1857
11990793-1	Sullivan	18	943	04/19/2022 1900	04/20/2022 1043
11988142-1	Bradford	8	940	04/19/2022 0638	04/19/2022 2218
11988305-1	Susquehanna	1	937	04/19/2022 0326	04/19/2022 1903
11988880-1	Bradford	126	925	04/19/2022 0629	04/19/2022 2154
11988878-1	Bradford	156	925	04/19/2022 0629	04/19/2022 2154
11990378-1	Wyoming	33	920	04/19/2022 0438	04/19/2022 1958
11993812-1	Susquehanna	1	919	04/21/2022 1949	04/22/2022 1108
11988795-4	Bradford	91	916	04/19/2022 0638	04/19/2022 2154
11992552-3	Tioga	6	902	04/20/2022 2028	04/21/2022 1130
11988795-4	Bradford	136	901	04/19/2022 0638	04/19/2022 2139
11988305-1	Susquehanna	12	898	04/19/2022 0326	04/19/2022 1824
11989399-1	Tioga	3	898	04/19/2022 0513	04/19/2022 2011
11987954-1	Tioga	5	892	04/19/2022 0122	04/19/2022 1614
11991418-1	Susquehanna	2	887	04/20/2022 0516	04/20/2022 2003
11993551-2	Susquehanna	6	886	04/21/2022 0957	04/22/2022 0043

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11989101-1	Sullivan	56	886	04/19/2022 0329	04/19/2022 1815
11989101-1	Sullivan	15	886	04/19/2022 0329	04/19/2022 1815
11989101-1	Sullivan	12	886	04/19/2022 0329	04/19/2022 1815
11989101-1	Sullivan	5	886	04/19/2022 0329	04/19/2022 1815
11988850-1	Tioga	12	880	04/19/2022 0122	04/19/2022 1602
11989116-2	Tioga	68	879	04/19/2022 0747	04/19/2022 2226
11988615-1	Bradford	33	873	04/19/2022 0419	04/19/2022 1852
11989028-1	Bradford	20	866	04/19/2022 0304	04/19/2022 1730
11989587-1	Wyoming	343	855	04/19/2022 0441	04/19/2022 1856
11993850-1	Bradford	2	851	04/21/2022 2149	04/22/2022 1200
11988708-2	Tioga	26	840	04/19/2022 0555	04/19/2022 1955
11991285-1	Sullivan	65	831	04/19/2022 0339	04/19/2022 1730
11988850-1	Tioga	2	823	04/19/2022 0122	04/19/2022 1505
11991299-2	Tioga	1	822	04/19/2022 2245	04/20/2022 1227
11988758-1	Bradford	13	816	04/19/2022 0620	04/19/2022 1956
11993779-1	Susquehanna	73	814	04/21/2022 1807	04/22/2022 0741
11990373-1	Tioga	13	812	04/19/2022 0721	04/19/2022 2053
11992685-1	Wyoming	85	802	04/21/2022 0026	04/21/2022 1348
11988883-2	Tioga	68	796	04/19/2022 0648	04/19/2022 2004
11987983-1	Bradford	1	794	04/19/2022 0801	04/19/2022 2115
11988911-1	Sullivan	7	793	04/19/2022 0721	04/19/2022 2034
11987983-1	Bradford	12	789	04/19/2022 0801	04/19/2022 2110
11990560-1	Bradford	1	785	04/19/2022 0445	04/19/2022 1750
11990560-1	Bradford	2	785	04/19/2022 0445	04/19/2022 1750
11991203-1	Sullivan	5	783	04/19/2022 2142	04/20/2022 1045
11991203-1	Sullivan	7	783	04/19/2022 2142	04/20/2022 1045
11989038-1	Bradford	16	780	04/19/2022 0724	04/19/2022 2024
11988830-1	Tioga	6	774	04/19/2022 0640	04/19/2022 1934
11990131-1	Wayne	16	772	04/19/2022 0956	04/19/2022 2248
11988172-1	Bradford	193	771	04/19/2022 0226	04/19/2022 1517
11988552-1	Tioga	12	771	04/19/2022 0424	04/19/2022 1715
11988160-1	Bradford	7	771	04/19/2022 0226	04/19/2022 1517
11988171-1	Bradford	379	771	04/19/2022 0226	04/19/2022 1517
11990575-2	Sullivan	2	763	04/20/2022 0030	04/20/2022 1313
11989094-1	Bradford	16	758	04/19/2022 0658	04/19/2022 1936
11989561-1	Wyoming	14	756	04/19/2022 0600	04/19/2022 1836
11989300-1	Tioga	17	749	04/19/2022 0852	04/19/2022 2121

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11988160-1	Bradford	3	738	04/19/2022 0226	04/19/2022 1444
11988066-1	Susquehanna	369	737	04/19/2022 0157	04/19/2022 1414
11989553-1	Wyoming	102	735	04/19/2022 0340	04/19/2022 1555
11990619-1	Tioga	6	730	04/19/2022 1614	04/20/2022 0424
11989756-1	Bradford	22	718	04/19/2022 0724	04/19/2022 1922
11992643-1	Blair	15	715	04/20/2022 2300	04/21/2022 1055
11990111-1	Wayne	13	706	04/19/2022 0944	04/19/2022 2130
11988927-1	Tioga	20	698	04/19/2022 0600	04/19/2022 1738
11988744-1	Tioga	57	693	04/19/2022 0610	04/19/2022 1743
11988544-1	Bradford	14	692	04/19/2022 0357	04/19/2022 1529
11991428-1	Tioga	14	691	04/19/2022 2244	04/20/2022 1015
11993447-1	Bradford	4	683	04/21/2022 0847	04/21/2022 2010
11994010-1	Susquehanna	2	672	04/22/2022 0802	04/22/2022 1914
11992925-3	Susquehanna	7	667	04/21/2022 0927	04/21/2022 2034
11993851-1	Susquehanna	1	666	04/21/2022 2149	04/22/2022 0855
11989004-1	Tioga	1	657	04/19/2022 0731	04/19/2022 1828
11989366-1	Bradford	128	653	04/19/2022 0829	04/19/2022 1922
11991382-2	Bradford	1	652	04/20/2022 0246	04/20/2022 1338
11988725-1	Tioga	13	648	04/19/2022 0604	04/19/2022 1652
11990093-1	Tioga	16	637	04/19/2022 0934	04/19/2022 2011
11988542-2	Tioga	55	632	04/19/2022 0423	04/19/2022 1455
11993006-1	Susquehanna	18	625	04/21/2022 0140	04/21/2022 1205
11989840-1	Wyoming	68	624	04/19/2022 0735	04/19/2022 1759
11988697-1	Tioga	2	621	04/19/2022 0544	04/19/2022 1605
11989247-2	Susquehanna	16	619	04/19/2022 0807	04/19/2022 1826
11994326-1	Susquehanna	30	618	04/22/2022 0727	04/22/2022 1745
11989041-1	Bradford	5	617	04/19/2022 0748	04/19/2022 1805
11989101-1	Sullivan	427	613	04/19/2022 0802	04/19/2022 1815
11994011-2	Susquehanna	1	609	04/22/2022 0805	04/22/2022 1814
11991433-1	Bradford	1	596	04/20/2022 0554	04/20/2022 1550
11992759-4	Susquehanna	4	594	04/21/2022 0631	04/21/2022 1625
11989120-1	Tioga	2	592	04/19/2022 0808	04/19/2022 1800
11989332-1	Bradford	19	578	04/19/2022 0902	04/19/2022 1840
11993160-1	Susquehanna	14	576	04/21/2022 0809	04/21/2022 1745
11989624-1	Sullivan	84	573	04/19/2022 0802	04/19/2022 1735
11998901-1	Sullivan	108	573	04/19/2022 0802	04/19/2022 1735
11998900-1	Sullivan	2	573	04/19/2022 0802	04/19/2022 1735

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11989097-1	Tioga	2	572	04/19/2022 0803	04/19/2022 1735
11994135-2	Wayne	1	572	04/22/2022 0936	04/22/2022 1908
11992805-2	Erie	2	559	04/21/2022 0743	04/21/2022 1702
11989247-2	Susquehanna	1	556	04/19/2022 0807	04/19/2022 1723
11991518-2	Bradford	2	556	04/20/2022 0809	04/20/2022 1725
11988584-2	Mifflin	7	543	04/19/2022 0440	04/19/2022 1343
11991596-1	Sullivan	14	540	04/20/2022 0813	04/20/2022 1713
11993964-1	Wyoming	13	532	04/22/2022 0336	04/22/2022 1228
11991591-1	Sullivan	41	524	04/20/2022 0846	04/20/2022 1730
11992501-1	Bradford	1	522	04/20/2022 1111	04/20/2022 1953
11988774-1	Tioga	136	521	04/19/2022 0623	04/19/2022 1504
11990388-2	Clearfield	17	520	04/19/2022 1519	04/19/2022 2359
11988100-1	Susquehanna	28	516	04/19/2022 0206	04/19/2022 1042
11993948-1	Jefferson	1	515	04/22/2022 0405	04/22/2022 1240
11992312-2	Erie	7	514	04/20/2022 1622	04/21/2022 0056
11991861-1	Susquehanna	18	512	04/20/2022 1059	04/20/2022 1931
11988142-1	Bradford	8	511	04/19/2022 0318	04/19/2022 1149
11988509-1	Tioga	84	505	04/19/2022 0405	04/19/2022 1230
11989389-1	Bradford	16	496	04/19/2022 0924	04/19/2022 1740
11989872-1	Wyoming	48	495	04/19/2022 1351	04/19/2022 2206
11991285-1	Sullivan	90	480	04/19/2022 0339	04/19/2022 1139
11994267-1	Susquehanna	2	480	04/22/2022 1113	04/22/2022 1913
11988066-1	Susquehanna	3	467	04/19/2022 0157	04/19/2022 0944
11990088-1	Tioga	5	452	04/19/2022 0955	04/19/2022 1727
11989286-1	Wyoming	426	450	04/19/2022 0940	04/19/2022 1710
11991423-1	Clearfield	1	443	04/20/2022 0530	04/20/2022 1253
11991922-1	Susquehanna	99	435	04/20/2022 1126	04/20/2022 1841
11989238-1	Bradford	18	428	04/19/2022 0832	04/19/2022 1540
11991839-2	Bradford	1	416	04/20/2022 1104	04/20/2022 1800
11990141-2	Tioga	4	414	04/19/2022 0646	04/19/2022 1340
11988160-1	Bradford	57	405	04/19/2022 0226	04/19/2022 0911
11992728-1	Bradford	42	402	04/21/2022 0510	04/21/2022 1152
11990242-1	Bradford	106	398	04/19/2022 0758	04/19/2022 1436
11988877-1	Bradford	1	395	04/19/2022 0629	04/19/2022 1304
11991405-1	Tioga	2	392	04/20/2022 0428	04/20/2022 1100
11991420-2	Tioga	2	389	04/20/2022 0518	04/20/2022 1147
11991815-1	Bradford	2	389	04/20/2022 1048	04/20/2022 1717


Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
11990165-1	Tioga	84	378	04/19/2022 1232	04/19/2022 1850
11988578-1	Wyoming	110	375	04/19/2022 0438	04/19/2022 1053
11988774-1	Tioga	154	365	04/19/2022 0623	04/19/2022 1228
11993151-1	Susquehanna	18	362	04/21/2022 1231	04/21/2022 1833


Attachment B: FirstEnergy Wind and Precipitation Report

Wind and Precipitation Reports: Graphic 1 and 2 illustrates Snow Totals in the Penelec service territory on April 18 and 19, 2022. Graphic 3 illustrates the maximum wind gusts in the Penelec service territory on April 19, 2022. The graphics are from the National Oceanic and Atmospheric Administration (“NOAA”).


Graphic 1: 24-Hour Snow Totals: Tuesday, April 18, 2022




Graphic 2: 24-Hour Snow Totals: Tuesday, April 19, 2022





Graphic 3: Maximum Wind Gusts: Tuesday, April 19, 2022



Attachment C: Restoration Curve



Attachment D: Order Restoration Graphs




Attachment E: FirstEnergy Meteorologist Reports

Thursday April 16, 2022 @ 0813

Changes.

1. Today – literally no changes for today. Confidence is normal with this graphic.
2. Monday into Tuesday – added nuisance wet snow threat with some details for situational awareness. Confidence is below normal – given the snow will have a hard time accumulating during daylight hours.

Next Update – 9am Sun




Friday, April 17, 2022 @ 0758

Changes.

1. Monday into Tuesday: Expanded snow area and increased amounts. Modified timing. Confidence is below normal given some melting may occur between 2 rounds of snow and snow will have a hard time accumulating during daylight hours. So too with ice – very uncommon in April so have limited amounts to higher elevations only.
2. Tuesday: Added details for afternoon gusts. Confidence is normal with this panel.

Next Update – 11am Mon





Saturday, April 18, 2022 @ 0921

Update:

Small adjustments to the snowfall and ice forecast for Monday and Tuesday. Also small adjustments to the wind gust forecast for Tuesday.

See graphics below for further information.

Next Update by 11am Tuesday



Sunday, April 18, 2022 @ 1228



Update:

Increased area and amounts of freezing rain/ice across portions of eastern WV and western MD this afternoon. Localized areas may see up to .25” of ice and 4” of wet snow by the time precipitation ends this evening.

No other changes.

See graphics below for further information.

Next Update by 11am Tuesday



Monday, April 18, 2022 @ 1426



Update:

Inserted an area in central NJ where occasional wind gusts of 35-45 will be possible overnight tonight. This may mix with periods of heavy rain at times.

No other changes.

See graphics below for further information.

Next Update by 11am Tuesday



Monday, April 19, 2022 @ 0750

Update:

Extended snowfall forecast in northwest PA, where a stubborn, stationary snowband will persist into late morning/early afternoon. Also extended the snowfall forecast in the lake effect areas of Lake Erie where snow showers will persist through the day. Additional 2-4" of wet snow will be possible in these areas.

Expanded wind forecast to include portions of eastern PA and NJ, and increased possible wind gusts across central PA.

See graphics below for further information.

Last Scheduled Update

