

Daniel Marston
Right of Way Agent
PPL Electric Utilities
4001 Sawmill Road
Bloomsburg, Pa 17815
Tel. 610-417-4973
demarston@pplweb.com



June 20, 2022

Ms. Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

**RE: APPLICATION FOR PUBLIC CROSSING
HAAS AVENUE
NORTH SHORE RAILROAD COMPANY
CITY OF SUNBURY
COUNTY OF NORTHUMBERLAND**

Dear Secretary Chiavetta,

In accordance with Public Utility Code, Title 66, Chapter 2702, enclosed please find an application requesting permission to alter crossing of **North Shore Railroad Company**. Said crossing will be within the public right of way confines of Haas Avenue. Located in the City of Sunbury, Northumberland County.

Said crossing will consist of the replacement of existing utility pole PPL# 26824N25307 in the City of Sunbury, Northumberland County, PA. To support existing and future loading conditions, the communication facility that crosses North Shore Railroad rails within the public right-of-way of Haas Avenue.

PPL Electric Utilities will provide copies of same to all parties listed under its Certificate of Service.

Please review and provide the appropriate authorization to this office.

Should you have any questions please contact this office.

Sincerely,

Daniel Marston
Right of Way Agent

Enclosures

cc: Rodney D. Binder, P.E.
Chief-Bureau of Rail Safety
PA Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

BEFORE

PENNSYLVANIA PUBLIC UTILITY COMMISSION

In re: Application of PPL Electric
Utilities for approval of the alteration
of the crossing 591731K by the
replacement of utility pole structure
where Haas Ave crosses at grade the
tracks of North Shore Railroad
Company, located in Sunbury City in
Northumberland County.

Application

Docket No.

To Pennsylvania Public Utility Commission:

1. The name and address of applicant are PPL Electric Utilities Corporation, 2 North Ninth Street, Allentown, PA 18101-1179
2. The name and address of the applicant's attorney are Mallory Jane Sweeney, Associate General Counsel, PPL Electric Utilities Corporation, 2 North Ninth Street Allentown, PA 18101-1179
3. PPL Electric Utilities wishes to raise primaries above tracks of North Shore Railroad Company in Sunbury City, Northumberland County, PA. To support existing and future loading conditions, the communication facilities that cross North Shore Railroad Company rails within the public right-of-way of Haas Ave are to be raised. The above ground communication facilities of utility pole PPL#26824N25307 will be altered.

4. The proposed change is to raise primaries attached to pole to the northwest side of the railroad crossing. The communication facility will be aerial. Haas Ave intersects the railroad at grade. See attached Exhibit "A". The proposed completion date for this project is September 30, 2022.

5. The public utilities, municipalities, corporations and property owners concerned in, or affected by, the crossing alteration are identified in Exhibit "B" attached hereto

6. The expected cost for the construction procedure is \$5,000. PPL Electric Utilities will pay all costs of construction or alteration of the facility, as well as be responsible for installing, maintaining and inspecting the facilities.

7. The alteration is necessary or proper for the following reasons: to provide adequate, efficient, and reasonable communication facilities and power to the public in Northumberland County and surrounding areas.

Wherefore, applicant prays your Honorable Commission to approve the application:

Daniel Marston

Daniel Marston

Right of Way Agent

PPL Electric Utilities Corporation

§ 1.36. Verification.

(a) Applications, petitions, formal complaints, motions and answers thereto containing an averment of fact not appearing of record in the action or containing a denial of fact shall be personally verified by a party thereto or by an authorized officer of the party if a corporation or association. Verification means a signed written statement of fact supported by oath or affirmation or made subject to the penalties of 18 Pa. C.S. §4904 (relating to unsworn falsification to authorities). If verification is required, notarization is not necessary.

(b) The Verification form should comply substantially with the following:

VERIFICATION

I, Daniel Marston, hereby state that the facts above set forth are true and correct (or are true and correct to the best of my knowledge, information and belief) and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Date: 6/20/2022

Daniel Marston

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true copy of the foregoing document upon the participants, listed below, in accordance with the requirements of § 1.54 (relating to service by participant) .

Mark Chappel, P.E. - Chief
Bureau of Project Delivery
P.O. Box 3362
Harrisburg, PA 17105-3362
marchappel@pa.gov

Sunbury City
Attn: Engineering/Permitting
225 Market St
Sunbury, PA 17801
sunbury1@ptd.net

Karen Cummings - Office of Chief Counsel
PennDOT
P.O. Box 8212
Harrisburg, PA 17105-8212
kcummings@pa.gov

North Shore Railroad
Attn: Engineering/Permitting
356 Priestley Ave
Northumberland, PA 17857
grfury@nshr.com

PennDOT Engineering District 3
Cory Kodish
715 Jordan Avenue
P.O. Box 218
Montoursville, PA 17754
ckodish@pa.gov

Zito
Attn: Engineering
18 N Juniata St
Lewistown, PA 17044
kori.ditty@zitomedia.com


Northumberland County Courthouse
Attn: Permits/Public works
201 Market St
Sunbury PA 17801
chuck.hopta@norrycopa.net

Service Electric Cablevision
4949 Liberty Ln #400
Allentown PA 18106
don.phillips@sevc.com

Level 3 Fiber Optic Communications
1025 Eldorado Boulevard
Broomfield Colorado 80021
paul.erickson@lumen.com

Dated this 20th day of June, 2022.

Daniel Marston




PLAN VIEW

CROSSING NUMBER:
591731K

CABLE HEIGHTS	MAX SAG
PRIMARIES (3) 41'-11"	41'-11"
NEUTRAL 38'-1"	36'-8"
BUNDLED PRIMARY 34'-3"	34'-4"
29'-10"	29'-10"
28'-10"	28'-6"
28'-0"	27'-7"

PPL# 26824N25307
LAT/LONG: 40.857283, -76.780338
HEIGHT: 50
CLASS: 2
BASE DIAMETER: 42'-0"
BURY DEPRTH: 7'



PPL# 26820N25299
LAT/LONG: 40.857116, -76.780183
HEIGHT: 50
CLASS: 3
BASE DIAMETER: 39'
BURY DEPRTH: 7'

PROFILE VIEW



CITY: SUNBURY	PROJECT NO: 1
COUNTY: NORTHUMBERLAND	PRINT NO: 1
STATE: PENNSYLVANIA	NO. OF PRINTS: 1
DATE: 4/4/2022	ENGINEERED BY: KATAPULT
DRAWN BY: NIYS	



FILENAME:
EXHIBIT A

EXHIBIT "B"

The public utilities, municipalities, corporations, and property owners concerned in, or affected by, the crossing alteration are:

Mark Chappel, P.E. - Chief
Bureau of Project Delivery
P.O. Box 3362
Harrisburg, PA 17105-3362
marchappel@pa.gov

Karen Cummings - Office of Chief Counsel
PennDOT
P.O. Box 8212
Harrisburg, PA 17105-8212
kcummings@pa.gov

PennDOT Engineering District 3
Cory Kodish
715 Jordan Avenue
P.O. Box 218
Montoursville, PA 17754
ckodish@pa.gov

Northumberland County Courthouse
Attn: Permits/Public works
201 Market St
Sunbury PA 17801
chuck.hopta@norrycopa.net

Sunbury City
Attn: Engineering/Permitting
225 Market St
Sunbury, PA 17801
sunbury1@ptd.net

North Shore Railroad
Attn: Engineering/Permitting
356 Priestley Ave
Northumberland, PA 17857
grfury@nshr.com

Zito
Attn: Engineering
18 N Juniata St
Lewistown, PA 17044
kori.ditty@zitomedia.com

Service Electric Cablevision
4949 Liberty Ln #400
Allentown PA 18106
don.phillips@secvcom

Level 3 Fiber Optic Communications
1025 Eldorado Boulevard
Broomfield Colorado 80021
paul.erickson@lumen.com



- 42'-0" Pole Top
- 41'-7" Double PPL Company Primary
- 40'-10" 8"
- Double PPL Company Primary
- Double PPL Company Primary
- 37'-5" Neutral PPL Company Neut
- 32'-10" Secondary PPL Company
- 32'-5" PPL Company Drip Loop Seco
- 31'-0" Proposed ZitoMedia / Zito We
- 30'-0" Service Electric Cablevision C
- 28'-7" Level 3 (Formerly TelCove) Fi

