



COMMONWEALTH OF PENNSYLVANIA  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
COMMONWEALTH KEYSTONE BUILDING  
400 NORTH STREET, HARRISBURG, PA 17120

BUREAU OF  
INVESTIGATION  
&  
ENFORCEMENT

September 30, 2022

**Via Electronic Filing**

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street  
Harrisburg, PA 17120

Re: Pennsylvania Public Utility Commission,  
Bureau of Investigation and Enforcement v.  
UGI Utilities, Inc.  
Docket No. C-2022-  
**Formal Complaint**

Dear Secretary Chiavetta:

Enclosed for electronic filing please find the Complaint in the above-referenced case on behalf of the Bureau of Investigation and Enforcement of the Pennsylvania Public Utility Commission. Copies have been served on the parties of record in accordance with the Certificate of Service.

Should you have any questions, please do not hesitate to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'K. Myers', written over a white background.

Kourtney L. Myers  
Prosecutor

Bureau of Investigation and Enforcement  
PA Attorney ID No. 316494  
(717) 705-4366  
[komyers@pa.gov](mailto:komyers@pa.gov)

KLM/ac  
Enclosure

cc: Per Certificate of Service

## NOTICE

**A. You must file an Answer within 20 days of the date of service of this Complaint.**

The date of service is the date as indicated at the top of the Secretarial Letter. *See* 52 Pa. Code §1.56(a). The Answer must raise all factual and legal arguments that you wish to claim in your defense, include the docket number of this Complaint, and be verified. You may file your Answer by mailing an original to:

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
400 North Street  
Harrisburg, PA 17120

Or, you may eFile your Answer using the Commission's website at [www.puc.pa.gov](http://www.puc.pa.gov). The link to eFiling is located under the Filing & Resources tab on the homepage. If your Answer is 250 pages or less, you are not required to file a paper copy. If your Answer exceeds 250 pages, you must file a paper copy with the Secretary's Bureau.

**Additionally, please serve a copy on:**

Kourtney L. Myers, Prosecutor  
Pennsylvania Public Utility Commission  
Bureau of Investigation and Enforcement  
400 North Street  
Harrisburg, PA 17210  
[komyers@pa.gov](mailto:komyers@pa.gov)

B. If you fail to answer this Complaint within 20 days, the Bureau of Investigation and Enforcement will request that the Commission issue an Order imposing the requested relief.

C. You may elect not to contest this Complaint by paying the administrative penalty within 20 days. Send only a certified check or money order made payable to the "Commonwealth of Pennsylvania," with the docket number indicated, and mail to:

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
400 North Street  
Harrisburg, PA 17120

D. If you file an Answer which either admits or fails to deny the allegations of the Complaint, the Bureau of Investigation and Enforcement will request that the Commission issue an Order imposing the requested relief set forth in this Complaint.

E. If you file an Answer which contests the Complaint, the matter will be assigned to an Administrative Law Judge for hearing and decision. The Judge is not bound by the penalty set forth in the Complaint and may impose additional and/or alternative penalties as appropriate.

F. If you are a corporation, you must be represented by legal counsel. 52 Pa. Code § 1.21.

G. Alternative formats of this material are available for persons with disabilities by contacting the Commission's ADA Coordinator at 717-787-8714.

**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Pennsylvania Public Utility Commission,	:	
Bureau of Investigation and Enforcement	:	
	:	
v.	:	Docket No. C-2022-
	:	
UGI Utilities, Inc.	:	

---

**FORMAL COMPLAINT**

---

NOW COMES the Bureau of Investigation and Enforcement (“I&E”) of the Pennsylvania Public Utility Commission (“Commission”), by its prosecuting attorneys, and files this Formal Complaint (“Complaint”) against UGI Utilities, Inc. (“UGI” or “Respondent”), pursuant to Sections 182.8(c)-(d) and 182.10 of the Underground Utility Line Protection Law, Act of October 30, 2017, P.L.806, No. 50 (hereinafter referred to as the “PA One Call Law”), 73 P.S. §§ 182.8(c)-(d) and 182.10.<sup>1</sup> In support of its Complaint, I&E respectfully represents the following:

**I. Commission Jurisdiction and Authority**

1. The Pennsylvania Public Utility Commission, with a mailing address of 400 North Street, Harrisburg, PA 17120, is a duly constituted agency of the Commonwealth of Pennsylvania empowered to, *inter alia*, enforce compliance by facility

---

<sup>1</sup> The purpose of the PA One Call Law is to protect the public health and safety by preventing excavation or demolition work from damaging underground lines used in providing electricity, communication, gas, propane, oil delivery, oil product delivery, sewage, water or other service; imposing duties upon the providers of such service and persons and other entities preparing drawings or performing excavation or demolition work; and prescribing penalties.

owners and other stakeholders pursuant to Section 182.10 of the PA One Call Law, 73 P.S. § 182.10.

2. Complainant is the Commission's Bureau of Investigation and Enforcement, which is the bureau established to take enforcement actions against public utilities and other entities subject to the Commission's jurisdiction pursuant to 66 Pa.C.S. § 308.2(a)(11); *See also Implementation of Act 129 of 2008; Organization of Bureaus and Offices*, Docket No. M-2008-2071852 (Order entered August 11, 2011) (delegating authority to initiate proceedings that are prosecutory in nature to I&E), including actions to enforce compliance of the PA One Call Law.

3. Complainant is represented by:

Kourtney L. Myers  
Prosecutor  
Pennsylvania Public Utility Commission  
Bureau of Investigation and Enforcement  
400 North Street  
Harrisburg, PA 17120  
(717) 705-4366  
[komyers@pa.gov](mailto:komyers@pa.gov)

Michael L. Swindler  
Deputy Chief Prosecutor  
Pennsylvania Public Utility Commission  
Bureau of Investigation and Enforcement  
400 North Street  
Harrisburg, PA 17120

4. Respondent is UGI Utilities, Inc. with a main mailing address of 1 UGI Drive, Denver, Pennsylvania, 17517.

5. Respondent is a “facility owner” as that term is defined at 73 P.S. § 176 as it is a “public utility . . . which owns or operates a line.”

6. A “line” or “facility” is defined as “an underground pipe used in carrying, gathering, transporting or providing natural or artificial gas . . . to one or more transportation carriers, consumers or customers of such service and the appurtenances thereto, regardless of whether such line or structure is located on land owned by a person or public agency or whether it is located within an easement or right-of-way.” 73 P.S. § 176.

7. Respondent, as a facility owner, is subject to the power and authority of this Commission pursuant to Section 182.10 of the PA One Call Law, 73 P.S. § 182.10, which requires facility owners to comply with the PA One Call Law.

8. Sections 182.8(c)-(d) and 182.10 of the PA One Call Law, 73 P.S. §§ 182.8(c)-(d) and 182.10, authorize the Commission to, *inter alia*, hear and determine complaints against facility owners for violations of the PA One Call Law and enforce the provisions of the PA One Call Law.

9. Section 182.10(a) of the PA One Call Law, 73 P.S. § 182.10(a), authorizes the Commission to impose administrative penalties on facility owners who violate the PA One Call Law. Section 182.10(b)(1)(i)-(ii) allows for the imposition of an administrative penalty not to exceed \$2,500 for each violation or if the violation results in injury, death, or property damage of \$25,000 or more, an administrative penalty not to exceed \$50,000.

10. Pursuant to the provisions of the applicable Commonwealth statutes, the Commission has jurisdiction over the subject matter of this complaint and the actions of Respondent related thereto.

## II. Factual Background

11. On September 11, 2019 at approximately 11:16 AM, Leeward Construction, Inc. (“Leeward”) placed an excavation routine ticket (“routine ticket”) with the Pennsylvania One Call System (“POCS”) at Serial No. 20192542049 to conduct an excavation with powered equipment. The routine ticket and responses thereto are attached as I&E Exhibits 1A-B, respectively.

12. The purpose of the excavation was to replace a water main for Pennsylvania American Water Company. *See* I&E Exhibit 1A.

13. The routine ticket identified the work site<sup>2</sup> as Brown Street with the nearest intersection of Fallbrook Street in Carbondale City, Lackawanna County, Pennsylvania. *See* I&E Exhibit 1A.

14. Respondent is the facility owner of gas lines and facilities that run underground in the vicinity of the work site.

15. An underground gas line and facility is a “line” or “facility” as defined in 73 P.S. § 176.

16. On September 27, 2019 at 6:55 PM, UGI responded “FIELD MARKED” to Leeward’s routine ticket through the POCS indicating that Respondent had located and marked its underground lines and facilities at the work site. *See* I&E Exhibit 1B.

---

<sup>2</sup> “Work site” is defined in the PA One Call Law as “the specific place denoted on the locate request where excavation or demolition work is being or is planned to be performed.” 73 P.S. § 176.

17. On October 15, 2019, at approximately 8:00 AM, Leeward exposed a UGI gas main that was approximately three (3) feet away from UGI's markout at the work site (hereinafter referred to as "mismark").

18. In response to the mismark, Leeward submitted an alleged violation report ("AVR") with the POCS, pursuant to 73 P.S. § 180(16). Leeward's AVR is attached as I&E Exhibit 2.

19. The purpose of an AVR is to report to the Commission through the POCS an alleged violation of the PA One Call Law that has been committed in association with excavation or demolition work. *See* 73 P.S. §§ 176 and 180(16).

20. In its AVR, Leeward alleges that "[t]he [UGI] gas main . . . was discovered to be 3' off the mark when it was exposed in our ditch line for water main installation." *See* I&E Exhibit 2.

21. In addition to its AVR, Leeward submitted with the POCS photographs of the mismark. Leeward's photographs are attached as I&E Exhibits 3A-B.

22. The photograph at I&E Exhibit 3A depicts a "MARK" post identifying UGI's markout in yellow paint, a 36-inch ruler, and a "DAMAGE" post indicating the actual location of the UGI gas line (although not pictured in this photograph) at the work site.

23. The photograph at I&E Exhibit 3B, taken at a different angle, shows the actual location of the UGI gas line in relation to UGI's markout as identified by the "MARK" post at the work site.

24. The photographs fairly and accurately show the mismark as it appeared on October 15, 2019 at the work site.

25. Collectively, the photographs demonstrate that UGI located and marked its line at the work site approximately 36 inches horizontally from the outside wall of such line.

26. UGI did not locate or mark its underground line at the work site within 18 inches horizontally from the outside wall of such line.

### **III. Violation**

27. Paragraphs 1-26 above are incorporated herein as if stated in their entirety.

28. UGI failed to locate and mark its underground line at the work site within 18 inches horizontally from the outside wall of such line in that UGI located and marked its line at the work site approximately 36 inches horizontally from the outside wall of such line.

If proven, this is a violation of Section 177(5)(i) of the PA One Call Law, 73 P.S. § 177(5)(i) (requiring a facility owner “after receipt of a timely request from an excavator . . . who identifies the work site of excavation . . . he intends to perform . . . [t]o mark, stake, locate or otherwise provide the position of the facility owner’s underground lines at the work site within eighteen inches horizontally from the outside wall of such line in a manner so as to enable the excavator, where appropriate, to employ prudent techniques . . . to determine the precise position of the underground facility owner’s lines”).

Pursuant to the factors set forth in Section 182.10(b)(2)(i)-(vi) of the PA One Call Law, 73 P.S. § 182.10(b)(2)(i)-(vi), the Bureau of Investigation and Enforcement's proposed administrative penalty for this violation is \$1,000.

**WHEREFORE**, the Bureau of Investigation and Enforcement of the Pennsylvania Public Utility Commission respectfully requests that the Commission:

- (a) Find Respondent to be in violation of the PA One Call Law at 73 P.S. § 177(5)(i);
- (b) Impose an administrative penalty upon Respondent in the amount of One Thousand Dollars (\$1,000); and
- (c) Order such other remedies as the Commission may deem appropriate.

Respectfully submitted,



Kourtney L. Myers  
Prosecutor  
PA Attorney ID No. 316494

Pennsylvania Public Utility Commission  
Bureau of Investigation and Enforcement  
Commonwealth Keystone Building  
400 North Street  
Harrisburg, PA 17120  
(717) 705-4366  
[komyers@pa.gov](mailto:komyers@pa.gov)

Date: September 30, 2022

**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Pennsylvania Public Utility Commission	:	
Bureau of Investigation and Enforcement	:	
	:	
v.	:	Docket No. C-2022-
	:	
UGI Utilities, Inc,	:	

**VERIFICATION**

I, Sara Andrade-Locke, Damage Prevention Supervisor, Damage Prevention Section, Bureau of Investigation and Enforcement, hereby state that the facts above set forth are true and correct to the best of my knowledge, information, and belief and that I expect the Bureau will be able to prove the same at any hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: September 30, 2022



---

Sara Andrade-Locke  
Damage Prevention Supervisor  
Damage Prevention Section  
Bureau of Investigation and Enforcement  
Pennsylvania Public Utility Commission  
400 North Street  
Harrisburg, PA 17120

**I&E**

**Exhibit 1A**

=====PENNSYLVANIA UNDERGROUND UTILITY LINE PROTECTION REQUEST=====

Serial Number--[20192542049]-[000] Channel#--[1112AWEB][0242][2019-08]  
Message Type--[NEW][EXCAVATION][ROUTINE]

County--[LACKAWANNA] Municipality--[CARBONDALE CITY]  
Work Site--[BROWN]  
Nearest Intersection--[FALLBROOK]  
Second Intersection--[VILLA]  
At Intersection--[N] Between Intersections--[N] Site Marked in White--[Y]  
Subdivision--[ ]

Location Information--

[ ]  
Caller Lat/Lon--[ ]  
Mapped Type--[P] Mapped Lat/Lon--  
[41.576660/-75.505817,41.576848/-75.505085,41.578669/-75.503893,  
41.578460/-75.503332,41.576585/-75.504815,41.576413/-75.505947]  
Attachments--[http://www.pa811.org/attachments/20192542049]

Type of Work--[WATER MAIN REPLACEMENT AND SERVICES] Depth--[6FT]  
Extent of Excavation--[6FT X 1000FT] Method of Excavation--[DIGGING]  
Equip Type--[HYDRAULIC EXCAVATOR]  
Street--[X] Sidewalk--[X] Pub Prop--[X] Pvt Prop--[X] Other--[ ]  
Private Front--[X] Rear--[ ] Left--[ ] Right--[ ]

Lawful Start Dates--[16-Sep-19] thru [25-Sep-19] Response Due Date--[13-Sep-19]  
Scheduled Excavation Date--[16-Sep-19] Dig Time--[0700] Duration--[6 WEEKS]

Caller--[ALLISON MALPASSE]  
Caller Phone--[570-313-7280]  
Excavator--[LEEWARD CONSTRUCTION]  
Address--[239 GOLF HILL RD]  
City--[HONESDALE] State--[PA] Zip--[18431]  
FAX--[ ] Caller Type--[B]  
Email--[AMALPASSE@LEEWARDCONSTRUCTION.COM]  
Work For--[PENNSYLVANIA AMERICAN WATER CO]  
Onsite Contact--[MIKE ANDERSON]  
Onsite Contact Phone--[570-840-3971]  
Best Time to Call--[ANYTIME]  
Onsite Contact Email--[MANDERSON@LEEWARDCONSTRUCTION.COM]  
Job Number--[511610]

Prepared--[11-Sep-19] at [1116] by [AMALPASSE]  
Remarks--  
[ ]

AF 0 AF =ADAMS CATV GN 0 GN =UGI ARCHBALD HI 0 HI =VERIZON WB STN  
PT 0 PT =PPL ELEC SRTN WW 0 WW =PAWC WILKES-BAR

Serial Number--[20192542049]-[000]  
===== Copyright (c) 2019 by Pennsylvania One Call System, Inc. =====

**I&E**  
**Exhibit 1B**

Ver	CDC	Name	Response	Time	Respondent
0	AF	ADAMS CABLE TV	1-CLEAR NO FACIL	09/12/2019 08:03:13	MB-WEB
1	GN	UGI UTL ARCHBALD	3-FIELD MARKED	09/27/2019 18:55:18	PGN-WEBSVC
1	GN	UGI UTL ARCHBALD	2-CONFLICT. DCTF	09/16/2019 15:47:19	PGN-WEBSVC
1	GN	UGI UTL ARCHBALD	2-CONFLICT. DCTF	09/16/2019 15:40:40	CLS-WEBSVC
1	GN	UGI UTL ARCHBALD	2-CONFLICT. DCTF	09/16/2019 13:47:25	PGN-WEBSVC
0	GN	UGI UTL ARCHBALD	9-NO RESPONSE**	09/16/2019 11:43:02	-KARL
0	GN	UGI UTL ARCHBALD	2-CONFLICT. DCTF	09/13/2019 10:58:59	CLS-WEBSVC
0	HI	VERIZON PENNSYLVANIA LLC	1-CLEAR NO FACIL	09/11/2019 13:38:24	AAA-WEBSVC
0	PT	PPL ELECTRIC UTILITIES CO	1-CLEAR NO FACIL	09/13/2019 10:58:56	CLS-WEBSVC
0	WW	PENNSYLVANIA AMERICAN WAT	3-FIELD MARKED	09/13/2019 12:54:39	CHU-WEBSVC

**I&E**  
**Exhibit 2**



# Alleged Violation Report

PA Act 287, as amended 73 P. S. § 176 et. seq.  
Powered by Pennsylvania One Call System, Inc.

**AVR Number** AVR2019OCT150027  
**AVR Version** 1  
**First Name** SHANE **Last Name** ELLIS  
**Company Name** LEEWARD CONSTRUCTION INC  
**Address** 239 GOLF HILL RD  
**City** HONESDALE  
**State** PA  
**Zip Code** 18431  
**Email** sellis@leewardconstruction.com **Phone** 5702297242

## Role

**Submitter Role(s) (?)**

- Facility Owner
- Excavator
- Locator
- Other
- Designer
- Project Owner
- Enforcement Agency

**Are you representing a company other than your own?**  Yes  No

**What company or individual are you representing?**

## Alleged Violation Information

**Type of Alleged Violation (?)** Facility Owner Issue

**Reason** Marked incorrectly §2(5)

**When did the alleged violation occur? (?)** 10/15/2019  
08:00:00 AM

**Was the One Call System notified?**  Yes  No

**Original Serial Number** Please enter the 11 digit One Call Serial Number under which work was taking place, which will populate the work site information of this alleged violation.  
20192542049

**Related Damage Serial Number, if applicable**

Other Related Serial Numbers (?)

Was the excavation exempt from One Call notification?  Yes  No  Unknown

Reason for Exemption

Event Information 

County LACKAWANNA  
Municipality CARBONDALE CITY  
Ward 0  
Work Site BROWN  
Nearest Intersection FALLBROOK  
Second Intersection VILLA

Geolocation (?)

Affected Facility Information 

Primary Right of Way Type Public  
Public Right of Way Type City Street  
Private Right of Way Type

Affected Operation Gas  
Facility Subtype Affected Distribution  
Facility Owner Company Name UGI Utilities, Inc.

Contact First Name Last Name

Address

City

State

Zip

Email Phone

Joint Trench?  Yes  No  Unknown

Involve Cross Bore?  Yes  No  Unknown

Measured Depth from Grade 18" - 36" / 46 - 91 cm

Exact Measured Depth from Grade Enter the inches or centimeters with number and measurement used



## Work Information

**Start Date of Excavation (?)** 10/15/2019  
07:00:00 AM

**Excavation Activity** WATER

**Excavator Company Name** Leeward Construction, Inc.

**Contact First Name** Shane **Last Name** Ellis

**Address** 239 Golf Hill Rd

**City** Honesdale

**State** PA

**Zip** 18431

**Email** sellis@leewardconstruction.com **Phone** 570-229-7242

**Marked in White**  Yes  No  Unknown

**Method of Excavation** DIGGING

**Equipment Used** What Equipment was used for excavation or demolition when the event occurred?  
BACKHOE/TRACKHOE

**Type of Excavator** What is the type of excavator for whom the work was being done when the event occurred?

**Did Excavator incur down time?**  Yes  No  Unknown

**How much down time?**

**Estimated cost of down time**

**Was a response posted to the One Call System?**  Yes  No  Unknown

**Was the design serial number on the plans/bid documents?**  Yes  No  Unknown

**Were the lines shown on the plans/bid documents?**  Yes  No  Unknown

**Project Owner Company Name**

**Contact First Name** **Last Name**

**Address**

**City**

**State**

**Zip**

Email

Phone

## Event Impact



Did Violation result in underground damage or near miss event?  Near Miss

OSHA Report Filed?  Yes  No

OSHA Report Number

Was 911 called?  Yes  No

Name of 911 Caller

Fire Response  Yes  No

Police Response  Yes  No

Number of Injuries (?) 0

Number of Fatalities 0

Was there an evacuation?  Yes  No

Number of people evacuated?

Traffic Stopped?  Yes  No

Service Interrupted?  Yes  No

Duration of Service Interruption?

Exact Value of Service Interruption

Approximately how many customers were affected?

Exact Number of Customers Affected

Cost of Damaged Line Repair? \$0

Exact Cost of Damaged Line Repair

Was other property damaged?  Yes  No

What other property was damaged?

Cost of Other Property Repair

## Locator/Locate Information



Who was the facility line locator?  Contract Locator

Locator Company

Contact First Name

Last Name

Address

City

State

Zip

Email

Phone

Was the line marked?

- Accurately  Inaccurately/Incompletely  Not Marked  
 Unknown

Were facilities marked according to APWA/CGA temporary marking color code (ANSI standard Z535.1)?

- Yes  No  Unknown

What types of marks were present?

- Paint  
 Flags  
 Stakes  
 Other

Were offset markings used?

- Yes  No  Unknown

Condition of Marks

Readily Visible

Was the line marked by the response due date or within the agreed upon locate schedule? (?)

- Yes  No  Unknown

Reason for Late Locate

Unknown

Was the excavation within the tolerance zone? (?)

- Yes  No  Unknown

Was there an indication of underground facilities (clear evidence) in the excavation area?

- Yes  No  Unknown

What was the evidence? (meter/pedestal, pipeline marker, valve box, hydrant, manhole, etc.)

Paint, Meters, Valve box

What method(s) were used to locate the facility?

- Electronic  Records  
 Visual  Exposed

Did the excavator request payment under PennDOT Form 408 specifications for extra work performed on a force account basis?

- Yes  No

Additional Locate Comments

USIC returned this section back to UGI for locator confidence  
If this incident involved any locating/markings errors, please include all records related to the locator's training and qualification (including training to meet UULPL standards as well as Operator Qualification).

Summary and Attachments

**Provide a summary of the event**

The gas main on Brown St in carbondale was discovered to be 3' off the mark when it was exposed in our ditch line for water main installation. Upon further investigation, it was determined that the locator could not accurately trace this line as it didn't have tracer wire and it was inserted in some spot. Services were recently renewed in the area as well. The locator turned the project back to UGI due to locator confidence.

If more space is needed, attach additional pages or documents.

**Attachments**

Brown St UGI 1.jpg	838.78KB
Brown St UGI 2.jpg	415.95KB
Brown St UGI 3.jpg	934.55KB
Brown St UGI 4.jpg	1.14MB
Brown St UGI 5.jpg	1.16MB

Attach pictures and additional documents

**Submit Date**

10/15/2019

**Compliance Update**

---

**Research Result**

- Listed tickets found
- Additional tickets found
- No tickets found

**Ticket Attachment**

SN-20190222284-20192331549-20192542049.pdf	3.71MB
CPA 303818 attachments.pdf	6.87MB

**Comments**

**I&E**  
**Exhibit 3A**



**I&E**  
**Exhibit 3B**



**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Pennsylvania Public Utility Commission	:	
Bureau of Investigation and Enforcement	:	
	:	
v.	:	Docket No. C-2022-
	:	
UGI Utilities, Inc.	:	

**CERTIFICATE OF SERVICE**

I hereby certify that I have this day served a true copy of the foregoing **Formal Complaint** in the manner and upon the parties listed below, in accordance with the requirements of 52 Pa. Code §§ 1.54 (relating to service by a party).

**Served via Electronic Mail**

Timothy J. Angstadt  
Vice President – Operations  
UGI Utilities, Inc.  
One UGI Drive  
Denver, PA 17517  
[tangstadt@ugi.com](mailto:tangstadt@ugi.com)

Kent D. Murphy, Esquire  
Vice-President, Law  
UGI Utilities, Inc.  
Group Counsel – Energy & Regulation  
UGI Corporation  
460 North Gulph Road  
King of Prussia, PA 19406  
[murphyke@ugicorp.com](mailto:murphyke@ugicorp.com)

Eric Swartley  
Senior Manager - Pipeline  
UGI Utilities, Inc.  
1301 API Drive  
Middletown, PA 17507  
[eswartley@ugi.com](mailto:eswartley@ugi.com)



\_\_\_\_\_  
Kourtney L. Myers  
Prosecutor  
Attorney ID No. 316494

Bureau of Investigation and Enforcement  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street  
Harrisburg, PA 17120  
(717) 705-4366  
[komyers@pa.gov](mailto:komyers@pa.gov)

Date: September 30, 2022