

Darsh Singh, Esq.
(610) 212-8331
(330) 315-9263 (Fax)

April 19, 2023

VIA E-FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

**Re: Completed Restoration of Momentary and Sustained Interruptions –
Pennsylvania Electric Company; Docket No. M-2021-3023564**

Dear Secretary Chiavetta:

Pursuant to 52 Pa. Code § 67.1, Pennsylvania Electric Company (“Penelec”) submits written notification of completed restoration efforts following storm conditions that began on April 1, 2023 that caused multiple service interruptions in the Penelec service territory.

Attached please find the details relative to the impact of this recent outage event and the restoration activities that took place. It should be noted that the review and approval process of this outage information is still in progress at the time of filing this report and as such, all outage information contained in this report should be considered preliminary.

If you have any questions, please contact me at (610) 212-8331.

Sincerely,



Darsh Singh

Enclosures

c: Dan Searfoorce - PaPUC Bureau of Technical Utility Services (via electronic mail)
Derek Ruhl - PaPUC Bureau of Technical Utility Services (via electronic mail)
John Van Zant - PaPUC Bureau of Technical Utility Services (via electronic mail)
Harry Bidelspach – PaPUC Bureau of Technical Utility Services (via electronic mail)

ELECTRIC UTILITY REPORT OF OUTAGE TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU
P O BOX 3265
HARRISBURG, PA 17105-3265

1. Reporting Utility: Pennsylvania Electric Company ("Penelec")
Address: 800 Cabin Hill Road
Greensburg, PA 15601

2. Name and title of person making report:

Scott Wyman President, Pennsylvania Operations
(Name) *(Title)*

3. Telephone number: (724) 838-6150
(Telephone Number)

4. Date and time report was made to Commission:

April 1, 2023 1530
(Date) *(Time)*

5. Interruption or Outage:

(a) Number of customers affected: 115,095 (Represents 19.9% of Penelec's total customers).

(b) Approximate number of outage cases and trouble cases for each county affected during event: See response to 5(c).

(c) Approximate number of outages for each county affected during the event:

County	Outages	Outage Cases	Trouble Cases
Bedford	1052	8	22
Blair	3404	35	101
Bradford	905	38	64
Cambria	8816	100	207
Centre	1879	15	50
Clarion	5124	60	212
Clearfield	15405	154	253
Crawford	7354	79	187
Cumberland	17	1	3
Erie	15028	131	273
Forest	1159	15	42
Franklin	112	3	0
Huntingdon	139	6	25
Indiana	8706	63	108
Jefferson	12259	76	125
Juniata	1	1	1
Lycoming	63	4	6
Mckean	710	17	68
Mifflin	93	15	22
Perry	1	1	1
Potter	962	7	16
Somerset	1659	27	41
Susquehanna	2857	23	21
Tioga	4476	70	135
Venango	10351	163	449
Warren	11406	67	115
Wayne	40	4	3
Westmoreland	1009	11	5
Wyoming	108	7	5
Total	115,095	1201	2,560

(d) Approximate number of outage cases exceeding 6 or more hours in duration: 789

(e) A listing of each outage case exceeding 6 or more hours in duration:
See Attachment A.

(f) Reason for the interruption or outages: Beginning the early morning of April 1, 2023, a storm producing rain and strong winds moved through Pennsylvania including the

Penelec service territory. Penelec experienced wind gusts up to 58 miles per hour and portions of the service territory received up to 1.5 inches of rain. Wind gusts above 30 miles per hour continued in the southwestern districts on Sunday, April 2. See Attachment B for the maximum wind gusts for April 1 & 2, and the 24-hour total precipitation for April 1, 2023.

- (g) Damage as a result of the high winds included downed trees/power lines, damaged and broken poles/crossarms, and damaged equipment. Erie and Oil City were the hardest hit areas. Approximately 52% of the total outages that occurred were tree related.

Preliminary data indicate the reliability impact of the storm was 152.9 minutes of SAIDI, 0.20 of SAIFI, and an overall storm CAIDI of 769.99 minutes.

- (h) Projected time of restoration: It was estimated that the majority of customers would be restored by 2300 on April 4, 2023.

See Attachment C for the restoration curve and Attachment D for the order restoration graphs.

- (i) The number of utility workers, contract workers, and workers received as mutual aid assigned specifically to the repair work by general function:

Company	# of Workers	General Function
Met Ed	39	Line Workers
Penelec	219	Line Workers
Potomac Edison	24	Line Workers
Penelec	5	Substation
Subtotal	287	Line Workers
Davey Tree	32	Forestry Contractor
Lewis Tree	23	Forestry Contractor
Penn Live Services	67	Forestry Contractor
Subtotal	122	Forestry Contractor
Bird Electric	50	Line Contractor
Liberty Line Builders	24	Line Contractor
PGS	20	Line Contractor
Danella Construction of NY	56	Line Contractor
Henkles & McCoy	24	Line Contractor
I.B Abel, Inc	44	Line Contractor
JW Didado	7	Line Contractor
Miller Bros	40	Line Contractor
NG Gilbert	28	Line Contractor

Thayer PC	11	Line Contractor
Thompson Electric	5	Line Contractor
Subtotal	309	Line Contractor
First Energy Service Co	20	Hazard Responder
Met-Ed	32	Hazard Responder
Penelec	83	Hazard Responder
One Resource Restoration	19	Hazard Responder
Penelec	11	Hazard Responder Support
Met-Ed	1	Hazard Responder Support
Penelec	18	Damage Assessors
Penelec	3	Damage Assessors Support
Subtotal	187	Hazard Responders/Damage Assessors
Penelec	62	Support
Met-Ed	10	Support
Potomac Edison	1	Support
West Penn Power	8	Support
First Energy Service Co	2	Support
Bird Electric	1	Contractor/Support
Liberty Line Builders	2	Contractor/Support
PGS	1	Contractor/Support
Danella Contruccion of NY	3	Contractor/Support
Henkles & McCoy	1	Contractor/Support
Subtotal	91	Support
Grand Total	996	

- (j) The date and time of the first information of a service interruption: April 1, 2023 at 0159
- (k) The date and time that repair crews were assembled: April 1, 2023 at 0159
- (l) The actual time that service was restored to the last affected customer: April 5, 2023 at 2244.
- (m) A general description of the physical damage sustained by the utility facilities as a result of the interruption/outage:

Equipment	Number
Crossarms Replaced	168
Cutouts Replaced	155
Poles Replaced	142
Transformers Replaced	68
Wire & Cable Replaced (feet)	22,309
Primary Spans Down	956
Secondary Spans Replaced	323

- (n) If the interruption/outage event was weather-related, the utility’s weather reports, outlooks, or scenarios for the day before and the day of the interruption/outage event:

See Attachment E for the weather forecast reports.

- (o) If the interruption/outage event caused approximate outages that exceed 10% or more of the number of customers in the utility’s entire service territory, rank the event in terms of the number and duration of outages and provide 2 comparable events, including the number and duration of outages for those comparable events.

The outages that were a result of this event did exceed 10% or more of customers in the utility’s entire service territory.

The below chart reflects a ranking of the subject event in relation to two comparable Penelec events (based on the number and duration of outages).

Rank by Number of Outages	Operating Company	Date	Event Description	Duration (hours)	Customers Affected
1	Penelec	April 1 to 5, 2023	High Winds & Rain	116 hours 45 minutes	115,095
2	Penelec	November 15 to 19, 2020	High Winds	106 hours 50 minutes	90,058
3	Penelec	July 6 to July 10, 2021	High Winds & Rain	105 hours 11 minutes	61,821

Remarks: The storm statistics contained in this report are preliminary. The review and approval of the storm statistics were still in progress as of the time this report was filed.

Attachment A: A listing of each outage case exceeding six or more hours in duration, including the following information¹:

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
347254	Erie	8	6,020	4/1/23 1:51 PM	4/5/23 6:11 PM
358783	Clarion	10	5,999	4/1/23 2:37 PM	4/5/23 6:36 PM
364073	Venango	1	5,993	4/1/23 2:14 PM	4/5/23 6:07 PM
357025	Venango	17	5,906	4/1/23 1:54 PM	4/5/23 4:20 PM
364839	Forest	1	5,889	4/1/23 2:39 PM	4/5/23 4:48 PM
366234	Clarion	5	5,853	4/1/23 2:27 PM	4/5/23 4:00 PM
347353	Venango	10	5,717	4/1/23 2:09 PM	4/5/23 1:26 PM
367831	Venango	1	5,711	4/1/23 1:58 PM	4/5/23 1:09 PM
367831	Venango	1	5,711	4/1/23 1:58 PM	4/5/23 1:09 PM
364903	Clarion	4	5,651	4/1/23 2:30 PM	4/5/23 12:41 PM
348585	Clarion	1	5,644	4/1/23 2:38 PM	4/5/23 12:42 PM
352265	Clarion	2	5,586	4/1/23 6:04 PM	4/5/23 3:10 PM
367830	Venango	38	5,579	4/1/23 1:58 PM	4/5/23 10:57 AM
367503	Clarion	39	5,569	4/1/23 2:20 PM	4/5/23 11:09 AM
367483	Venango	3	5,546	4/1/23 3:30 PM	4/5/23 11:56 AM
351686	Clearfield	1	5,516	4/1/23 5:07 PM	4/5/23 1:03 PM
359783	Blair	13	5,514	4/1/23 2:57 PM	4/5/23 10:51 AM
366760	Blair	1	5,464	4/1/23 3:11 PM	4/5/23 10:15 AM
360579	Centre	1	5,453	4/1/23 2:57 PM	4/5/23 9:50 AM
358455	Crawford	6	5,422	4/1/23 2:58 PM	4/5/23 9:20 AM
367528	Venango	8	5,402	4/1/23 2:03 PM	4/5/23 8:05 AM
355265	Clarion	7	5,332	4/1/23 8:48 PM	4/5/23 1:40 PM
363435	Venango	3	5,310	4/1/23 5:43 PM	4/5/23 10:13 AM
352972	Clearfield	4	5,307	4/1/23 5:20 PM	4/5/23 9:47 AM
347615	Clearfield	1	5,292	4/1/23 2:48 PM	4/5/23 7:00 AM
355041	Clarion	2	5,240	4/1/23 8:33 PM	4/5/23 11:53 AM
367534	Venango	13	5,117	4/1/23 5:43 PM	4/5/23 7:00 AM
357028	Huntingdon	1	5,025	4/2/23 12:50 AM	4/5/23 12:35 PM
347488	Venango	38	4,922	4/1/23 1:58 PM	4/5/23 12:00 AM
348430	Venango	10	4,909	4/1/23 2:36 PM	4/5/23 12:25 AM
366184	Venango	5	4,812	4/1/23 1:52 PM	4/4/23 10:04 PM

¹ When applicable, the individual restoration steps for an order are provided for those customers that were out of service for 6 hours or more.

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
366184	Venango	3	4,790	4/1/23 1:52 PM	4/4/23 9:42 PM
356250	Venango	2	4,784	4/1/23 6:22 PM	4/5/23 2:06 AM
359060	Clearfield	1	4,759	4/2/23 10:41 AM	4/5/23 6:00 PM
351857	Clarion	1	4,734	4/1/23 5:24 PM	4/5/23 12:18 AM
364856	Venango	4	4,705	4/1/23 1:43 PM	4/4/23 8:08 PM
356274	Warren	1	4,681	4/1/23 2:11 PM	4/4/23 8:12 PM
356274	Warren	1	4,681	4/1/23 2:11 PM	4/4/23 8:12 PM
353931	Crawford	12	4,660	4/1/23 2:06 PM	4/4/23 7:46 PM
347193	Venango	16	4,658	4/1/23 1:48 PM	4/4/23 7:26 PM
347483	Clearfield	2	4,642	4/1/23 2:23 PM	4/4/23 7:45 PM
361824	Venango	34	4,631	4/1/23 1:45 PM	4/4/23 6:56 PM
356274	Warren	2	4,626	4/1/23 2:11 PM	4/4/23 7:17 PM
362337	Clarion	68	4,626	4/1/23 1:57 PM	4/4/23 7:03 PM
351657	Clarion	15	4,622	4/1/23 2:27 PM	4/4/23 7:29 PM
366158	Crawford	136	4,620	4/1/23 2:06 PM	4/4/23 7:06 PM
347395	Venango	43	4,620	4/1/23 1:56 PM	4/4/23 6:56 PM
366477	Venango	7	4,617	4/1/23 1:51 PM	4/4/23 6:48 PM
362116	Venango	10	4,614	4/1/23 1:55 PM	4/4/23 6:49 PM
347096	Venango	19	4,612	4/1/23 1:36 PM	4/4/23 6:28 PM
348071	Clarion	4	4,597	4/1/23 2:21 PM	4/4/23 6:58 PM
349155	Indiana	6	4,591	4/1/23 2:56 PM	4/4/23 7:27 PM
347483	Clearfield	63	4,589	4/1/23 2:23 PM	4/4/23 6:52 PM
347842	Venango	11	4,587	4/1/23 2:15 PM	4/4/23 6:42 PM
363703	Clearfield	2	4,580	4/1/23 2:48 PM	4/4/23 7:08 PM
347728	Clarion	7	4,578	4/1/23 2:12 PM	4/4/23 6:30 PM
347591	Venango	16	4,565	4/1/23 2:03 PM	4/4/23 6:08 PM
364930	Forest	37	4,546	4/1/23 3:05 PM	4/4/23 6:51 PM
358590	Clearfield	2	4,544	4/1/23 2:16 PM	4/4/23 6:00 PM
358947	Clarion	10	4,527	4/1/23 3:28 PM	4/4/23 6:55 PM
358366	Crawford	32	4,526	4/1/23 1:59 PM	4/4/23 5:25 PM
366760	Blair	4	4,520	4/1/23 3:11 PM	4/4/23 6:31 PM
349686	Clarion	11	4,492	4/1/23 3:16 PM	4/4/23 6:08 PM
366567	Venango	1	4,491	4/1/23 1:54 PM	4/4/23 4:45 PM
366567	Venango	1	4,491	4/1/23 1:54 PM	4/4/23 4:45 PM
366866	Clearfield	2	4,486	4/1/23 4:34 PM	4/4/23 7:20 PM
355932	Clearfield	8	4,471	4/1/23 3:36 PM	4/4/23 6:07 PM
358897	Forest	3	4,466	4/2/23 10:10 AM	4/5/23 12:36 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
354968	Blair	5	4,459	4/1/23 3:11 PM	4/4/23 5:30 PM
349196	Venango	22	4,445	4/1/23 2:58 PM	4/4/23 5:03 PM
367478	Clarion	4	4,436	4/2/23 2:32 PM	4/5/23 4:28 PM
349408	Blair	2	4,427	4/1/23 3:05 PM	4/4/23 4:52 PM
362237	Indiana	13	4,424	4/1/23 2:48 PM	4/4/23 4:32 PM
349836	Venango	39	4,413	4/1/23 3:21 PM	4/4/23 4:54 PM
357203	Venango	33	4,404	4/1/23 1:52 PM	4/4/23 3:16 PM
364912	Venango	24	4,396	4/1/23 1:55 PM	4/4/23 3:11 PM
348284	Clarion	10	4,390	4/1/23 2:28 PM	4/4/23 3:38 PM
365932	Forest	159	4,378	4/1/23 2:33 PM	4/4/23 3:31 PM
349785	Blair	1	4,373	4/1/23 3:19 PM	4/4/23 4:12 PM
352384	Venango	5	4,362	4/1/23 6:16 PM	4/4/23 6:58 PM
353536	Clarion	11	4,348	4/1/23 7:11 PM	4/4/23 7:39 PM
348744	Clarion	25	4,345	4/1/23 2:47 PM	4/4/23 3:12 PM
350829	Clearfield	1	4,341	4/1/23 3:58 PM	4/4/23 4:19 PM
365649	Clearfield	54	4,324	4/1/23 2:36 PM	4/4/23 2:40 PM
351432	Venango	19	4,323	4/1/23 4:44 PM	4/4/23 4:47 PM
347797	Venango	41	4,304	4/1/23 2:09 PM	4/4/23 1:53 PM
349811	Venango	72	4,301	4/1/23 3:20 PM	4/4/23 3:01 PM
347605	Clearfield	70	4,289	4/1/23 2:36 PM	4/4/23 2:05 PM
351881	Venango	85	4,284	4/1/23 4:01 PM	4/4/23 3:25 PM
347242	Venango	4	4,268	4/1/23 1:52 PM	4/4/23 1:00 PM
347932	Forest	159	4,264	4/1/23 2:14 PM	4/4/23 1:18 PM
365398	Crawford	5	4,255	4/1/23 1:53 PM	4/4/23 12:48 PM
347312	Crawford	1	4,242	4/1/23 1:43 PM	4/4/23 12:25 PM
365690	Venango	75	4,240	4/1/23 1:55 PM	4/4/23 12:35 PM
351818	Clearfield	1	4,238	4/1/23 2:15 PM	4/4/23 12:53 PM
353951	Venango	3	4,235	4/1/23 5:51 PM	4/4/23 4:26 PM
361162	Venango	33	4,228	4/1/23 2:03 PM	4/4/23 12:31 PM
366087	Venango	1	4,202	4/1/23 1:56 PM	4/4/23 11:58 AM
364699	Jefferson	2	4,195	4/1/23 5:19 PM	4/4/23 3:14 PM
366085	Venango	4	4,194	4/1/23 1:56 PM	4/4/23 11:50 AM
366086	Venango	11	4,194	4/1/23 1:56 PM	4/4/23 11:50 AM
364508	Venango	35	4,192	4/1/23 1:56 PM	4/4/23 11:48 AM
353417	Crawford	30	4,191	4/1/23 7:05 PM	4/4/23 4:56 PM
364925	Clarion	1	4,178	4/1/23 2:34 PM	4/4/23 12:12 PM
365671	Huntingdon	46	4,169	4/1/23 3:08 PM	4/4/23 12:37 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
365810	Clearfield	2	4,164	4/1/23 7:32 PM	4/4/23 4:56 PM
356338	Venango	19	4,150	4/1/23 10:18 PM	4/4/23 7:28 PM
364651	Clearfield	10	4,147	4/1/23 2:54 PM	4/4/23 12:01 PM
364417	Tioga	2	4,142	4/1/23 3:36 PM	4/4/23 12:38 PM
351171	Blair	3	4,141	4/1/23 4:29 PM	4/4/23 1:30 PM
347330	Venango	6	4,113	4/1/23 1:55 PM	4/4/23 10:28 AM
348382	Forest	222	4,111	4/1/23 2:36 PM	4/4/23 11:07 AM
360614	Venango	7	4,107	4/1/23 1:51 PM	4/4/23 10:18 AM
360624	Venango	13	4,107	4/1/23 1:51 PM	4/4/23 10:18 AM
360616	Venango	15	4,107	4/1/23 1:51 PM	4/4/23 10:18 AM
361385	Venango	3	4,107	4/1/23 1:51 PM	4/4/23 10:18 AM
360615	Venango	3	4,107	4/1/23 1:51 PM	4/4/23 10:18 AM
360618	Venango	1	4,107	4/1/23 1:51 PM	4/4/23 10:18 AM
347597	Venango	59	4,094	4/1/23 1:59 PM	4/4/23 10:13 AM
364901	Clarion	109	4,081	4/1/23 2:20 PM	4/4/23 10:21 AM
361889	Clearfield	26	4,074	4/1/23 2:36 PM	4/4/23 10:30 AM
360998	Crawford	20	4,041	4/1/23 3:29 PM	4/4/23 10:50 AM
364905	Clarion	148	4,010	4/1/23 2:20 PM	4/4/23 9:10 AM
350597	Jefferson	1	3,959	4/1/23 3:47 PM	4/4/23 9:46 AM
364958	Crawford	14	3,946	4/1/23 3:29 PM	4/4/23 9:15 AM
361244	Crawford	5	3,926	4/1/23 1:53 PM	4/4/23 7:19 AM
353054	Tioga	9	3,910	4/1/23 6:48 PM	4/4/23 11:58 AM
356019	Clearfield	3	3,900	4/1/23 4:05 PM	4/4/23 9:05 AM
355875	Jefferson	1	3,900	4/1/23 6:50 PM	4/4/23 11:50 AM
351379	Clearfield	1	3,875	4/1/23 4:40 PM	4/4/23 9:15 AM
349473	Clearfield	3	3,862	4/1/23 3:08 PM	4/4/23 7:30 AM
365201	Clarion	1	3,837	4/1/23 2:09 PM	4/4/23 6:06 AM
350338	Clearfield	6	3,819	4/1/23 3:37 PM	4/4/23 7:16 AM
359940	Venango	3	3,804	4/2/23 1:00 PM	4/5/23 4:24 AM
366032	Indiana	1	3,800	4/1/23 8:39 PM	4/4/23 11:59 AM
355134	Indiana	17	3,796	4/1/23 8:39 PM	4/4/23 11:55 AM
353847	Clearfield	1	3,753	4/1/23 7:32 PM	4/4/23 10:05 AM
352371	Venango	84	3,730	4/1/23 3:24 PM	4/4/23 5:34 AM
347324	Crawford	1	3,723	4/1/23 1:55 PM	4/4/23 3:58 AM
347796	Clarion	60	3,649	4/1/23 2:09 PM	4/4/23 2:58 AM
356744	Clarion	13	3,647	4/1/23 11:37 PM	4/4/23 12:24 PM
353486	Jefferson	1	3,611	4/1/23 7:09 PM	4/4/23 7:20 AM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
347305	Clarion	113	3,593	4/1/23 1:53 PM	4/4/23 1:46 AM
360872	Indiana	7	3,338	4/1/23 2:39 PM	4/3/23 10:17 PM
346506	Clearfield	3	3,324	4/1/23 6:06 AM	4/3/23 1:30 PM
363069	Clearfield	5	3,322	4/2/23 12:04 PM	4/4/23 7:26 PM
356378	Clearfield	4	3,311	4/1/23 2:15 PM	4/3/23 9:26 PM
347230	Clearfield	46	3,306	4/1/23 1:52 PM	4/3/23 8:58 PM
347242	Venango	2	3,305	4/1/23 1:52 PM	4/3/23 8:57 PM
364483	Venango	33	3,289	4/1/23 3:21 PM	4/3/23 10:10 PM
348251	Venango	5	3,286	4/1/23 2:27 PM	4/3/23 9:13 PM
347845	Venango	6	3,275	4/1/23 1:55 PM	4/3/23 8:30 PM
359083	Jefferson	1	3,273	4/2/23 10:47 AM	4/4/23 5:20 PM
362439	Venango	2	3,271	4/3/23 5:47 AM	4/5/23 12:18 PM
363763	Venango	2	3,267	4/3/23 2:00 PM	4/5/23 8:27 PM
361460	Clearfield	1	3,239	4/1/23 2:29 PM	4/3/23 8:28 PM
364743	Jefferson	2	3,230	4/1/23 2:55 PM	4/3/23 8:45 PM
362546	Clarion	1	3,221	4/1/23 2:31 PM	4/3/23 8:12 PM
364849	Venango	86	3,209	4/1/23 1:43 PM	4/3/23 7:12 PM
364849	Venango	86	3,209	4/1/23 1:43 PM	4/3/23 7:12 PM
364507	Venango	397	3,209	4/1/23 1:43 PM	4/3/23 7:12 PM
364848	Venango	25	3,209	4/1/23 1:43 PM	4/3/23 7:12 PM
364848	Venango	25	3,209	4/1/23 1:43 PM	4/3/23 7:12 PM
362542	Centre	1	3,196	4/3/23 7:16 AM	4/5/23 12:32 PM
356538	Warren	1	3,191	4/1/23 2:12 PM	4/3/23 7:23 PM
362860	Clearfield	5	3,186	4/1/23 2:49 PM	4/3/23 7:55 PM
364826	Venango	12	3,184	4/1/23 1:51 PM	4/3/23 6:55 PM
362998	Venango	2	3,183	4/1/23 1:51 PM	4/3/23 6:54 PM
349372	Clarion	76	3,172	4/1/23 3:03 PM	4/3/23 7:55 PM
358006	Jefferson	4	3,172	4/1/23 3:18 PM	4/3/23 8:10 PM
364617	Clearfield	26	3,162	4/1/23 2:39 PM	4/3/23 7:21 PM
351100	Cambria	4	3,159	4/1/23 2:41 PM	4/3/23 7:20 PM
364278	Jefferson	2	3,152	4/1/23 3:11 PM	4/3/23 7:43 PM
348404	Crawford	4	3,150	4/1/23 2:34 PM	4/3/23 7:04 PM
355607	Crawford	3	3,146	4/1/23 1:49 PM	4/3/23 6:15 PM
362667	Tioga	44	3,131	4/1/23 3:29 PM	4/3/23 7:40 PM
363461	Venango	3	3,127	4/1/23 1:55 PM	4/3/23 6:02 PM
351105	Tioga	6	3,121	4/1/23 4:22 PM	4/3/23 8:23 PM
356821	Warren	7	3,112	4/1/23 2:12 PM	4/3/23 6:04 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
360998	Crawford	33	3,108	4/1/23 3:29 PM	4/3/23 7:17 PM
358551	Clearfield	10	3,106	4/1/23 2:49 PM	4/3/23 6:35 PM
361934	Crawford	14	3,105	4/1/23 1:39 PM	4/3/23 5:24 PM
358368	Crawford	2	3,103	4/1/23 1:45 PM	4/3/23 5:28 PM
361027	Centre	35	3,100	4/1/23 2:57 PM	4/3/23 6:37 PM
347224	Venango	60	3,096	4/1/23 1:51 PM	4/3/23 5:27 PM
347312	Crawford	881	3,085	4/1/23 1:44 PM	4/3/23 5:09 PM
359039	Jefferson	1	3,082	4/2/23 10:37 AM	4/4/23 1:59 PM
347288	Venango	40	3,080	4/1/23 1:54 PM	4/3/23 5:14 PM
359844	Clearfield	7	3,072	4/1/23 3:44 PM	4/3/23 6:56 PM
362889	Clearfield	2	3,071	4/3/23 9:26 AM	4/5/23 12:37 PM
361976	Jefferson	7	3,069	4/1/23 2:13 PM	4/3/23 5:22 PM
349723	Bedford	4	3,068	4/1/23 3:17 PM	4/3/23 6:25 PM
360686	Tioga	10	3,066	4/1/23 4:29 PM	4/3/23 7:35 PM
357892	Crawford	4	3,060	4/1/23 1:49 PM	4/3/23 4:49 PM
349051	Centre	77	3,051	4/1/23 2:53 PM	4/3/23 5:44 PM
347541	Clearfield	120	3,050	4/1/23 2:39 PM	4/3/23 5:29 PM
347143	Venango	65	3,037	4/1/23 1:43 PM	4/3/23 4:20 PM
349104	Clearfield	116	3,034	4/1/23 2:54 PM	4/3/23 5:28 PM
348602	Forest	78	3,031	4/1/23 2:39 PM	4/3/23 5:10 PM
350790	Tioga	20	3,031	4/1/23 3:57 PM	4/3/23 6:28 PM
361817	Venango	185	3,025	4/1/23 1:56 PM	4/3/23 4:21 PM
355210	Tioga	14	3,025	4/1/23 3:55 PM	4/3/23 6:20 PM
364311	Jefferson	7	3,024	4/1/23 5:19 PM	4/3/23 7:43 PM
351761	Cambria	1	3,022	4/1/23 5:13 PM	4/3/23 7:35 PM
364825	Clearfield	8	3,020	4/1/23 7:12 PM	4/3/23 9:32 PM
355779	Blair	1	3,017	4/1/23 2:38 PM	4/3/23 4:55 PM
355779	Blair	2	3,014	4/1/23 2:38 PM	4/3/23 4:52 PM
351411	Cambria	1	2,990	4/1/23 4:42 PM	4/3/23 6:32 PM
349421	Clearfield	18	2,979	4/1/23 3:06 PM	4/3/23 4:45 PM
350858	Tioga	11	2,974	4/1/23 4:01 PM	4/3/23 5:35 PM
361395	Tioga	52	2,969	4/1/23 3:17 PM	4/3/23 4:46 PM
349411	Forest	59	2,968	4/1/23 6:15 PM	4/3/23 7:43 PM
352282	Blair	7	2,965	4/1/23 6:05 PM	4/3/23 7:30 PM
349219	Clearfield	60	2,962	4/1/23 2:59 PM	4/3/23 4:21 PM
351576	Bradford	14	2,953	4/1/23 4:56 PM	4/3/23 6:09 PM
362274	Cambria	2	2,952	4/1/23 2:29 PM	4/3/23 3:41 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
350302	Crawford	1	2,949	4/1/23 3:36 PM	4/3/23 4:45 PM
363071	Clarion	1	2,944	4/3/23 10:28 AM	4/5/23 11:32 AM
347796	Clarion	215	2,939	4/1/23 2:09 PM	4/3/23 3:08 PM
363613	Centre	9	2,932	4/1/23 2:48 PM	4/3/23 3:40 PM
363358	Warren	20	2,931	4/1/23 2:09 PM	4/3/23 3:00 PM
360858	Centre	38	2,919	4/1/23 2:57 PM	4/3/23 3:36 PM
364046	Venango	559	2,918	4/1/23 2:14 PM	4/3/23 2:52 PM
363836	Crawford	33	2,917	4/1/23 2:57 PM	4/3/23 3:34 PM
361423	Tioga	7	2,915	4/1/23 3:00 PM	4/3/23 3:35 PM
360619	Venango	2	2,912	4/2/23 3:23 PM	4/4/23 3:55 PM
347863	Erie	4	2,905	4/1/23 2:20 PM	4/3/23 2:45 PM
363066	Clearfield	1	2,905	4/1/23 3:50 PM	4/3/23 4:15 PM
347353	Venango	6	2,904	4/1/23 2:09 PM	4/3/23 2:33 PM
351700	Lycoming	6	2,902	4/1/23 5:08 PM	4/3/23 5:30 PM
363349	Cambria	7	2,900	4/1/23 2:29 PM	4/3/23 2:49 PM
350284	Tioga	10	2,899	4/1/23 3:36 PM	4/3/23 3:55 PM
363349	Cambria	109	2,888	4/1/23 2:29 PM	4/3/23 2:37 PM
363092	Tioga	5	2,886	4/1/23 5:11 PM	4/3/23 5:17 PM
364460	Venango	1	2,879	4/3/23 4:06 PM	4/5/23 4:05 PM
349883	Forest	343	2,873	4/1/23 3:23 PM	4/3/23 3:16 PM
359766	Venango	13	2,864	4/2/23 12:12 PM	4/4/23 11:56 AM
350982	Tioga	11	2,864	4/1/23 4:11 PM	4/3/23 3:55 PM
348389	Jefferson	11	2,861	4/1/23 3:29 PM	4/3/23 3:10 PM
351807	Crawford	6	2,860	4/1/23 1:43 PM	4/3/23 1:23 PM
360337	Tioga	2	2,854	4/1/23 3:33 PM	4/3/23 3:07 PM
347128	Crawford	55	2,844	4/1/23 1:41 PM	4/3/23 1:05 PM
356492	Crawford	1	2,841	4/1/23 10:40 PM	4/3/23 10:01 PM
361891	Venango	67	2,840	4/2/23 8:10 PM	4/4/23 7:30 PM
363466	Tioga	20	2,839	4/1/23 3:29 PM	4/3/23 2:48 PM
357777	Erie	1	2,834	4/1/23 1:54 PM	4/3/23 1:08 PM
347101	Crawford	7	2,832	4/1/23 1:36 PM	4/3/23 12:48 PM
353516	Tioga	1	2,829	4/1/23 7:11 PM	4/3/23 6:20 PM
361875	Tioga	87	2,821	4/1/23 4:02 PM	4/3/23 3:03 PM
356355	Clearfield	19	2,820	4/1/23 2:15 PM	4/3/23 1:15 PM
362608	Erie	13	2,808	4/1/23 3:54 PM	4/3/23 2:42 PM
353920	Jefferson	3	2,804	4/1/23 5:16 PM	4/3/23 4:00 PM
364222	Forest	10	2,803	4/1/23 5:07 PM	4/3/23 3:50 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
357892	Crawford	4	2,801	4/1/23 1:49 PM	4/3/23 12:30 PM
352536	Clearfield	158	2,799	4/1/23 6:16 PM	4/3/23 4:55 PM
349671	Jefferson	14	2,789	4/1/23 3:15 PM	4/3/23 1:44 PM
352005	Clearfield	11	2,779	4/1/23 5:41 PM	4/3/23 4:00 PM
348657	Cambria	1	2,778	4/1/23 4:22 PM	4/3/23 2:40 PM
355459	Potter	4	2,773	4/1/23 8:07 PM	4/3/23 6:20 PM
361886	Venango	38	2,752	4/2/23 8:08 PM	4/4/23 6:00 PM
359139	Warren	8	2,751	4/1/23 2:09 PM	4/3/23 12:00 PM
347541	Clearfield	501	2,749	4/1/23 2:39 PM	4/3/23 12:28 PM
353919	Jefferson	13	2,747	4/1/23 4:23 PM	4/3/23 2:10 PM
347831	Warren	7	2,734	4/1/23 2:13 PM	4/3/23 11:47 AM
356008	Cambria	1	2,726	4/1/23 8:34 PM	4/3/23 6:00 PM
347224	Venango	93	2,724	4/1/23 1:51 PM	4/3/23 11:15 AM
352679	Mckean	1	2,724	4/1/23 6:36 PM	4/3/23 4:00 PM
347377	Venango	444	2,723	4/1/23 1:55 PM	4/3/23 11:18 AM
362201	Cambria	107	2,716	4/1/23 2:32 PM	4/3/23 11:48 AM
351103	Lycoming	52	2,715	4/1/23 4:22 PM	4/3/23 1:37 PM
350794	Tioga	3	2,703	4/1/23 3:50 PM	4/3/23 12:53 PM
347589	Erie	1	2,700	4/1/23 2:03 PM	4/3/23 11:03 AM
361379	Tioga	47	2,700	4/1/23 3:29 PM	4/3/23 12:29 PM
350793	Crawford	2	2,696	4/1/23 3:57 PM	4/3/23 12:53 PM
352585	Jefferson	13	2,692	4/1/23 6:29 PM	4/3/23 3:21 PM
347333	Clarion	93	2,691	4/1/23 2:02 PM	4/3/23 10:53 AM
353238	Cambria	2	2,686	4/1/23 2:22 PM	4/3/23 11:08 AM
360901	Jefferson	58	2,680	4/1/23 2:50 PM	4/3/23 11:30 AM
359734	Jefferson	57	2,673	4/1/23 2:20 PM	4/3/23 10:53 AM
351823	Crawford	39	2,672	4/1/23 1:43 PM	4/3/23 10:15 AM
351125	Clearfield	4	2,669	4/1/23 4:24 PM	4/3/23 12:53 PM
359329	Jefferson	2	2,662	4/1/23 2:13 PM	4/3/23 10:35 AM
358109	Jefferson	11	2,657	4/1/23 2:20 PM	4/3/23 10:37 AM
353692	Lycoming	4	2,648	4/1/23 7:22 PM	4/3/23 3:30 PM
363190	Mckean	41	2,640	4/1/23 3:29 PM	4/3/23 11:29 AM
363025	Cambria	16	2,631	4/1/23 2:29 PM	4/3/23 10:20 AM
356889	Tioga	22	2,624	4/1/23 3:33 PM	4/3/23 11:17 AM
360901	Jefferson	135	2,616	4/1/23 3:54 PM	4/3/23 11:30 AM
347351	Venango	1	2,609	4/1/23 1:51 PM	4/3/23 9:20 AM
365142	Clarion	2	2,607	4/3/23 11:31 PM	4/5/23 6:58 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
361073	Susquehanna	1	2,567	4/1/23 6:18 PM	4/3/23 1:05 PM
347058	Crawford	100	2,538	4/1/23 1:21 PM	4/3/23 7:39 AM
365105	Venango	4	2,537	4/3/23 5:26 PM	4/5/23 11:43 AM
351835	Susquehanna	4	2,524	4/1/23 5:22 PM	4/3/23 11:26 AM
353202	Bradford	1	2,524	4/1/23 6:53 PM	4/3/23 12:57 PM
351094	Potter	7	2,510	4/1/23 4:22 PM	4/3/23 10:12 AM
361168	Jefferson	3	2,501	4/2/23 5:30 PM	4/4/23 11:11 AM
361049	Venango	2	2,481	4/2/23 4:57 PM	4/4/23 10:18 AM
361101	Venango	6	2,463	4/2/23 5:15 PM	4/4/23 10:18 AM
347486	Indiana	10	2,421	4/1/23 2:29 PM	4/3/23 6:50 AM
348342	Clarion	19	2,399	4/1/23 2:40 PM	4/3/23 6:39 AM
364474	Clarion	7	2,398	4/3/23 4:10 PM	4/5/23 8:08 AM
347298	Clarion	10	2,394	4/1/23 1:58 PM	4/3/23 5:52 AM
361818	Clearfield	1	2,393	4/2/23 7:42 PM	4/4/23 11:35 AM
352121	Clearfield	27	2,373	4/1/23 4:52 PM	4/3/23 8:25 AM
356149	Huntingdon	6	2,350	4/1/23 10:00 PM	4/3/23 1:10 PM
365014	Venango	1	2,345	4/3/23 8:40 PM	4/5/23 11:45 AM
347055	Bradford	14	2,313	4/1/23 1:20 PM	4/3/23 3:53 AM
347058	Crawford	48	2,296	4/1/23 5:23 PM	4/3/23 7:39 AM
355239	Cambria	2	2,274	4/1/23 2:37 PM	4/3/23 4:31 AM
351123	Bradford	1	2,256	4/1/23 4:24 PM	4/3/23 6:00 AM
353445	Cambria	5	2,247	4/1/23 7:07 PM	4/3/23 8:34 AM
364932	Venango	20	2,245	4/3/23 7:42 PM	4/5/23 9:07 AM
348942	Cambria	1	2,233	4/1/23 2:49 PM	4/3/23 4:02 AM
351377	Bradford	1	2,210	4/1/23 4:40 PM	4/3/23 5:30 AM
362273	Clarion	18	2,200	4/3/23 1:00 AM	4/4/23 1:40 PM
356608	Indiana	1	2,197	4/1/23 2:18 PM	4/3/23 2:55 AM
357382	Crawford	3	2,174	4/2/23 3:41 AM	4/3/23 3:55 PM
365252	Venango	3	2,147	4/4/23 5:45 AM	4/5/23 5:32 PM
347266	Clarion	753	2,132	4/1/23 1:54 PM	4/3/23 1:26 AM
348300	Clearfield	5	2,125	4/1/23 2:29 PM	4/3/23 1:54 AM
352361	Cambria	2	2,117	4/1/23 2:15 PM	4/3/23 1:32 AM
347963	Clarion	975	2,112	4/1/23 2:15 PM	4/3/23 1:27 AM
362472	Tioga	473	2,091	4/1/23 4:16 PM	4/3/23 3:07 AM
366517	Venango	7	2,090	4/3/23 8:42 AM	4/4/23 7:32 PM
349620	Clearfield	11	2,086	4/1/23 3:13 PM	4/3/23 1:59 AM
348588	Indiana	7	2,082	4/1/23 2:38 PM	4/3/23 1:20 AM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
362189	Clarion	587	2,081	4/1/23 1:57 PM	4/3/23 12:38 AM
362189	Clarion	587	2,081	4/1/23 1:57 PM	4/3/23 12:38 AM
362446	Clarion	7	2,073	4/3/23 6:04 AM	4/4/23 4:37 PM
365999	Venango	24	2,072	4/3/23 5:48 AM	4/4/23 4:20 PM
362203	Cambria	33	2,061	4/1/23 2:29 PM	4/3/23 12:50 AM
361974	Jefferson	38	2,052	4/1/23 2:13 PM	4/3/23 12:25 AM
352142	Clearfield	9	2,049	4/1/23 2:29 PM	4/3/23 12:38 AM
352142	Clearfield	354	2,039	4/1/23 2:29 PM	4/3/23 12:28 AM
347725	Indiana	19	2,021	4/1/23 2:10 PM	4/2/23 11:51 PM
356775	Jefferson	1	2,019	4/1/23 2:15 PM	4/2/23 11:54 PM
360611	Wayne	4	2,008	4/2/23 2:34 AM	4/3/23 12:02 PM
358894	Clearfield	7	2,001	4/2/23 10:09 AM	4/3/23 7:30 PM
367141	Venango	2	1,999	4/3/23 11:26 PM	4/5/23 8:45 AM
358403	Warren	3	1,987	4/2/23 8:34 AM	4/3/23 5:41 PM
359868	Venango	1	1,962	4/1/23 1:55 PM	4/2/23 10:37 PM
359838	Venango	334	1,956	4/1/23 1:55 PM	4/2/23 10:31 PM
361111	Indiana	163	1,950	4/1/23 2:10 PM	4/2/23 10:40 PM
347219	Crawford	9	1,936	4/1/23 1:51 PM	4/2/23 10:07 PM
346964	Wyoming	5	1,917	4/1/23 12:33 PM	4/2/23 8:30 PM
356753	Jefferson	48	1,915	4/1/23 2:15 PM	4/2/23 10:10 PM
359839	Venango	109	1,915	4/1/23 1:55 PM	4/2/23 9:50 PM
361076	Warren	51	1,904	4/1/23 2:06 PM	4/2/23 9:50 PM
357409	Tioga	3	1,899	4/2/23 3:41 AM	4/3/23 11:20 AM
354321	Centre	8	1,884	4/1/23 2:46 PM	4/2/23 10:10 PM
364883	Erie	3	1,877	4/2/23 11:52 AM	4/3/23 7:09 PM
359322	Erie	1	1,877	4/2/23 11:52 AM	4/3/23 7:09 PM
357382	Crawford	3	1,875	4/2/23 8:40 AM	4/3/23 3:55 PM
360370	Crawford	1	1,869	4/2/23 2:08 PM	4/3/23 9:17 PM
347113	Crawford	90	1,853	4/1/23 1:39 PM	4/2/23 8:32 PM
354127	Warren	18	1,841	4/1/23 2:18 PM	4/2/23 8:59 PM
347384	Jefferson	219	1,837	4/1/23 2:13 PM	4/2/23 8:50 PM
358476	Crawford	7	1,815	4/2/23 8:50 AM	4/3/23 3:05 PM
347290	Erie	162	1,812	4/1/23 1:54 PM	4/2/23 8:06 PM
360872	Indiana	6	1,804	4/2/23 4:13 PM	4/3/23 10:17 PM
361402	Venango	129	1,799	4/1/23 1:45 PM	4/2/23 7:44 PM
356740	Indiana	4	1,793	4/1/23 2:07 PM	4/2/23 8:00 PM
366093	Clarion	1	1,788	4/4/23 12:16 PM	4/5/23 6:04 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
348402	Cambria	5	1,786	4/1/23 2:34 PM	4/2/23 8:20 PM
357749	Cambria	4	1,769	4/2/23 6:01 AM	4/3/23 11:30 AM
355671	Bradford	39	1,765	4/1/23 6:27 PM	4/2/23 11:52 PM
346954	Susquehanna	25	1,764	4/1/23 12:19 PM	4/2/23 5:43 PM
350257	Tioga	134	1,762	4/1/23 3:31 PM	4/2/23 8:53 PM
349798	Clearfield	38	1,759	4/1/23 2:42 PM	4/2/23 8:01 PM
348809	Clearfield	475	1,755	4/1/23 2:29 PM	4/2/23 7:44 PM
352142	Clearfield	310	1,755	4/1/23 2:29 PM	4/2/23 7:44 PM
348978	Clearfield	96	1,755	4/1/23 2:50 PM	4/2/23 8:05 PM
353939	Crawford	85	1,755	4/1/23 1:37 PM	4/2/23 6:52 PM
347803	Indiana	118	1,751	4/1/23 2:07 PM	4/2/23 7:18 PM
357450	Jefferson	10	1,749	4/1/23 2:20 PM	4/2/23 7:29 PM
363735	Tioga	3	1,740	4/2/23 8:51 AM	4/3/23 1:51 PM
350196	Warren	1	1,737	4/1/23 3:33 PM	4/2/23 8:30 PM
348594	Cambria	9	1,736	4/1/23 2:38 PM	4/2/23 7:34 PM
347615	Clearfield	11	1,732	4/1/23 2:48 PM	4/2/23 7:40 PM
347163	Venango	303	1,727	4/1/23 1:45 PM	4/2/23 6:32 PM
351119	Warren	3	1,726	4/1/23 2:10 PM	4/2/23 6:56 PM
360463	Erie	7	1,721	4/1/23 1:34 PM	4/2/23 6:15 PM
361161	Erie	22	1,714	4/1/23 1:37 PM	4/2/23 6:11 PM
348569	Jefferson	45	1,708	4/1/23 2:37 PM	4/2/23 7:05 PM
360503	Cambria	458	1,707	4/1/23 2:22 PM	4/2/23 6:49 PM
363391	Venango	14	1,705	4/3/23 12:02 PM	4/4/23 4:27 PM
355777	Crawford	5	1,701	4/1/23 1:46 PM	4/2/23 6:07 PM
368146	Venango	3	1,691	4/4/23 11:49 AM	4/5/23 4:00 PM
351369	Crawford	298	1,688	4/1/23 3:29 PM	4/2/23 7:37 PM
352066	Clearfield	40	1,687	4/1/23 3:40 PM	4/2/23 7:47 PM
357966	Crawford	738	1,660	4/1/23 1:53 PM	4/2/23 5:33 PM
365669	Venango	1	1,658	4/4/23 9:22 AM	4/5/23 1:00 PM
365632	Venango	1	1,658	4/4/23 9:04 AM	4/5/23 12:42 PM
349184	Blair	10	1,655	4/1/23 2:57 PM	4/2/23 6:32 PM
349578	Jefferson	1	1,651	4/1/23 3:11 PM	4/2/23 6:42 PM
349033	Clearfield	14	1,650	4/1/23 2:52 PM	4/2/23 6:22 PM
350598	Erie	15	1,649	4/1/23 1:46 PM	4/2/23 5:15 PM
347201	Warren	8	1,648	4/1/23 1:49 PM	4/2/23 5:17 PM
366283	Venango	3	1,647	4/4/23 2:02 PM	4/5/23 5:29 PM
349442	Jefferson	7	1,643	4/1/23 3:07 PM	4/2/23 6:30 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
360043	Wyoming	2	1,643	4/1/23 6:01 PM	4/2/23 9:24 PM
347615	Clearfield	406	1,640	4/1/23 2:48 PM	4/2/23 6:08 PM
361004	Cambria	6	1,639	4/1/23 2:51 PM	4/2/23 6:10 PM
360580	Venango	159	1,639	4/1/23 1:51 PM	4/2/23 5:10 PM
361046	Crawford	3	1,633	4/2/23 4:57 PM	4/3/23 8:10 PM
352142	Clearfield	22	1,630	4/1/23 2:29 PM	4/2/23 5:39 PM
357718	Warren	3	1,629	4/1/23 2:06 PM	4/2/23 5:15 PM
357718	Warren	71	1,629	4/1/23 2:06 PM	4/2/23 5:15 PM
347254	Erie	1	1,626	4/1/23 3:05 PM	4/2/23 6:11 PM
366702	Venango	1	1,625	4/4/23 11:19 AM	4/5/23 2:24 PM
357113	Clearfield	1	1,623	4/2/23 1:16 AM	4/3/23 4:19 AM
362274	Clearfield	899	1,621	4/1/23 2:29 PM	4/2/23 5:30 PM
352049	Clearfield	79	1,617	4/1/23 2:30 PM	4/2/23 5:27 PM
351140	Bradford	4	1,609	4/1/23 4:26 PM	4/2/23 7:15 PM
349407	Erie	4	1,604	4/1/23 3:05 PM	4/2/23 5:49 PM
349725	Tioga	263	1,602	4/1/23 3:29 PM	4/2/23 6:11 PM
349261	Tioga	95	1,602	4/1/23 3:29 PM	4/2/23 6:11 PM
350157	Tioga	117	1,602	4/1/23 3:29 PM	4/2/23 6:11 PM
353454	Clearfield	9	1,602	4/1/23 7:08 PM	4/2/23 9:50 PM
347098	Erie	3	1,601	4/1/23 1:36 PM	4/2/23 4:17 PM
347808	Indiana	82	1,598	4/1/23 2:10 PM	4/2/23 4:48 PM
353917	Bradford	49	1,592	4/1/23 4:25 PM	4/2/23 6:57 PM
351539	Susquehanna	22	1,586	4/1/23 4:51 PM	4/2/23 7:17 PM
357758	Clearfield	1	1,576	4/2/23 6:04 AM	4/3/23 8:20 AM
365634	Venango	6	1,575	4/4/23 9:06 AM	4/5/23 11:21 AM
347597	Venango	119	1,571	4/1/23 1:59 PM	4/2/23 4:10 PM
358422	Bradford	3	1,559	4/2/23 8:38 AM	4/3/23 10:37 AM
361140	Blair	1	1,551	4/1/23 4:11 PM	4/2/23 6:02 PM
357778	Warren	4	1,542	4/1/23 3:03 PM	4/2/23 4:45 PM
360579	Centre	125	1,539	4/1/23 2:57 PM	4/2/23 4:36 PM
360579	Centre	59	1,536	4/1/23 2:57 PM	4/2/23 4:33 PM
356274	Warren	703	1,533	4/1/23 2:11 PM	4/2/23 3:44 PM
347803	Indiana	6	1,529	4/1/23 2:07 PM	4/2/23 3:36 PM
351514	Bradford	7	1,529	4/1/23 4:49 PM	4/2/23 6:18 PM
365440	Venango	11	1,526	4/3/23 10:14 AM	4/4/23 11:40 AM
349314	Clearfield	63	1,523	4/1/23 3:02 PM	4/2/23 4:25 PM
349953	Warren	35	1,520	4/1/23 3:25 PM	4/2/23 4:45 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
347222	Venango	624	1,509	4/1/23 1:51 PM	4/2/23 3:00 PM
353624	Cambria	1	1,508	4/1/23 2:42 PM	4/2/23 3:50 PM
349826	Potter	158	1,506	4/1/23 3:18 PM	4/2/23 4:24 PM
349868	Potter	459	1,506	4/1/23 3:18 PM	4/2/23 4:24 PM
349806	Potter	283	1,506	4/1/23 3:18 PM	4/2/23 4:24 PM
347299	Bedford	1	1,502	4/1/23 1:58 PM	4/2/23 3:00 PM
347676	Venango	275	1,495	4/1/23 2:03 PM	4/2/23 2:58 PM
347721	Venango	158	1,495	4/1/23 2:03 PM	4/2/23 2:58 PM
352142	Clearfield	46	1,491	4/1/23 2:29 PM	4/2/23 3:20 PM
351316	Erie	13	1,483	4/1/23 4:36 PM	4/2/23 5:19 PM
351319	Tioga	14	1,482	4/1/23 4:36 PM	4/2/23 5:18 PM
352142	Clearfield	114	1,480	4/1/23 2:29 PM	4/2/23 3:09 PM
358104	Erie	9	1,476	4/1/23 1:55 PM	4/2/23 2:31 PM
360579	Centre	918	1,469	4/1/23 2:57 PM	4/2/23 3:26 PM
360510	Tioga	100	1,469	4/1/23 3:51 PM	4/2/23 4:20 PM
351565	Jefferson	39	1,468	4/1/23 4:35 PM	4/2/23 5:03 PM
353541	Warren	2	1,468	4/1/23 2:18 PM	4/2/23 2:46 PM
356417	Warren	12	1,467	4/1/23 2:18 PM	4/2/23 2:45 PM
347098	Erie	7	1,463	4/1/23 3:54 PM	4/2/23 4:17 PM
352041	Erie	4	1,461	4/1/23 5:44 PM	4/2/23 6:05 PM
351771	Tioga	82	1,458	4/1/23 5:14 PM	4/2/23 5:32 PM
360025	Cambria	10	1,457	4/1/23 2:22 PM	4/2/23 2:39 PM
360503	Cambria	310	1,457	4/1/23 2:22 PM	4/2/23 2:39 PM
364818	Tioga	1	1,453	4/3/23 3:47 PM	4/4/23 4:00 PM
350921	Tioga	26	1,452	4/1/23 3:18 PM	4/2/23 3:30 PM
358327	Blair	82	1,449	4/1/23 6:20 PM	4/2/23 6:29 PM
351603	Susquehanna	6	1,443	4/1/23 4:57 PM	4/2/23 5:00 PM
347486	Indiana	33	1,440	4/1/23 2:23 PM	4/2/23 2:23 PM
348318	Clearfield	13	1,436	4/1/23 2:46 PM	4/2/23 2:42 PM
348525	Clearfield	184	1,435	4/1/23 2:35 PM	4/2/23 2:30 PM
354210	Cambria	140	1,430	4/1/23 2:05 PM	4/2/23 1:55 PM
362872	Warren	3	1,429	4/3/23 9:17 AM	4/4/23 9:06 AM
367907	Clarion	2	1,427	4/4/23 3:51 PM	4/5/23 3:38 PM
365423	Clearfield	22	1,424	4/3/23 3:38 PM	4/4/23 3:22 PM
351613	Tioga	4	1,421	4/1/23 4:28 PM	4/2/23 4:09 PM
347332	Venango	37	1,421	4/1/23 2:02 PM	4/2/23 1:43 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
349144	Clearfield	32	1,420	4/1/23 2:56 PM	4/2/23 2:36 PM
360353	Erie	14	1,415	4/1/23 4:44 PM	4/2/23 4:19 PM
348216	Cambria	26	1,412	4/1/23 2:26 PM	4/2/23 1:58 PM
357536	Clearfield	16	1,388	4/1/23 7:01 PM	4/2/23 6:09 PM
356689	Cambria	2	1,388	4/1/23 2:22 PM	4/2/23 1:30 PM
368003	Venango	52	1,383	4/4/23 4:42 PM	4/5/23 3:45 PM
347132	Erie	8	1,382	4/1/23 1:41 PM	4/2/23 12:43 PM
347323	Venango	5	1,379	4/1/23 2:01 PM	4/2/23 1:00 PM
352299	Tioga	3	1,373	4/1/23 6:07 PM	4/2/23 5:00 PM
347682	Crawford	19	1,372	4/1/23 2:08 PM	4/2/23 1:00 PM
364798	Tioga	20	1,370	4/1/23 4:29 PM	4/2/23 3:19 PM
351169	Tioga	20	1,370	4/1/23 4:29 PM	4/2/23 3:19 PM
359980	Indiana	9	1,365	4/1/23 2:28 PM	4/2/23 1:13 PM
350780	Tioga	286	1,363	4/1/23 3:51 PM	4/2/23 2:34 PM
350202	Tioga	104	1,359	4/1/23 3:33 PM	4/2/23 2:12 PM
347289	Venango	65	1,357	4/1/23 1:55 PM	4/2/23 12:32 PM
350755	Potter	37	1,354	4/1/23 3:54 PM	4/2/23 2:28 PM
359980	Indiana	83	1,351	4/1/23 2:28 PM	4/2/23 12:59 PM
354394	Erie	2	1,350	4/1/23 1:45 PM	4/2/23 12:15 PM
350653	Tioga	45	1,349	4/1/23 3:51 PM	4/2/23 2:20 PM
358065	Indiana	21	1,349	4/1/23 5:55 PM	4/2/23 4:24 PM
359980	Indiana	37	1,343	4/1/23 2:28 PM	4/2/23 12:51 PM
352400	Susquehanna	10	1,336	4/1/23 6:18 PM	4/2/23 4:34 PM
350431	Tioga	36	1,335	4/1/23 3:41 PM	4/2/23 1:56 PM
364672	Clearfield	29	1,332	4/3/23 5:28 PM	4/4/23 3:40 PM
358163	Venango	25	1,327	4/1/23 2:44 PM	4/2/23 12:51 PM
350384	Indiana	18	1,326	4/1/23 3:39 PM	4/2/23 1:45 PM
347870	Jefferson	317	1,322	4/1/23 2:20 PM	4/2/23 12:22 PM
362099	Clarion	185	1,315	4/2/23 10:14 PM	4/3/23 8:09 PM
362099	Clarion	185	1,315	4/2/23 10:14 PM	4/3/23 8:09 PM
363506	Clearfield	1	1,311	4/3/23 12:38 PM	4/4/23 10:29 AM
350785	Cambria	9	1,305	4/1/23 2:03 PM	4/2/23 11:48 AM
350556	Indiana	49	1,304	4/1/23 2:13 PM	4/2/23 11:57 AM
347725	Indiana	221	1,304	4/1/23 2:10 PM	4/2/23 11:54 AM
366462	Venango	13	1,302	4/4/23 12:13 PM	4/5/23 9:55 AM
355656	Susquehanna	4	1,299	4/1/23 9:18 PM	4/2/23 6:57 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
362237	Indiana	25	1,295	4/1/23 2:48 PM	4/2/23 12:23 PM
357791	Erie	24	1,293	4/1/23 2:05 PM	4/2/23 11:38 AM
352536	Clearfield	133	1,292	4/1/23 2:13 PM	4/2/23 11:45 AM
353670	Jefferson	14	1,289	4/1/23 6:56 PM	4/2/23 4:25 PM
353903	Cambria	8	1,284	4/1/23 7:36 PM	4/2/23 5:00 PM
357260	Warren	76	1,281	4/1/23 2:09 PM	4/2/23 11:30 AM
352395	Indiana	1	1,273	4/1/23 6:17 PM	4/2/23 3:30 PM
360579	Centre	357	1,266	4/1/23 2:57 PM	4/2/23 12:03 PM
355968	Cambria	7	1,255	4/1/23 4:33 PM	4/2/23 1:28 PM
350286	Warren	1	1,254	4/1/23 3:36 PM	4/2/23 12:30 PM
347615	Clearfield	8	1,250	4/1/23 2:48 PM	4/2/23 11:38 AM
347714	Crawford	42	1,241	4/1/23 2:04 PM	4/2/23 10:45 AM
347422	Warren	11	1,239	4/1/23 2:15 PM	4/2/23 10:54 AM
351676	Bradford	14	1,234	4/1/23 5:06 PM	4/2/23 1:40 PM
360584	Westmoreland	3	1,234	4/2/23 7:42 AM	4/3/23 4:16 AM
351107	Erie	6	1,231	4/1/23 4:23 PM	4/2/23 12:54 PM
350335	Mckean	8	1,228	4/1/23 3:37 PM	4/2/23 12:05 PM
366819	Clarion	4	1,227	4/4/23 7:19 PM	4/5/23 3:46 PM
352270	Bedford	5	1,218	4/1/23 6:04 PM	4/2/23 2:22 PM
349490	Huntingdon	69	1,212	4/1/23 3:08 PM	4/2/23 11:20 AM
347138	Crawford	16	1,212	4/1/23 1:43 PM	4/2/23 9:55 AM
358563	Bradford	86	1,211	4/1/23 5:06 PM	4/2/23 1:17 PM
350123	Cambria	8	1,211	4/1/23 2:19 PM	4/2/23 10:30 AM
356889	Tioga	64	1,209	4/1/23 3:33 PM	4/2/23 11:42 AM
347615	Clearfield	20	1,208	4/1/23 2:48 PM	4/2/23 10:56 AM
355874	Jefferson	14	1,207	4/1/23 2:18 PM	4/2/23 10:25 AM
351396	Susquehanna	5	1,204	4/1/23 4:41 PM	4/2/23 12:45 PM
347153	Crawford	4	1,203	4/1/23 1:44 PM	4/2/23 9:47 AM
347605	Clearfield	488	1,196	4/1/23 2:36 PM	4/2/23 10:32 AM
361161	Erie	19	1,193	4/1/23 1:37 PM	4/2/23 9:30 AM
364939	Clearfield	7	1,186	4/3/23 7:44 PM	4/4/23 3:30 PM
353624	Cambria	1	1,180	4/1/23 8:10 PM	4/2/23 3:50 PM
352536	Clearfield	4	1,178	4/1/23 6:16 PM	4/2/23 1:54 PM
347766	Indiana	75	1,176	4/1/23 2:06 PM	4/2/23 9:42 AM
351972	Wyoming	22	1,172	4/1/23 5:38 PM	4/2/23 1:10 PM
356569	Erie	1	1,171	4/1/23 10:55 PM	4/2/23 6:26 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
347384	Jefferson	12	1,167	4/1/23 2:13 PM	4/2/23 9:40 AM
355266	Erie	13	1,166	4/1/23 3:54 PM	4/2/23 11:20 AM
347540	Blair	3	1,166	4/1/23 2:39 PM	4/2/23 10:05 AM
362630	Tioga	17	1,163	4/2/23 10:00 PM	4/3/23 5:23 PM
355463	Erie	1	1,149	4/1/23 9:06 PM	4/2/23 4:15 PM
347315	Erie	3	1,145	4/1/23 1:55 PM	4/2/23 9:00 AM
358825	Erie	12	1,142	4/1/23 3:51 PM	4/2/23 10:53 AM
361899	Crawford	3	1,141	4/2/23 8:15 PM	4/3/23 3:16 PM
359258	Bradford	30	1,135	4/1/23 4:47 PM	4/2/23 11:42 AM
354264	Crawford	45	1,134	4/1/23 1:38 PM	4/2/23 8:32 AM
347691	Jefferson	464	1,129	4/1/23 2:13 PM	4/2/23 9:02 AM
348290	Clearfield	82	1,124	4/1/23 6:16 PM	4/2/23 1:00 PM
347875	Clearfield	195	1,124	4/1/23 6:16 PM	4/2/23 1:00 PM
352536	Clearfield	159	1,124	4/1/23 6:16 PM	4/2/23 1:00 PM
347849	Clearfield	40	1,124	4/1/23 2:16 PM	4/2/23 9:00 AM
350921	Tioga	87	1,122	4/1/23 3:18 PM	4/2/23 10:00 AM
357794	Erie	34	1,119	4/1/23 2:01 PM	4/2/23 8:40 AM
364620	Clearfield	78	1,118	4/3/23 5:06 PM	4/4/23 11:44 AM
349734	Blair	6	1,118	4/1/23 3:17 PM	4/2/23 9:55 AM
348945	Mckean	39	1,118	4/1/23 2:49 PM	4/2/23 9:27 AM
350159	Cambria	3	1,114	4/1/23 3:32 PM	4/2/23 10:06 AM
362047	Warren	71	1,113	4/1/23 10:42 PM	4/2/23 5:15 PM
364280	Clearfield	4	1,112	4/3/23 3:28 PM	4/4/23 10:00 AM
367836	Clarion	11	1,110	4/4/23 4:31 PM	4/5/23 11:01 AM
352086	Erie	2	1,107	4/1/23 5:46 PM	4/2/23 12:13 PM
347833	Warren	119	1,107	4/1/23 2:13 PM	4/2/23 8:40 AM
350705	Tioga	98	1,098	4/1/23 3:53 PM	4/2/23 10:11 AM
349272	Erie	9	1,098	4/1/23 3:00 PM	4/2/23 9:18 AM
349497	Mckean	1	1,091	4/1/23 3:09 PM	4/2/23 9:20 AM
349492	Warren	7	1,091	4/1/23 3:09 PM	4/2/23 9:20 AM
366268	Venango	157	1,088	4/4/23 1:57 PM	4/5/23 8:05 AM
348331	Clearfield	50	1,070	4/1/23 2:30 PM	4/2/23 8:20 AM
366806	Clarion	35	1,067	4/4/23 1:51 AM	4/4/23 7:38 PM
366559	Crawford	3	1,063	4/4/23 4:37 PM	4/5/23 10:20 AM
351159	Susquehanna	28	1,059	4/1/23 4:26 PM	4/2/23 10:05 AM
358816	Wyoming	2	1,055	4/1/23 10:55 PM	4/2/23 4:30 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
360378	Wyoming	4	1,055	4/1/23 10:55 PM	4/2/23 4:30 PM
351381	Mifflin	1	1,054	4/1/23 4:40 PM	4/2/23 10:14 AM
348377	Clearfield	665	1,053	4/1/23 2:32 PM	4/2/23 8:05 AM
356800	Erie	9	1,050	4/1/23 1:51 PM	4/2/23 7:21 AM
349874	Cambria	31	1,048	4/1/23 3:22 PM	4/2/23 8:50 AM
367149	Forest	8	1,042	4/4/23 8:27 PM	4/5/23 1:49 PM
348702	Erie	29	1,041	4/1/23 2:45 PM	4/2/23 8:06 AM
347693	Indiana	1	1,040	4/1/23 2:10 PM	4/2/23 7:30 AM
365182	Clarion	35	1,039	4/4/23 1:51 AM	4/4/23 7:10 PM
347198	Erie	38	1,039	4/1/23 1:48 PM	4/2/23 7:07 AM
354371	Cambria	2	1,037	4/1/23 8:01 PM	4/2/23 1:18 PM
352054	Clearfield	34	1,036	4/1/23 2:49 PM	4/2/23 8:05 AM
359797	Blair	3	1,020	4/2/23 12:20 PM	4/3/23 5:20 AM
359055	Erie	1	1,020	4/1/23 6:00 PM	4/2/23 11:00 AM
350889	Warren	1	1,017	4/1/23 4:03 PM	4/2/23 9:00 AM
361110	Erie	3	1,016	4/2/23 5:19 PM	4/3/23 10:15 AM
358037	Crawford	10	997	4/1/23 2:53 PM	4/2/23 7:30 AM
358037	Crawford	10	997	4/1/23 2:53 PM	4/2/23 7:30 AM
349928	Somerset	1	996	4/1/23 3:24 PM	4/2/23 8:00 AM
350607	Somerset	1	990	4/1/23 3:48 PM	4/2/23 8:18 AM
362285	Clearfield	4	982	4/3/23 1:27 AM	4/3/23 5:49 PM
366155	Venango	6	979	4/4/23 12:45 PM	4/5/23 5:04 AM
353998	Indiana	218	970	4/1/23 2:23 PM	4/2/23 6:33 AM
352741	Erie	17	968	4/1/23 6:41 PM	4/2/23 10:49 AM
355083	Blair	2	964	4/1/23 8:36 PM	4/2/23 12:40 PM
361952	Blair	22	954	4/2/23 4:02 PM	4/3/23 7:56 AM
348384	Cambria	17	948	4/1/23 2:25 PM	4/2/23 6:13 AM
350670	Somerset	1	944	4/1/23 3:51 PM	4/2/23 7:35 AM
347367	Venango	42	923	4/1/23 1:56 PM	4/2/23 5:19 AM
347445	Venango	588	922	4/1/23 1:57 PM	4/2/23 5:19 AM
349626	Mckean	22	916	4/1/23 3:13 PM	4/2/23 6:29 AM
355619	Wyoming	21	914	4/1/23 9:16 PM	4/2/23 12:30 PM
347750	Venango	61	914	4/1/23 2:05 PM	4/2/23 5:19 AM
350415	Erie	101	913	4/1/23 11:00 AM	4/2/23 2:13 AM
347689	Venango	8	913	4/1/23 2:06 PM	4/2/23 5:19 AM
352263	Susquehanna	24	905	4/1/23 6:04 PM	4/2/23 9:09 AM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
356865	Susquehanna	3	888	4/2/23 12:14 AM	4/2/23 3:02 PM
355844	Susquehanna	11	887	4/1/23 9:29 PM	4/2/23 12:16 PM
349622	Cambria	6	887	4/1/23 3:13 PM	4/2/23 6:00 AM
362088	Tioga	2	884	4/2/23 10:06 PM	4/3/23 12:50 PM
347620	Crawford	639	881	4/1/23 1:59 PM	4/2/23 4:40 AM
347752	Crawford	1,025	875	4/1/23 2:05 PM	4/2/23 4:40 AM
347228	Venango	1	874	4/1/23 1:52 PM	4/2/23 4:26 AM
350491	Somerset	5	865	4/1/23 3:43 PM	4/2/23 6:08 AM
356421	Warren	18	863	4/1/23 10:17 PM	4/2/23 12:40 PM
357777	Erie	98	862	4/1/23 1:54 PM	4/2/23 4:16 AM
352104	Venango	49	853	4/1/23 5:49 PM	4/2/23 8:02 AM
352104	Venango	49	853	4/1/23 5:49 PM	4/2/23 8:02 AM
349260	Clearfield	13	846	4/1/23 3:00 PM	4/2/23 5:06 AM
359055	Erie	5	842	4/1/23 6:00 PM	4/2/23 8:02 AM
357777	Erie	145	842	4/1/23 1:54 PM	4/2/23 3:56 AM
364938	Clarion	1	839	4/3/23 7:43 PM	4/4/23 9:42 AM
359121	Cambria	6	837	4/2/23 12:43 AM	4/2/23 2:40 PM
360559	Wayne	11	836	4/2/23 2:34 AM	4/2/23 4:30 PM
357450	Jefferson	268	832	4/1/23 2:20 PM	4/2/23 4:12 AM
351565	Jefferson	524	830	4/1/23 4:35 PM	4/2/23 6:25 AM
353160	Cambria	554	822	4/1/23 2:22 PM	4/2/23 4:04 AM
349195	Crawford	78	822	4/1/23 2:58 PM	4/2/23 4:40 AM
356872	Jefferson	3	810	4/2/23 12:00 PM	4/3/23 1:30 AM
347290	Erie	214	809	4/1/23 1:54 PM	4/2/23 3:23 AM
350788	Cambria	23	804	4/1/23 2:19 PM	4/2/23 3:43 AM
366690	Clearfield	7	802	4/4/23 6:09 PM	4/5/23 7:31 AM
356219	Crawford	2	799	4/1/23 2:53 PM	4/2/23 4:12 AM
356219	Crawford	2	799	4/1/23 2:53 PM	4/2/23 4:12 AM
352222	Erie	2	793	4/1/23 6:00 PM	4/2/23 7:13 AM
348398	Jefferson	391	785	4/1/23 2:20 PM	4/2/23 3:25 AM
357450	Jefferson	2	785	4/1/23 2:20 PM	4/2/23 3:25 AM
356840	Westmoreland	10	785	4/1/23 3:24 PM	4/2/23 4:29 AM
356840	Westmoreland	8	783	4/1/23 3:24 PM	4/2/23 4:27 AM
358655	Somerset	1	757	4/1/23 10:23 PM	4/2/23 11:00 AM
365630	Clearfield	1	747	4/4/23 9:03 AM	4/4/23 9:30 PM
356108	Warren	23	746	4/1/23 2:09 PM	4/2/23 2:35 AM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
347167	Crawford	22	739	4/1/23 8:09 PM	4/2/23 8:28 AM
357261	Wayne	15	734	4/2/23 2:34 AM	4/2/23 2:48 PM
347227	Venango	144	728	4/1/23 1:52 PM	4/2/23 2:00 AM
356254	Clearfield	8	723	4/1/23 8:54 PM	4/2/23 8:57 AM
357811	Mifflin	3	715	4/1/23 6:35 PM	4/2/23 6:30 AM
356251	Warren	116	710	4/1/23 10:10 PM	4/2/23 10:00 AM
362509	Tioga	1	706	4/3/23 6:29 AM	4/3/23 6:15 PM
351852	Bradford	13	704	4/1/23 5:23 PM	4/2/23 5:07 AM
351174	Bradford	9	701	4/1/23 4:29 PM	4/2/23 4:10 AM
361442	Mckean	275	700	4/2/23 6:42 PM	4/3/23 6:22 AM
347548	Indiana	53	686	4/1/23 2:02 PM	4/2/23 1:28 AM
348343	Clearfield	211	683	4/1/23 2:27 PM	4/2/23 1:50 AM
350574	Erie	9	672	4/1/23 3:46 PM	4/2/23 2:58 AM
350275	Mifflin	8	670	4/1/23 3:35 PM	4/2/23 2:45 AM
348550	Somerset	4	663	4/1/23 2:36 PM	4/2/23 1:39 AM
354210	Cambria	336	662	4/1/23 2:05 PM	4/2/23 1:07 AM
357245	Westmoreland	56	661	4/1/23 5:15 PM	4/2/23 4:16 AM
347338	Cambria	1	653	4/1/23 1:49 PM	4/2/23 12:42 AM
346553	Crawford	14	650	4/1/23 7:04 AM	4/1/23 5:54 PM
355920	Perry	1	649	4/1/23 9:35 PM	4/2/23 8:24 AM
347703	Clearfield	155	637	4/1/23 2:15 PM	4/2/23 12:52 AM
362168	Cambria	11	633	4/2/23 1:17 PM	4/2/23 11:50 PM
360454	Bedford	1	632	4/2/23 2:23 PM	4/3/23 12:55 AM
367635	Venango	1	613	4/5/23 7:41 AM	4/5/23 5:54 PM
357149	Crawford	23	609	4/2/23 1:31 AM	4/2/23 11:40 AM
349910	Westmoreland	10	602	4/1/23 5:38 PM	4/2/23 3:40 AM
363338	Mckean	1	601	4/3/23 11:43 AM	4/3/23 9:44 PM
351637	Somerset	2	599	4/1/23 5:01 PM	4/2/23 3:00 AM
347703	Clearfield	11	597	4/1/23 2:15 PM	4/2/23 12:12 AM
347973	Jefferson	645	597	4/1/23 2:15 PM	4/2/23 12:12 AM
347703	Clearfield	805	594	4/1/23 2:15 PM	4/2/23 12:09 AM
351929	Bedford	2	591	4/1/23 5:34 PM	4/2/23 3:25 AM
346376	Erie	5	588	4/1/23 4:03 AM	4/1/23 1:51 PM
352356	Jefferson	14	581	4/1/23 2:18 PM	4/1/23 11:59 PM
359883	Venango	64	581	4/2/23 12:46 PM	4/2/23 10:27 PM
351655	Bradford	3	581	4/1/23 5:03 PM	4/2/23 2:44 AM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
365860	Clarion	1	577	4/4/23 10:48 AM	4/4/23 8:25 PM
348779	Cambria	19	573	4/1/23 2:47 PM	4/2/23 12:20 AM
362987	Tioga	154	571	4/3/23 10:14 AM	4/3/23 7:45 PM
347216	Cambria	10	571	4/1/23 1:49 PM	4/1/23 11:20 PM
349910	Westmoreland	8	565	4/1/23 5:38 PM	4/2/23 3:03 AM
353918	Somerset	7	563	4/1/23 5:06 PM	4/2/23 2:29 AM
363770	Venango	1	557	4/3/23 2:03 PM	4/3/23 11:20 PM
352308	Blair	15	555	4/1/23 6:08 PM	4/2/23 3:23 AM
349752	Huntingdon	3	554	4/1/23 3:18 PM	4/2/23 12:32 AM
346425	Crawford	29	551	4/1/23 4:29 AM	4/1/23 1:40 PM
346420	Erie	21	532	4/1/23 4:28 AM	4/1/23 1:20 PM
367529	Venango	1	528	4/5/23 6:13 AM	4/5/23 3:01 PM
363495	Jefferson	2	524	4/3/23 12:36 PM	4/3/23 9:20 PM
351853	Bradford	7	514	4/1/23 5:23 PM	4/2/23 1:57 AM
361349	Cambria	1	508	4/2/23 6:09 PM	4/3/23 2:37 AM
362876	Clearfield	2	507	4/3/23 9:18 AM	4/3/23 5:45 PM
366556	Clarion	1	503	4/4/23 4:35 PM	4/5/23 12:58 AM
362971	Venango	1	501	4/3/23 9:58 AM	4/3/23 6:19 PM
365933	Venango	14	498	4/4/23 11:19 AM	4/4/23 7:37 PM
351332	Tioga	1	498	4/1/23 4:37 PM	4/2/23 12:55 AM
353160	Cambria	2	494	4/1/23 2:22 PM	4/1/23 10:36 PM
348232	Clearfield	87	490	4/1/23 5:40 PM	4/2/23 1:50 AM
346461	Crawford	1	488	4/1/23 4:57 AM	4/1/23 1:05 PM
356881	Cumberland	17	484	4/2/23 12:17 AM	4/2/23 8:21 AM
365413	Erie	6	483	4/4/23 7:42 AM	4/4/23 3:45 PM
347535	Warren	371	482	4/1/23 2:12 PM	4/1/23 10:14 PM
347891	Warren	121	481	4/1/23 2:22 PM	4/1/23 10:23 PM
356172	Indiana	7	478	4/1/23 2:18 PM	4/1/23 10:16 PM
346370	Clearfield	6	475	4/1/23 3:57 AM	4/1/23 11:52 AM
351794	Bradford	3	475	4/1/23 5:17 PM	4/2/23 1:12 AM
349788	Huntingdon	14	471	4/1/23 3:19 PM	4/1/23 11:10 PM
351107	Erie	6	467	4/1/23 4:23 PM	4/2/23 12:10 AM
365819	Venango	7	466	4/4/23 10:30 AM	4/4/23 6:16 PM
357669	Mifflin	20	464	4/2/23 5:19 AM	4/2/23 1:03 PM
347254	Erie	147	461	4/1/23 1:51 PM	4/1/23 9:32 PM
347693	Indiana	84	461	4/1/23 2:10 PM	4/1/23 9:51 PM

Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
347136	Erie	7	461	4/1/23 1:42 PM	4/1/23 9:23 PM
347097	Erie	6	460	4/1/23 1:36 PM	4/1/23 9:16 PM
347254	Erie	596	460	4/1/23 1:51 PM	4/1/23 9:31 PM
347700	Warren	985	453	4/1/23 2:14 PM	4/1/23 9:47 PM
347950	Warren	883	452	4/1/23 2:14 PM	4/1/23 9:46 PM
367631	Somerset	1	451	4/1/23 5:05 PM	4/2/23 12:36 AM
365190	Indiana	3	450	4/4/23 2:53 AM	4/4/23 10:23 AM
348007	Warren	269	447	4/1/23 2:17 PM	4/1/23 9:44 PM
348406	Mckean	71	446	4/1/23 2:34 PM	4/1/23 10:00 PM
348406	Mckean	71	446	4/1/23 2:34 PM	4/1/23 10:00 PM
348011	Warren	264	446	4/1/23 2:18 PM	4/1/23 9:44 PM
365098	Cambria	12	443	4/3/23 9:50 PM	4/4/23 5:13 AM
365098	Cambria	18	443	4/3/23 9:50 PM	4/4/23 5:13 AM
367631	Somerset	6	443	4/1/23 5:05 PM	4/2/23 12:28 AM
346310	Erie	36	439	4/1/23 1:59 AM	4/1/23 9:18 AM
352356	Jefferson	1	436	4/1/23 2:18 PM	4/1/23 9:34 PM
352356	Jefferson	81	436	4/1/23 2:18 PM	4/1/23 9:34 PM
353306	Cambria	351	435	4/1/23 2:22 PM	4/1/23 9:37 PM
350370	Crawford	3	435	4/1/23 2:53 PM	4/1/23 10:08 PM
368188	Clearfield	1	434	4/5/23 8:35 AM	4/5/23 3:49 PM
346495	Erie	1	434	4/1/23 5:46 AM	4/1/23 1:00 PM
346347	Erie	183	431	4/1/23 4:09 AM	4/1/23 11:20 AM
367549	Clarion	9	430	4/5/23 6:30 AM	4/5/23 1:40 PM
347202	Crawford	489	427	4/1/23 1:49 PM	4/1/23 8:56 PM
349910	Westmoreland	258	423	4/1/23 5:38 PM	4/2/23 12:41 AM
367850	Venango	1	423	4/5/23 11:10 AM	4/5/23 6:13 PM
350793	Crawford	36	422	4/1/23 3:57 PM	4/1/23 10:59 PM
349075	Mckean	26	421	4/1/23 2:53 PM	4/1/23 9:54 PM
365001	Tioga	3	419	4/3/23 3:57 PM	4/3/23 10:56 PM
367581	Venango	3	418	4/5/23 7:22 AM	4/5/23 2:20 PM
362663	Lycoming	1	417	4/3/23 8:24 AM	4/3/23 3:21 PM
350479	Indiana	27	415	4/1/23 2:18 PM	4/1/23 9:13 PM
368170	Centre	2	415	4/5/23 2:53 PM	4/5/23 9:48 PM
368277	Erie	2	414	4/5/23 11:58 AM	4/5/23 6:52 PM
359244	Warren	1	414	4/2/23 11:32 AM	4/2/23 6:26 PM
352356	Jefferson	94	414	4/1/23 2:18 PM	4/1/23 9:12 PM


Penelec Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
360562	Cambria	1	409	4/2/23 2:51 PM	4/2/23 9:40 PM
360418	Tioga	5	409	4/2/23 2:15 PM	4/2/23 9:04 PM
351415	Bradford	6	408	4/1/23 4:42 PM	4/1/23 11:30 PM
349087	Crawford	212	403	4/1/23 2:54 PM	4/1/23 9:37 PM
347227	Venango	18	403	4/1/23 1:52 PM	4/1/23 8:35 PM
364661	Juniata	1	400	4/3/23 5:25 PM	4/4/23 12:05 AM
347169	Crawford	21	398	4/1/23 1:46 PM	4/1/23 8:24 PM
353998	Indiana	2,286	396	4/1/23 2:23 PM	4/1/23 8:59 PM
367843	Clearfield	1	394	4/5/23 11:40 AM	4/5/23 6:14 PM
353998	Indiana	51	391	4/1/23 2:23 PM	4/1/23 8:54 PM
349910	Westmoreland	471	388	4/1/23 5:38 PM	4/2/23 12:06 AM
347540	Blair	354	387	4/1/23 2:39 PM	4/1/23 9:06 PM
360988	Bradford	1	385	4/2/23 4:40 PM	4/2/23 11:05 PM
347087	Crawford	138	381	4/1/23 1:29 PM	4/1/23 7:50 PM
359760	Erie	1	380	4/2/23 12:11 PM	4/2/23 6:31 PM
367824	Clearfield	38	379	4/5/23 10:54 AM	4/5/23 5:13 PM
349834	Blair	14	379	4/1/23 3:21 PM	4/1/23 9:40 PM
348678	Clearfield	13	378	4/1/23 2:36 PM	4/1/23 8:54 PM
352356	Jefferson	686	376	4/1/23 2:18 PM	4/1/23 8:34 PM
347168	Erie	121	375	4/1/23 1:45 PM	4/1/23 8:00 PM
349190	Centre	47	373	4/1/23 2:58 PM	4/1/23 9:11 PM
346610	Jefferson	7	370	4/1/23 3:44 AM	4/1/23 9:54 AM
347540	Blair	117	368	4/1/23 2:39 PM	4/1/23 8:47 PM
366646	Warren	2	366	4/4/23 11:30 AM	4/4/23 5:36 PM
346481	Bradford	1	364	4/1/23 5:27 AM	4/1/23 11:31 AM
348431	Blair	16	362	4/1/23 2:37 PM	4/1/23 8:39 PM
365959	Warren	16	362	4/4/23 11:30 AM	4/4/23 5:32 PM


Attachment B: Precipitation Reports

Wind & Precipitation Reports: Graphic 1 & 2 illustrates the maximum wind gusts in the Penelec service territory on April 1 & 2, 2023. Graphic 3 illustrate the 24-Hour Total Precipitation in the Penelec service territory on April 1, 2023. The graphics are from the National Oceanic and Atmospheric Administration (“NOAA”).


Graphic 1: Wind Speeds: Saturday, April 1, 2023




Graphic 2: Wind Speeds: Sunday, April 2, 2023




Graphic 3: 24-Hour Total Precipitation: Saturday, April 1, 2023




Attachment C: Restoration Curve



Attachment D: Order Restoration Graphs





Attachment E: Meteorologist Reports

Tuesday, March 28, 2023 @ 0941

Special Weather Statement – Saturday

Weather system expected this Saturday has the potential to produce a day’s worth of strong wind gusts. A preliminary cut at general threats are provided in the graphic.

We have some confidence the best chance for strongest gusts will be where the front passes during afternoon hours.

However, we don’t have confidence yet with the position and timing of the front itself - critical for the details (will get more clarity as the event draws closer).

Therefore a rough starting point estimate of gust magnitudes are 45-55 mph in locations where the front passes through before midday and elsewhere the same plus some 55-65+ mph gusts. Also areas where the front arrives earlier in the day implies a longer duration of wind gusts and vice versa (because generally after sunset the gusts will shut off except the typical ridge tops of WV/MD/PA)

Reiterating this is a preliminary cut and not etched in stone.

Next Update – Wed 11am

Manousos – 330 396 0059

Workoff – 716 397 4430



Wednesday, March 29, 2023 @ 1037

New Issuance:

Changes (relative to yesterday’s Special Weather Statement):

1. Friday - added details for nuisance gust threat combined with 1” rain potential. Confidence is normal with this panel.
2. Saturday
 - a. Delayed front’s arrival by 2 hours all locations. Confidence is normal for top right panel
 - b. Added details for non-thunderstorm gusts and an additional thunderstorm risk. Confidence is slightly below normal for bottom left panel (too far out still to discern details and quantify risk regarding thunder)


Although this is not a cut/paste event from last weekend – it has a lot of the same attributes (preceding rain, non-thunderstorm gusts, thunderstorm threat, skies clearing out a few hours before the front arrives).

But by comparison the window for max winds this event is going to be tied with the frontal passage itself (a 1-2 hour window) vs last weekend’s long period of 60+ mph gusts. Regardless, this Saturday before and after that window of max gusts, there will be occasional gusts 40-50 mph through late afternoon. And the threat does extend farther east than last weekend’s event.

Next Update – Thu 11am

Manousos – 330 396 0059

Workoff – 716 397 4430



Thursday, March 30, 2023 @ 0914

Changes: Overall slight improvement to the forecast. Big picture still - general 40-50 mph gusts most of Saturday will get enhanced for a short period by two causes: the frontal passage itself (expected) and any thunderstorms (low risk)


1. Friday: Added a period of gusts in the afternoon, reduced area of gusts in WV/PA/MD, eliminated north area of 1"+ rain potential. Confidence is normal with this panel.
2. Saturday: Fine-tuned frontal timing, trimmed area (red) for highest gusts, diminished frequency of gusts east half of FE. Confidence is normal with this panel.
 - a. It is still too far into the future to quantify the thunderstorm risk Saturday. We will be able to do so in tomorrow's update but an initial ball-park estimate is no higher than 30% in the yellow area and about half that in the white area.

Reiterating - FE is expected to receive what is detailed in the bottom right panel. The thunder threat is an additional lower risk threat.

Next Update – Fri 11am

Manousos – 330 396 0059

Workoff – 716 397 4430



Friday, March 31, 2023 @ 0856

Changes

1. Today: Added thunder threat this evening/overnight OH and WV/southwest PA. Fine-tuned 1"+ rain window. Confidence is normal with this panel except with how far east thunder threat extends.
2. Saturday: Fine tuned timing of front. Extended duration of strong wind gusts significantly (by a 2-3 hours) in red area. Added details for thunderstorm risk. Confidence is normal with this panel except for thunder threat which confidence is slightly below normal.

Next Update – Sat 11am

Manousos – 330 396 0059

Workoff – 716 397 4430

