



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE
REFER TO OUR FILE

May 16, 2023

Docket No. A-2023-3039812
Utility Code 230073

ERIN K FURE ESQUIRE
PENNSYLVANIA AMERICAN WATER COMPANY
852 WESLEY DRIVE
MECHANICSBURG PA 17055
ERIN.FURE@AMWATER.COM

RE: Application of Pennsylvania-American Water Company – Wastewater Division for approval to begin to offer, render, furnish or supply wastewater service to the public in an additional portion of Sadsbury Township, Chester County, Pennsylvania at Docket No. A-2023-3039812

Dear Attorney Fure:

On April 11, 2023, Pennsylvania-American Water Company – Wastewater Division (PAWC-WD) filed the above-referenced documents (Application) with the Pennsylvania Public Utility Commission (Commission). For the Commission to complete its analysis of the filing, please respond with the information requested in the attached document.

Please forward the information to the Secretary of the Commission at the address listed below **within ten (10) business days** from the date of this letter. Make sure to reference the Docket Number listed above when filing your response. Please note that some responses may be e-filed to your case, <http://www.puc.pa.gov/efiling/default.aspx>. A list of document types allowed to be e-filed can be found at <http://www.puc.pa.gov/efiling/DocTypes.aspx>. All documents requiring notary stamps must have original signatures.

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

Your answers must be verified per 52 Pa Code § 1.36. Accordingly, you must provide the following statement with your responses:

I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Signature _____

Title _____

Date _____

Please contact the below staff person if any problems should arise that prevent a full response within ten business days or if any clarification of these data requests is needed. Please mark the materials "CONFIDENTIAL" in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

In addition, to expedite completion of the application, please send a copy of your response to Clinton McKinley in the Water/Wastewater Section of the Bureau of Technical Utility Services via e-mail at cmckinley@pa.gov. Thank you in advance for your cooperation.

Sincerely,



Rosemary Chiavetta
Secretary

Enclosure: TUS Data Request Set 2

cc: Patrick Cicero, Office of Consumer Advocate (w/enclosure), ra-oca@pa.gov
Christine Hoover, Office of Consumer Advocate (w/enclosure), choover@paoca.org
NazAarah Sabree, Office of Small Business Advocate (w/enclosure), ra-sba@pa.gov
Richard Kanaskie, Bureau of Investigation & Enforcement (w/enclosure), rkanaskie@pa.gov

TUS Data Request Set 2

Application of Pennsylvania-American Water Company – Wastewater Division for approval to begin to offer, render, furnish or supply wastewater service to the public in an additional portion of Sadsbury Township, Chester County, Pennsylvania at Docket No. A-2023-3039812

Note: Please restate the data request prior to providing a response. In addition, provide the name and title of the person(s) providing the response and/or information for each data request.

- A-8 In response to Data Request A-1a., PAWC-WD indicated PAWC-WD is the owner of the Octorara Force Main. However, Section 9 of the Utility Easement Agreement between Upper Octorara Presbyterian Church and Sadsbury Commons, L.P. (UOPEA), provided in response to Data Request A-3, indicated that the Octorara Force Main shall be owned by Sadsbury Commons, L.P. and that Sadsbury Commons, L.P. may dedicate, assign, grant alienate, convey or sell the force main. Considering this discrepancy, please provide the following:
- a. An executed copy of any Sewer Main Extension Agreement or Sewer Main Extension Deposit Agreement PAWC-WD's entered into with Sadsbury Commons, L.P. for the construction of the Octorara Force Main;
 - b. Evidence that the Octorara Force Main was dedicated to PAWC-WD;
 - c. A description of PAWC-WD's journal entries by major plant account for the booking of the original cost of the Octorara Force Main. Specifically identify all contributions in-aid-of construction and company contributions; and
 - d. If PAWC-WD incurred the cost to construct the Octorara Force Main, please explain how this complies with PAWC-WD's effective tariff.
- A-9 In response to Data Request A-1c., PAWC-WD identified the diameter of the Octorara Force Main to be six feet. Please reconfirm the diameter of the Octorara Force Main as a six foot force main does not seem plausible for the described system.
- A-10 In response to Data Request A-5., PAWC-WD indicated it intends to meter water consumption at the requested service territory by installing a PAWC-owned meter on the privately-owned well at the Octorara Trail property and will issue wastewater bills based on meter reads from such meter. Please quantify the cost of the meter and meter installation and identify the PAWC-WD or PAWC account under which this cost will be recorded.