

ELECTRIC UTILITY REPORT OF OUTAGE TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU
400 NORTH STREET
HARRISBURG, PA 17105-3265

RCVD PUC SEC BUR
OCT 19 2023 AM 10:41

Phone-In Reports: Always call (717) 941-0003
Email RA-PUCPEMA@pa.gov

M-2021-3023564

An original and one copy of this report are to be mailed to the Secretary's Bureau at the address above, even if an electronic copy has been emailed to the address above.

Information Required:

1. Reporting Utility: Pike County Light & Power Company ("PCL&P")
Address: 105 Schneider Lane, Milford, PA 18337

2. Name and title of person making report:

Ed Verbraak

(Name)

General Manager

(Title)

3. Telephone number: 570-832-2988 Ext 354
(Telephone Number)

4. Date and time initial telephonic report was made to Commission:

10.10.2023

(Date)

12:36

(Time)

5. Interruption or Outage:

(a) Number of customers affected:

1,905 Customers

(b) Approximate number of outage cases and trouble cases for each county affected during the event:

There was a single trouble location on Canal Street in Port Jervis, NY. A dead tree fell on the O&R subtransmission line serving PCLP's Matamoros Substation.

(c) Approximate number of outages for each county affected during the event:

Pike County: 1 outage

(d) Approximate number of outage cases exceeding 6 or more hours in duration:

No outage exceeded 6-hours

(e) A listing of each outage case exceeding 6 or more hours in duration, including the following information:

N/A

(f) Reason for the interruption or outages:

At approximately 14:00 on 10.09.2023 a dead tree came down on the O&R sub-transmission line serving PCLP's Matamoras Substation resulting in a complete loss of service to the substation.

(g) Projected time of restoration:

10.09.2023 14:30

(h) The number of utility workers, contract workers and workers received as mutual aid assigned specifically to the repair work by general function, that is linemen, troublemen, tree crew, and the like:

Utility/Company	# of Workers	General Function
PLC&P	4	Linemen
PLC&P	1	Planner
PLC&P	1	General Manager

(i) The date and time of the first information of a service interruption:

10.09.2023 14:00

(j) The date and time that repair crews were assembled:

10.09.2023 14:05

(k) The actual time that service was restored to the last affected customer:

10.09.2023 14:31

- (l) A general description of the physical damage sustained by the utility facilities as a result of the interruption/outage:

No damage

- (m) If the interruption / outage event was weather-related, the utility's weather reports, outlooks, or scenarios for the day before and the day of the interruption / outage event:

N/A

- (n) If the interruption / outage event caused approximate outages that exceed 10% or more of customers in the utility's entire service territory, rank the event in terms of the number and duration of outages and provide 2 comparable events, including the number and duration of outages for those comparable events:

Event and Rank	Event Date	Number of Outages	Duration of Outages
Tree Contractor - Rank 1	6/18/22	2,157	241 minutes
Downed wires - Rank 3	9/5/22	1,847	136 minutes
Tree on sub-transmission - Rank 2	10/9/23	1,905	31 minutes

Remarks:

 **H**awke
  **M**cKeon &
   **S**niscak LLP

Harrisburg Energy Center
100 North Tenth Street
Harrisburg, PA 17101



\$000.87⁰
10/17/2023 ZIP 17101
043M30246590

US PO

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor (filing room)
Harrisburg, PA 17120

1712030093 0000

