

# **EXHIBIT N2**



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2023  
 DMR Effective To: 08/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2023	08	01	FROM	2023	08	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.87	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.78	***	7.59	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 37.81	55.36	lbs/day	***	< 3.89	5.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	115.58	***	lbs/day	***	13.15	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	6.7	***	lbs/day	***	.68	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	5.4	***	lbs/day	***	.54	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	567	***	lbs/day	***	73.8	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .0948	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.202	2.455	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.12	.22	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	60	2420	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
	<b>Facility Parameter Comments</b>	Switched to new Rotameter for Chlorine gas injection. The new Rotameter is different than the older one we have. I was dialing it in where it needed to be and I just didn't have i high enough, thus causing the fecals to be high for that day. It is now dialed in and should not occur again.								
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 29.36	< 34.48	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2023  
 DMR Effective To: 08/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	08	01	TO	2023	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	998	1555	lbs/day	***	101	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1408	2272	lbs/day	***	144	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, August, 2023.pdf	Influent and Process Control Form	2023-09-14T09:20:56-04:00	
Sludge Report August 2023.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-09-14T09:21:43-04:00	
Effluent Monitoring Report, August, 2022.pdf	Daily Effluent Monitoring Form	2023-09-14T09:21:21-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
197150	08/01/2023	08/31/2023	Fecal Coliform	Instantaneous Maximum	2420	1000	No./100 ml	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
IMAX Fecal Violation occurred on 8/9/23. Switched to new Rotameter for Chlorine gas injection. The new Rotameter is different than the older one we have. I was dialing it in where it needed to be and I just didn't have it high enough, thus causing the fecals to be high for that day. It is now dialed in and should not occur again.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	09	14
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>		<b>001</b>				
PERMIT NUMBER		OUTFALL NUMBER				
MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2023	01	01	TO	2023	03	31

Reporting Frequency: Quarterly  
 DMR Effective From: 01/01/2023  
 DMR Effective To: 03/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	< .1009	***	lbs/day	***	< .002	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
	Facility Parameter Comments	Lab Report it in micro grams per liter. I convert it to mg/L. Lab result was 2.00 micrograms, 2.00/1000=0.002mg/L. The flow was very high on this sample day also.								
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	Facility Parameter Comments	We do one once a year. Will do later on this year. See Permit.								
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	Facility Parameter Comments	We do one once a year. Will do later on this year. See Permit.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	Facility Parameter Comments	We do one once a year. Will do later on this year. See Permit.								
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
1st Quarter Nickel Results, 1-4-23.pdf	Other	2023-02-06T09:08:33-05:00	Nickel Results 1/4/23
Effluent Monitoring Report, Jan. 2023.pdf	Daily Effluent Monitoring Form	2023-02-06T09:10:18-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	02	06
			SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 04/01/2023  
 DMR Effective To: 06/30/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2023	04	01	TO	2023	06 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0470	***	lbs/day	***	.00205	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
	<b>Facility Parameter Comments</b>	Lab reports it as micrograms. I convert it to mg/L								
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	1.79	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	PASS 1st round in April Passed Results are on the 2nd Quarter April 2023 EFF Monitoring Report Form I uploaded.								
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	1.79	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	This is passing result.. Retested during the days 5/22, 5/24, & 5/26/2023 Failed Water Flea Test in April. 1st round done in April. Failed Results are on the 2nd Quarter April 2023 EFF Monitoring Report Form I uploaded. Passed results are in the 2nd Quarter May 2023 EFF Monitoring Report Form.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	1.79	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	PASS 1st round done in April. Passed Results are on the 2nd Quarter April 2023 EFF Monitoring Report Form I uploaded.								
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
2nd Quarter April 2023 EFF Monitoring Report Form.pdf	Daily Effluent Monitoring Form	2023-06-28T10:57:07-04:00	Has results from April Wet Test & Nickel
2nd Quarter May 2023 EFF Monitoring Report Form .pdf	Daily Effluent Monitoring Form	2023-06-28T10:57:58-04:00	Has Results from Wet Test Retest
Wet Test Retest May 2023 Ceriodaphnia dubia.pdf	WET Test Summary Report	2023-06-28T11:01:50-04:00	Retested in May 2023 for Water Fleas & Passed.
Wet Test April 2023 pimephales promelas-PASS, Ceriodaphnia dubia-FAIL.pdf	WET Test Summary Report	2023-06-28T10:59:47-04:00	PASSED for the minnows FAILED for water fleas

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
We ran our annual Wet Test in April 2023 (4/17,4/19,4/21). The results showed we had passed the minnow portion, but failed the Water Flea portion. We retested for the Water Fleas in May 2023 (5/22,5/24,5/26). The results showed we passed the retest for water fleas. We now can continue to do annual Wet Testing.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon		(724)	813-1101	2023	06	28	
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>		<b>001</b>			
PERMIT NUMBER		OUTFALL NUMBER			
MONITORING PERIOD					
YEAR	MO	DAY	YEAR		
2023	07	01	2023		
FROM		TO			
2023	07	01	2023	09	
		DAY	30		

Reporting Frequency: Quarterly  
 DMR Effective From: 07/01/2023  
 DMR Effective To: 09/30/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE	
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nickel, Total (01067)	Sample Measurement	.0113	***	lbs/day	***	.00247	***	mg/L	1/quarter	24-Hr Composite	
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite	
	<b>Facility Parameter Comments</b>	Lab reports Nickel as micrograms/Liter, I convert it to mg/L by taking the lab's result and divide it by 1000 to get the Nickel in mg/L.									
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc			
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit	
	<b>Facility Parameter Comments</b>	Passed the 1st WET Test for the minnows. No more Testing is required for this year.									
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc			
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit	
	<b>Facility Parameter Comments</b>	We failed the 1st one. Passed the 2nd time. No more Testing is required for the year.									
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc			
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit	
	<b>Facility Parameter Comments</b>	Passed the 1st WET Test for the minnows. No more Testing is required for this year.									
<b>Facility Sampling Point Comments</b>											



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, July 2023.pdf	Daily Effluent Monitoring Form	2023-08-17T10:11:13-04:00	
3rd Quarter Nickel results 7-5-23.pdf	Other	2023-08-17T10:13:20-04:00	Lab results for Nickel 7/5/23

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	08	17
			SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2018  
 DMR Effective To: 08/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2018	08	01	FROM	2018	08	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.83	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.89	***	7.32	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	66.18	89.18	lbs/day	***	10.50	14.50	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	105.24	***	lbs/day	***	18.30	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	2.02	***	lbs/day	***	.31	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	4.57	***	lbs/day	***	.76	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	561.59	***	lbs/day	***	84.70	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.1570	***	lbs/day	***	<.0200	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.642	1.959	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.35	.49	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<2.22	48	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<27.79	45.21	lbs/day	***	<4.61	5.60	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2018  
 DMR Effective To: 08/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	08	01	TO	2018	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1594	5392	lbs/day	***	250.60	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2253	7483	lbs/day	***	341	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, August 2018.pdf	Daily Effluent Monitoring Form	2018-09-19T09:27:13-04:00	
Influent Monitoring Report, August 2018.pdf	Influent and Process Control Form	2018-09-19T09:29:48-04:00	
Sludge Report, August 2018.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2018-09-19T09:30:43-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
----------	---------------	-------------------------------	-------------------------

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2018	9	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2018  
 DMR Effective To: 09/30/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	09	01	TO	2018	09	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.40	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.82	***	7.47	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	<122	200	lbs/day	***	<10.0	15.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	138.94	***	lbs/day	***	15.27	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	7	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	6	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	462.80	***	lbs/day	***	82.70	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.26	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.890	9.586	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.46	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<3	1203	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<56	97	lbs/day	***	<4.3	5.2	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2018  
 DMR Effective To: 09/30/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2018	09	01	TO	2018	09	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1212	3307	lbs/day	***	113.40	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1067	3231	lbs/day	***	102	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, Sept. 2018.pdf	Daily Effluent Monitoring Form	2018-10-26T08:38:14-04:00	
Influent Monitoring Report, Sept. 2018.pdf	Influent and Process Control Form	2018-10-26T08:39:28-04:00	
Sludge Report, Sept. 2018.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2018-10-26T08:40:37-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
75279	09/01/2018	09/30/2018	Fecal Coliform	Instantaneous Maximum	1203	1000	No./100 ml	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
IMAX for Fecal Coliform exceeded because of heavy rain.	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2018	10	26
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2018  
 DMR Effective To: 10/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	10	01	TO	2018	10	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.61	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.92	***	7.60	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	<60	236	lbs/day	***	<6.7	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	136.10	***	lbs/day	***	16.10	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	6	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	7	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	699.44	***	lbs/day	***	76.80	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.22	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.117	2.784	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.33	.48	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<1.22	3	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<35	168	lbs/day	***	<3.7	6.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2018  
 DMR Effective To: 10/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2018	10	01	TO	2018	10 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1483	4559	lbs/day	***	173	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2002	6739	lbs/day	***	236	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, Oct. 2018.pdf	Daily Effluent Monitoring Form	2018-11-19T13:36:52-05:00	
Influent Monitoring Report, Oct. 2018.pdf	Influent and Process Control Form	2018-11-19T13:37:52-05:00	
Sludge Report, Oct. 2018.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2018-11-19T13:39:06-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2018	11	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2018  
 DMR Effective To: 11/30/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	11	01	TO	2018	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.19	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.03	***	7.48	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	200	244	lbs/day	***	10.3	14.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	109.73	***	lbs/day	***	10.70	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	22	***	lbs/day	***	1.1	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	14	***	lbs/day	***	.73	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	839.34	***	lbs/day	***	60.70	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.3278	***	lbs/day	***	<.0200	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.564	6.458	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.47	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<4	135	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<105	117	lbs/day	***	<5.1	5.8	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2018  
 DMR Effective To: 11/30/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	11	01	TO	2018	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1380	2337	lbs/day	***	79.61	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1268	4053	lbs/day	***	72.00	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, Nov. 2018.pdf	Daily Effluent Monitoring Form	2018-12-19T13:09:08-05:00	
Daily Influent Monitoring Report, Nov. 2018.pdf	Influent and Process Control Form	2018-12-19T13:10:37-05:00	
Sludge Report, Nov. 2018.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2018-12-19T13:11:56-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2018	12	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2018  
 DMR Effective To: 12/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2018	12	01	FROM	2018	12	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.54	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.02	***	7.82	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	124	218	lbs/day	***	7.8	9.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	205.63	***	lbs/day	***	13.80	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	27	***	lbs/day	***	1.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1372.75	***	lbs/day	***	75.40	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.27	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.940	4.322	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.30	.40	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<1	5	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	84	125	lbs/day	***	5.3	6.4	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2018  
 DMR Effective To: 12/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	12	01	TO	2018	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2139	5570	lbs/day	***	148.91	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2015	7427	lbs/day	***	131	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, Dec. 2018.pdf	Daily Effluent Monitoring Form	2019-01-10T08:59:41-05:00	
Daily Influent Monitoring Report, Dec. 2018.pdf	Influent and Process Control Form	2019-01-10T09:01:19-05:00	
Sludge Report, Dec. 2018.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-01-10T09:03:03-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Steven Vosler	T2520	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	1	10
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 07/01/2018  
 DMR Effective To: 09/30/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	07	01	TO	2018	09	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0011	***	lbs/day	***	.0001	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	<1.0	***	TUc	1/quarter	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	<1.0	***	TUc	1/quarter	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	<1.0	***	TUc	1/quarter	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Facility Comments										

**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Greenville WWTP WET Testing July 2018.pdf	Laboratory Analytical Report	2018-08-14T14:26:40-04:00	
Nickel Test Lab Results, July, 2018.pdf	Laboratory Analytical Report	2018-08-14T14:23:34-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Comments
-------------------	---------------------	----------------	-----------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2018	8	14
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 10/01/2018  
 DMR Effective To: 12/31/2018  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2018	10	01	TO	2018	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0091	***	lbs/day	***	.0010	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Facility Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Wet Test Summary Report, Oct. 2018.pdf	WET Test Summary Report	2018-12-19T14:02:41-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2018	12	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>			<b>001</b>			
PERMIT NUMBER			OUTFALL NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2019	01	01	TO	2019	01	31

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2019  
 DMR Effective To: 01/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.1	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.06	***	7.58	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	<200	354	lbs/day	***	<6.9	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	257.72	***	lbs/day	***	12.40	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	61	***	lbs/day	***	2.2	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	15	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1257.50	***	lbs/day	***	57.20	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.57	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.512	8.230	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.42	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<8.32	1011	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	174	452	lbs/day	***	6.1	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2019  
 DMR Effective To: 01/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2019	01	01	TO	2019	01 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	3059	14139	lbs/day	***	106	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3342	13728	lbs/day	***	120.56	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, Jan. 2019.pdf	Influent and Process Control Form	2019-02-18T13:35:41-05:00	
Supplemental Laboratory Accreditation Form, 2019.pdf	Laboratory Accreditation Form	2019-02-18T13:38:03-05:00	
Effluent Monitoring Report, Jan. 2019.pdf	Daily Effluent Monitoring Form	2019-02-18T13:34:43-05:00	
Sludge Report, Jan. 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-02-18T13:36:41-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
82190	02/08/2019	02/08/2019	02/08/2019 12:02:00	Sewage	Ohle St. Siphon	1080000(Est)	9	Shenango River	None Observed	Other	02/08/2019 12:02:00	Landslide took out sewer line.

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	2	18
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2019  
 DMR Effective To: 02/28/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	02	01	TO	2019	02	28

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.03	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.94	***	7.80	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	212	392	lbs/day	***	7.1	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	425	***	lbs/day	***	8	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	68	***	lbs/day	***	2.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12	***	lbs/day	***	.4	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	7480	***	lbs/day	***	139	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.75	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	3.313	9.30	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.32	.48	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<4	1733	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<195	290	lbs/day	***	<6.2	7.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2019  
 DMR Effective To: 02/28/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	02	01	TO	2019	02	28

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2968	9795	lbs/day	***	127	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2740	8310	lbs/day	***	111.3	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, Feb. 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-03-13T13:06:29-04:00	
Daily Effluent Monitoring Report, Feb. 2019.pdf	Daily Effluent Monitoring Form	2019-03-13T13:03:42-04:00	
Daily Influent Monitoring Report, Feb. 2019.pdf	Influent and Process Control Form	2019-03-13T13:05:13-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	3	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2019  
 DMR Effective To: 03/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	03	01	TO	2019	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.6	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.6	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	98	148	lbs/day	***	7.0	9.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	192	***	lbs/day	***	13.2	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	50	***	lbs/day	***	3.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	9	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1152	***	lbs/day	***	82.5	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.26	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.098	5.426	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.32	.48	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<2	365	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<69	88	lbs/day	***	<5.0	6.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2019  
 DMR Effective To: 03/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2019	03	01	TO	2019	03 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2077	3204	lbs/day	***	151	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2298	3462	lbs/day	***	168.89	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Eff. Monitoring Report, March, 2019.pdf	Daily Effluent Monitoring Form	2019-04-24T13:09:34-04:00	
Influent Monitoring Report, March, 2019.pdf	Influent and Process Control Form	2019-04-24T13:10:28-04:00	
Sludge Report, March, 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-04-24T13:11:20-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	4	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2019  
 DMR Effective To: 04/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	04	01	TO	2019	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.29	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.03	***	7.84	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	<90	97	lbs/day	***	<6.3	9.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	121.72	***	lbs/day	***	11.42	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	10	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1.044	***	lbs/day	***	75.70	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.24	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.973	4.947	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.45	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<3	9	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<70	79	lbs/day	***	<4.7	6.2	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2019  
 DMR Effective To: 04/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	04	01	TO	2019	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1984	4250	lbs/day	***	134	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2355	6519	lbs/day	***	149.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, April 2019.pdf	Daily Effluent Monitoring Form	2019-05-24T14:33:59-04:00	
Daily Influent Monitoring Report, April 2019.pdf	Influent and Process Control Form	2019-05-24T14:35:23-04:00	
Sludge Report, April 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-05-24T14:36:23-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	5	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2019  
 DMR Effective To: 05/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	05	01	TO	2019	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.55	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.99	***	7.51	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	<93	272	lbs/day	***	<7.2	18.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	132.29	***	lbs/day	***	9.39	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	7	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	11	***	lbs/day	***	.9	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1373.77	***	lbs/day	***	66.50	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.2366	***	lbs/day	***	<.0200	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.525	3.018	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.32	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<2	18	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<53	89	lbs/day	***	<3.9	4.7	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2019  
 DMR Effective To: 05/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	05	01	TO	2019	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1812	3205	lbs/day	***	152	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2300	5657	lbs/day	***	190.20	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, May 2019.pdf	Daily Effluent Monitoring Form	2019-06-21T09:32:46-04:00	
Daily Influent Monitoring Report, May 2019 (2).pdf	Influent and Process Control Form	2019-06-21T09:34:08-04:00	
Sludge Report, May 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-06-21T09:35:06-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	6	21
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2019  
 DMR Effective To: 06/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	06	01	TO	2019	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.2	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.9	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	235	591	lbs/day	***	7.0	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	515.91	***	lbs/day	***	8.98	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	18	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12	***	lbs/day	***	.4	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	7036.40	***	lbs/day	***	71.30	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.80	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Copper limit exceeded because of a torrential rainfall of 4 in./hr. causing an extremely high flow of 11.833 mgd on a sample day which caused the lbs/day to be very high.								
Flow (50050)	Sample Measurement	3684	11833	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.33	.5	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<4	153	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<114	<207	lbs/day	***	<4.0	4.4	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2019  
 DMR Effective To: 06/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	06	01	TO	2019	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1879	6809	lbs/day	***	62	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2359	7105	lbs/day	***	87	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, June 2019.pdf	Influent and Process Control Form	2019-07-19T09:54:14-04:00	
Sludge Report, June 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-07-19T09:57:17-04:00	
Daily Effluent Monitoring Report, June 2019.pdf	Daily Effluent Monitoring Form	2019-07-19T09:53:02-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
91537	06/01/2019	06/30/2019	Copper, Total	Average Monthly	<.8	.76	lbs/day	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Copper lb/day limit exceeded because of an extremely high flow on that sample day.	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	7	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2019  
 DMR Effective To: 07/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	07	01	TO	2019	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.52	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.98	***	7.45	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	225	361	lbs/day	***	11.3	13.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	168.64	***	lbs/day	***	11.09	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	18	***	lbs/day	***	.9	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	13	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1468.04	***	lbs/day	***	88.10	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.38	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.240	5.799	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.33	.6	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<3	18	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<68	<97	lbs/day	***	<3.5	<4.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2019  
 DMR Effective To: 07/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	07	01	TO	2019	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2045	4555	lbs/day	***	116	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3260	11061	lbs/day	***	167	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, July 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-08-22T14:19:59-04:00	
Daily Influent Monitoring Report, July 2019.pdf	Influent and Process Control Form	2019-08-22T14:18:46-04:00	
Daily Effluent Monitoring Report, July 2019.pdf	Daily Effluent Monitoring Form	2019-08-22T14:17:27-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	8	22
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2019  
 DMR Effective To: 08/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	08	01	TO	2019	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.18	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.81	***	7.45	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	112	203	lbs/day	***	9.4	14.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	176.16	***	lbs/day	***	13.75	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	9	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	713.42	***	lbs/day	***	64.70	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.30	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.384	3.469	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.29	.46	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<1.49	9	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<40	<65	lbs/day	***	<3.3	<4.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2019  
 DMR Effective To: 08/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	08	01	TO	2019	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1404	2336	lbs/day	***	134	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1697	3101	lbs/day	***	153	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, August 2019.pdf	Influent and Process Control Form	2019-09-12T13:11:22-04:00	
Sludge Report, August 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-09-12T13:12:17-04:00	
Daily Effluent Monitoring Report, August 2019.pdf	Daily Effluent Monitoring Form	2019-09-12T13:10:24-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	9	12
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2019  
 DMR Effective To: 09/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	09	01	TO	2019	09	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.16	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.94	***	7.57	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	<92	173	lbs/day	***	<9.0	17.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	160.41	***	lbs/day	***	12.55	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	5	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	613.03	***	lbs/day	***	66.40	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.20	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.294	3.278	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.30	.49	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<3	30	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<35	<64	lbs/day	***	<3.1	<3.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2019  
 DMR Effective To: 09/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2019	09	01	TO	2019	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1614	5056	lbs/day	***	141	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3711	20101	lbs/day	***	275	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, Sept. 2019.pdf	Daily Effluent Monitoring Form	2019-10-09T13:49:09-04:00	
Influent Monitoring Report, Sept. 2019.pdf	Influent and Process Control Form	2019-10-09T13:50:20-04:00	
Sludge Report, Sept. 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-10-09T13:51:15-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	10	9
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2019  
 DMR Effective To: 10/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2019	10	01	FROM	2019	10	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.3	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.6	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	90	630	lbs/day	***	10.4	24.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	144.83	***	lbs/day	***	18.90	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	5	***	lbs/day	***	.54	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	7	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	738.56	***	lbs/day	***	84.50	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.22	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.273	7.424	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.45	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<3	6	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<27	122	lbs/day	***	<3.1	4.8	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2019  
 DMR Effective To: 10/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2019	10	01	TO	2019	10 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1046	2491	lbs/day	***	114	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	930	1564	lbs/day	***	104	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, Oct. 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-11-19T08:54:26-05:00	
Effluent Monitoring Report, Oct. 2019.pdf	Daily Effluent Monitoring Form	2019-11-19T08:52:04-05:00	
Influent Monitoring Report, Oct. 2019.pdf	Influent and Process Control Form	2019-11-19T08:53:18-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	11	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2019  
 DMR Effective To: 11/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	11	01	TO	2019	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.2	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	221	145	lbs/day	***	12.8	13.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	177.74	***	lbs/day	***	14.55	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	13	***	lbs/day	***	1.0	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	9	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	796.09	***	lbs/day	***	64.80	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.23	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.484	3.713	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.35	.51	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<2	10	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<52	<36	lbs/day	***	<3.4	<3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2019  
 DMR Effective To: 11/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	11	01	TO	2019	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2103	2822	lbs/day	***	178	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	4963	9519	lbs/day	***	419	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, Nov. 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2019-12-13T08:37:27-05:00	
Influent Monitoring Report, Nov. 2019.pdf	Influent and Process Control Form	2019-12-13T08:36:15-05:00	
Daily Effluent Monitoring Report, Nov. 2019.pdf	Daily Effluent Monitoring Form	2019-12-13T08:34:51-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	12	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2019  
 DMR Effective To: 12/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2019	12	01	FROM	2019	12	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.8	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.81	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	161	184	lbs/day	***	9.0	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	204.90	***	lbs/day	***	10.21	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610)	Sample Measurement	22	***	lbs/day	***	1.2	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1198.83	***	lbs/day	***	67.90	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	<.34	***	lbs/day	***	<.020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.447	5.799	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055)	Sample Measurement	***	***	***	***	<6	1300	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	Sample Measurement	<58	<88	lbs/day	***	<3.3	<3.9	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2019  
 DMR Effective To: 12/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	12	01	TO	2019	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1770	2681	lbs/day	***	118	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2854	8828	lbs/day	***	165	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, Dec. 2020.pdf	Daily Effluent Monitoring Form	2020-01-16T14:30:29-05:00	
Influent Monitoring Report, Dec., 2020.pdf	Influent and Process Control Form	2020-01-16T14:28:58-05:00	
Sludge Report, Dec. 2019.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-01-16T14:31:37-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William Harry Jamison	S-7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	1	16
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 01/01/2019  
 DMR Effective To: 03/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2019	01	01	TO	2019	03 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0220	***	lbs/day	***	.0010	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
WET Test Summary Report, 1st quarter 2019, 4-22-19.pdf	WET Test Summary Report	2019-04-24T13:19:15-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	4	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 04/01/2019  
 DMR Effective To: 06/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2019	04	01	TO	2019	06 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0124	***	lbs/day	***	.0009	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
-----------	-----------------	---------------	---------------------

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	7	2
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 07/01/2019  
 DMR Effective To: 09/30/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2019	07	01	TO	2019	09	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0333	***	lbs/day	***	.002	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
-----------	-----------------	---------------	---------------------

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	10	10
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>				
PERMIT NUMBER	OUTFALL NUMBER				
<b>MONITORING PERIOD</b>					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 2019	10	01	TO 2019	12	31

Reporting Frequency: Quarterly  
 DMR Effective From: 10/01/2019  
 DMR Effective To: 12/31/2019  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.02	***	lbs/day	***	.002	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
-----------	-----------------	---------------	---------------------

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2019	11	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2020  
 DMR Effective To: 01/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	01	01	TO	2020	01	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.6	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.1	***	7.8	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 115	215	lbs/day	***	< 4.7	8.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	173.37	***	lbs/day	***	10.12	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	37	***	lbs/day	***	1.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	11	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1063.49	***	lbs/day	***	65.90	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .39	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.870	4.898	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.34	.5	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 3	20	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 79	113	lbs/day	***	< 3.4	4.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2020  
 DMR Effective To: 01/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2020	01	01	TO	2020	01 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2154	3724	lbs/day	***	98	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2683	5229	lbs/day	***	116	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Supplemental Laboratory Accreditation Form, 2020.pdf	Laboratory Accreditation Form	2020-02-14T13:29:37-05:00	
Influent Monitoring Report, Jan. 2020.pdf	Influent and Process Control Form	2020-02-14T13:31:03-05:00	
Effluent Monitoring Report Jan. 2020.pdf	Daily Effluent Monitoring Form	2020-02-14T13:32:09-05:00	
Sludge Report Jan. 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-02-14T13:33:46-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	02	14
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2020  
 DMR Effective To: 02/29/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	02	01	TO	2020	02	29

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	8.0	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.9	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	162	194	lbs/day	***	8.3	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	186.70	***	lbs/day	***	9.00	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	24	***	lbs/day	***	1.2	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1523.49	***	lbs/day	***	82.10	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .41	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.410	4.633	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.31	.41	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 6.92	1986	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 67	< 87	lbs/day	***	< 3.4	< 4.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2020  
 DMR Effective To: 02/29/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	02	01	TO	2020	02	29

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1413	3629	lbs/day	***	72	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1877	5747	lbs/day	***	94	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, Feb. 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-03-25T13:01:51-04:00	
Daily Effluent Monitoring Report, Feb. 2020.pdf	Daily Effluent Monitoring Form	2020-03-25T12:59:34-04:00	
Daily Influent Monitoring Report, Feb. 2020.pdf	Influent and Process Control Form	2020-03-25T13:00:55-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	03	25
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY

3800-FM-BCW0462 12/2016



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
FACILITY: GREENVILLE SANI AUTH  
LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
DMR Effective From: 03/01/2020  
DMR Effective To: 03/31/2020  
Permit Expires: 12/31/2022  
Permit Application Due: 07/04/2022  
No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2020	03	01	2020	03	31

PARAMETERS REPORTED VALUES

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.6	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***	***	4.0 Inst Min	***	***	***	1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.8	S.U.	1/day	Grab
	Permit Requirement	***	***	***	6.0 Inst Min	***	8.0 IMAX	***	1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 168	< 388	lbs/day	***	< 6.5	8.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	100 Avg Mo	1500 Wkly Avg	***	***	30.0 Avg Mo	45.0 Wkly Avg	***	2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	217.08	***	lbs/day	***	10.55	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***	***	***	Monitor & Report Avg Mo	***	***	2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	31	***	lbs/day	***	1.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***	***	***	21.0 Avg Mo	***	***	2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	15	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***	***	***	1.0 Avg Mo	***	***	2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	2496.13	***	lbs/day	***	94.00	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***	***	***	Monitor & Report Avg Mo	***	***	1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .44	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.78 Avg Mo	***	***	***	.023 Avg Mo	***	***	1/week	24-Hr Composite
Flow (50050)	Sample Measurement	3.019	11.061	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max	***	***	***	***	***	Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.29	.45	mg/L	1/day	Grab
	Permit Requirement	***	***	***	***	.37 Avg Mo	1.2 IMAX	***	1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 6	345	No./100 ml	2/week	Grab
	Permit Requirement	***	***	***	***	2000 Geo Mean	10000 IMAX	***	2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 96	< 139	lbs/day	***	< 4.2	5.7	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg	***	***	25.0 Avg Mo	40.0 Wkly Avg	***	2/week	24-Hr Composite
Facility Sampling Point Comments										

3800-FM-BCW0462 12/2016



COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF CLEAN WATER  
 DISCHARGE MONITORING REPORT (DMR)

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2020  
 DMR Effective To: 03/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
2020	03	01		2020	03	31

PARAMETERS REPORTED VALUES

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	< 2440	7956	lbs/day	***	< 109	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3074	10279	lbs/day	***	135	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										

3800-FM-BCW0462 12/2016



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, March 2020.pdf	Daily Effluent Monitoring Form	2020-04-14T09:22:45-04:00	
Influent Monitoring Report, March 2020.pdf	Influent and Process Control Form	2020-04-14T09:31:33-04:00	
Sludge Report, March, 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-04-14T09:34:48-04:00	

PERMIT VIOLATIONS

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

UNAUTHORIZED DISCHARGES

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

OTHER PERMIT VIOLATIONS

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

COMMENT DETAILS

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	57240	(724)-588-2036

SUBMISSION INFORMATION

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	SUBMITTED BY FULL NAME	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
jamisonw		William Jamison	(724)	588-2036	2020	04	14



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2020  
 DMR Effective To: 04/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	04	01	TO	2020	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.98	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.97	***	7.85	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	135	259	lbs/day	***	7.8	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	137	***	lbs/day	***	9.34	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	9	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	11	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1559	***	lbs/day	***	71	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .35	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.913	4.481	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.28	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 7.27	205	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 52	< 106	lbs/day	***	< 3.1	< 4.2	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2020  
 DMR Effective To: 04/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	04	01	TO	2020	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	3393	12376	lbs/day	***	210	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	5261	17164	lbs/day	***	356	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Report, April 2020.pdf	Influent and Process Control Form	2020-05-15T09:09:19-04:00	
Daily Effluent Monitoring Report, April 2020.pdf	Daily Effluent Monitoring Form	2020-05-15T09:06:03-04:00	
Sludge Report, April 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-05-15T09:12:27-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	05	15
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2020  
 DMR Effective To: 05/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	05	01	TO	2020	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.2	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.9	***	7.65	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 177	324	lbs/day	***	< 13.4	28.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	130.61	***	lbs/day	***	14.75	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	15	***	lbs/day	***	1.0	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	13	***	lbs/day	***	.88	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	851.93	***	lbs/day	***	75.00	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .17	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.417	3.150	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.29	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 1.61	3	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 70	98	lbs/day	***	< 5.0	8.6	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2020  
 DMR Effective To: 05/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	05	01	TO	2020	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1371	3126	lbs/day	***	99	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1854	4519	lbs/day	***	141	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, May 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-06-23T09:36:43-04:00	
Daily Influent Monitoring Report, May 2020.pdf	Influent and Process Control Form	2020-06-23T09:32:35-04:00	
Daily Effluent Monitoring Report, May 2020.pdf	Daily Effluent Monitoring Form	2020-06-23T09:29:39-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	06	23
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2020  
 DMR Effective To: 06/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	06	01	TO	2020	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.3	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.12	***	7.61	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 49	79	lbs/day	***	< 6.2	< 10.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	171.62	***	lbs/day	***	15.80	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	6	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	7	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	684.73	***	lbs/day	***	75.60	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .17	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.955	1.757	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.28	.56	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 1	1	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	25	31	lbs/day	***	3.1	10.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2020  
 DMR Effective To: 06/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	06	01	TO	2020	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1227	2302	lbs/day	***	149	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2124	3624	lbs/day	***	262	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, June 2020.pdf	Daily Effluent Monitoring Form	2020-07-13T13:16:42-04:00	
Daily Influent Monitoring Report, June 2020.pdf	Influent and Process Control Form	2020-07-13T13:20:03-04:00	
Sludge Report, June 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-07-13T13:23:28-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	07	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2020  
 DMR Effective To: 07/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2020	07	01	FROM	2020	07	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.0	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.9	***	7.6	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 58	92	lbs/day	***	< 8.7	13.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	120.17	***	lbs/day	***	22.94	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	4	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	5	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	383.95	***	lbs/day	***	83.10	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .14	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.869	1.542	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.27	.5	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 2	58	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 22	26	lbs/day	***	< 3.3	4.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2020  
 DMR Effective To: 07/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	07	01	TO	2020	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1159	1685	lbs/day	***	174	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1854	2908	lbs/day	***	267	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, July 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-08-17T14:19:42-04:00	
Daily Influent Monitoring Report, July 2020.pdf	Influent and Process Control Form	2020-08-17T14:16:45-04:00	
Daily Effluent Monitoring Report, July 2020.pdf	Daily Effluent Monitoring Form	2020-08-17T14:13:36-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	08	17
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
FACILITY: GREENVILLE SANI AUTH  
LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
DMR Effective From: 09/01/2020  
DMR Effective To: 09/30/2020  
Permit Expires: 12/31/2022  
Permit Application Due: 07/04/2022  
No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
2020	09	01	TO	2020	09	30

PARAMETERS REPORTED VALUES

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	4.9	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***	***	4.0	Inst Min	***	***	1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.1	***	7.9	S.U.	1/day	Grab
	Permit Requirement	***	***	***	6.0	Inst Min	9.0	IMAX	1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 89	126	lbs/day	***	< 8.1	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1003	1500	Wkly Avg	***	30.0	45.0	Avg Mo	2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	240.65	***	lbs/day	***	14.50	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report	***	***	***	Monitor & Report	***	Avg Mo	2/month	24-Hr Composite
Ammonia-Nitrogen (00810) (May-Oct)	Sample Measurement	5	***	lbs/day	***	5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233	***	***	***	7.0	***	Avg Mo	2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8	***	lbs/day	***	8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33	***	***	***	1.0	***	Avg Mo	2/week	24-Hr Composite
Chloride (00340)	Sample Measurement	1610.79	***	lbs/day	***	72.50	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report	***	***	***	Monitor & Report	***	Avg Mo	1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< 25	***	lbs/day	***	< 0.20	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	78	***	***	***	0.23	***	Avg Mo	1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.342	3.642	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report	Monitor & Report	Daily Max	***	***	***	***	Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	30	5	mg/L	1/day	Grab
	Permit Requirement	***	***	***	***	37	1.2	Avg Mo	1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 3	488	No./100 ml	2/week	Grab
	Permit Requirement	***	***	***	***	200	1000	Geo Mean	2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 31	< 47	lbs/day	***	< 3.0	< 3.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	667	1000	Wkly Avg	***	20.0	30.0	Avg Mo	2/week	24-Hr Composite
Facility Sampling Point Comments										



COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF CLEAN WATER  
 DISCHARGE MONITORING REPORT (DMR)

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
2020	09	01	TO	2020	09	30	

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2020  
 DMR Effective To: 09/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

PARAMETERS REPORTED VALUES

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1247	4266	lbs/day	***	111	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1930	6532	lbs/day	***	170	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2020  
 DMR Effective To: 09/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2020	09	01	TO	2020	09	30

PARAMETERS REPORTED VALUES

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	4.9	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***	***	4.0	Inst Min	***	***	1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.1	***	7.9	S.U.	1/day	Grab
	Permit Requirement	***	***	***	6.0	Inst Min	9.0	IMAX	1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 89	126	lbs/day	***	< 8.1	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000	1500	Wkly Avg	***	36.0	45.0	Wkly Avg	2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	240.65	***	lbs/day	***	14.50	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report	***	***	***	Monitor & Report	***	***	2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	5	***	lbs/day	***	5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233	***	***	***	7.0	***	***	2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8	***	lbs/day	***	8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33	***	***	***	1.0	***	***	2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1610.79	***	lbs/day	***	72.50	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report	***	***	***	Monitor & Report	***	***	1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .25	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	76	***	***	***	.023	***	***	1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.342	3.642	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report	Monitor & Report	Daily Max	***	***	***	***	Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	30	5	mg/L	1/day	Grab
	Permit Requirement	***	***	***	***	37	1.2	IMAX	1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 3	488	No./100 ml	2/week	Grab
	Permit Requirement	***	***	***	***	200	1000	IMAX	2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 31	< 47	lbs/day	***	< 3.0	< 3.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	667	1000	Wkly Avg	***	20.0	30.0	Wkly Avg	2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2020  
 DMR Effective To: 10/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	10	01	TO	2020	10	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.06	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.99	***	8.01	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	167	331	lbs/day	***	13.3	17.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	153.92	***	lbs/day	***	20.15	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	10	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	577.72	***	lbs/day	***	81.40	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .27	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.687	7.526	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.33	.55	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 6	292	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 57	< 135	lbs/day	***	< 3.5	< 5.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2020  
 DMR Effective To: 10/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	10	01	TO	2020	10	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2439	7357	lbs/day	***	160	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3258	8907	lbs/day	***	222	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, Oct. 2020.pdf	Influent and Process Control Form	2020-11-17T13:36:30-05:00	
Sludge Report, Oct. 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-11-17T13:44:07-05:00	
Daily Effluent Monitoring Report, Oct. 2020.pdf	Daily Effluent Monitoring Form	2020-11-17T13:40:40-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	11	17
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2020  
 DMR Effective To: 10/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	10	01	TO	2020	10	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.06	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.99	***	8.01	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	167	331	lbs/day	***	13.3	17.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	153.92	***	lbs/day	***	20.15	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	10	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	577.72	***	lbs/day	***	81.40	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .27	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.687	7.526	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.33	.55	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 6	292	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 57	< 135	lbs/day	***	< 3.5	< 5.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2020  
 DMR Effective To: 10/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	10	01	TO	2020	10	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2439	7357	lbs/day	***	160	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3258	8907	lbs/day	***	222	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, Oct. 2020.pdf	Influent and Process Control Form	2020-11-17T13:36:30-05:00	
Sludge Report, Oct. 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-11-17T13:44:07-05:00	
Daily Effluent Monitoring Report, Oct. 2020.pdf	Daily Effluent Monitoring Form	2020-11-17T13:40:40-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	11	17
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2020  
 DMR Effective To: 11/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
FROM	2020	11	01	TO	2020	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.57	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.79	***	7.74	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 137	< 153	lbs/day	***	< 10.4	12.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	175.59	***	lbs/day	***	13.13	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	11	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	7	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	927.28	***	lbs/day	***	66.30	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .31	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1,919	4,542	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.29	.5	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 3	18	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 43	< 65	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367  
 PERMIT NUMBER

001  
 OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2020  
 DMR Effective To: 11/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	11	01	TO	2020	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2303	3411	lbs/day	***	179	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2845	4791	lbs/day	***	226	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, Nov. 2020.pdf	Influent and Process Control Form	2020-12-16T13:08:46-05:00	
Daily Effluent Monitoring Report, Nov. 2020.pdf	Daily Effluent Monitoring Form	2020-12-16T13:05:45-05:00	
Sludge Report, Nov. 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2020-12-16T13:12:23-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
132949	11/04/2020	11/12/2020	03/04/2021 11:03:00	Sewage	Saul Run	22400(Est)	192(Est)	Saul Run Stream	Solids Deposition	Other	11/04/2020 11:11:00	Fractured sewer line caused by storm wash out of stream bank.

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
I submitted this on non-compliance report on the Oct. 2020 DMR by mistake and have since deleted it as it should have went into Nov. 2020s report and I am revising now. I had forgotten to report it as a SSO on the original report and I am trying to get it reported by this revision now.	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER  jamisonw	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
			(724)	588-2036	2021	03	09
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2020  
 DMR Effective To: 12/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	12	01	TO	2020	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.4	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.92	***	7.93	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 153	< 208	lbs/day	***	< 6.6	< 9.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	184	***	lbs/day	***	8	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	20	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	14	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1945	***	lbs/day	***	69	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .49	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.758	4.802	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.29	.45	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.37 Avg Mo	1.2 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 6	99	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 79	< 133	lbs/day	***	< 3.2	< 4.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2020  
 DMR Effective To: 12/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2020	12	01	TO	2020	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	3323	6488	lbs/day	***	173	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	5164	9604	lbs/day	***	269	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, Dec. 2020.pdf	Influent and Process Control Form	2021-01-27T09:42:40-05:00	
Daily Effluent Monitoring Report, Dec. 2020.pdf	Daily Effluent Monitoring Form	2021-01-27T09:46:13-05:00	
Sludge Report, Dec. 2020.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-01-27T09:50:44-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2021	01	27
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>			<b>001</b>			
PERMIT NUMBER			OUTFALL NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2020	01	01	TO	2020	03	31

Reporting Frequency: Quarterly  
 DMR Effective From: 01/01/2020  
 DMR Effective To: 03/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0145	***	lbs/day	***	.0009	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	1.8	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	1.8	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
WETT Test Summary Report, March, 2020.pdf	WET Test Summary Report	2020-03-25T12:39:45-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	03	25
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 04/01/2020  
 DMR Effective To: 06/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2020	04	01	TO	2020	06 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0154	***	lbs/day	***	.0007	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Official Wet Test DMR, 1st Quarter, 2020.pdf	WET Test Summary Report	2020-07-13T12:54:17-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(725)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	07	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 07/01/2020  
 DMR Effective To: 09/30/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2020	07	01	TO	2020	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0046	***	lbs/day	***	.0010	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Nickel Lab results, 7-8-20.pdf	Laboratory Analytical Report	2020-08-26T12:54:31-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
jamisonw			(724)	588-2036	2020	08	26
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 10/01/2020  
 DMR Effective To: 12/31/2020  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2020	10	01	TO	2020	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0213	***	lbs/day	***	.0030	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Nickel Test Results, 10-7-20.pdf	Laboratory Analytical Report	2020-11-17T14:05:16-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William H. Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
			(724)	588-2036	2020	11	17
jamisonw		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2021  
 DMR Effective To: 01/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 2021	01	01	TO 2021	01	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.9	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.07	***	7.97	S.U.	1/day	Grab
	Permit Requirement	***	***		8.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	167	253	lbs/day	***	9.9	11.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	203.11	***	lbs/day	***	10.93	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	17	***	lbs/day	***	1.0	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1556.87	***	lbs/day	***	65.50	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .36	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.372	7.369	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.32	.62	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 1	1	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 51	< 69	lbs/day	***	< 3.1	< 3.2	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2021  
 DMR Effective To: 01/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	01	01	TO	2021	01	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	3786	7220	lbs/day	***	245	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	6111	9388	lbs/day	***	392	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Analysis Report & C.O.C. for landfill recertification, 2-9-21.pdf	Laboratory Analytical Report	2021-02-18T14:16:56-05:00	
Sludge Report, Jan. 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-02-18T14:15:26-05:00	
Supplemental Laboratory Accreditation Form, Greenville WWTP, 2021.pdf	Laboratory Accreditation Form	2021-02-18T14:16:43-05:00	
Effluent Monitoring Report, Jan. 2021.pdf	Daily Effluent Monitoring Form	2021-02-18T14:12:55-05:00	
Influent Monitoring Report, Jan. 2021.pdf	Influent and Process Control Form	2021-02-18T14:13:59-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
131738	01/01/2021	01/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.32	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Unable to meet new chlorine limit restrictions with equipment provided.	Steven Vosler	T2520	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Steven Vosler	TELEPHONE		DATE		
			(724)	456-3240	2021	02	18
voslerst		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2021  
 DMR Effective To: 02/28/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
2021	02	01		2021	02	28

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.6	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.7	***	7.9	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	145	205	lbs/day	***	9.3	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	212	***	lbs/day	***	15.7	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	25	***	lbs/day	***	1.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	11	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1781	***	lbs/day	***	130	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .31	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1,827	3,746	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.57	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Facility Parameter Comments	Can not make monthly average limit with equipment provided. A consent order has been issued using our 537 Plan as our corrective action until our project is completed.									
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 9	1986	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 53	87	lbs/day	***	< 3.3	4.2	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2021  
 DMR Effective To: 02/28/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	02	01	TO	2021	02	28

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	8321	23393	lbs/day	***	537	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	13826	40487	lbs/day	***	884	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, Feb. 2021.pdf	Daily Effluent Monitoring Form	2021-03-12T13:24:00-05:00	
Sludge Report, Feb. 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-03-12T13:37:20-05:00	
Influent Monitoring Report, Feb. 2021.pdf	Influent and Process Control Form	2021-03-12T13:34:46-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
133323	02/01/2021	02/28/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Unable to meet monthly average limit for Chlorine Residual with equipment provided. A consent order has been issued letting us use our 537 plan as our corrective action.	William Harry Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	William Jamison	TELEPHONE		DATE		
			(724)	588-2036	2021	03	12
jamisonw		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2021  
 DMR Effective To: 03/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	03	01	TO	2021	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.3	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.9	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	100	122	lbs/day	***	7.4	8.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	277.15	***	lbs/day	***	19.17	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	14	***	lbs/day	***	1.0	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	11	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	2220.53	***	lbs/day	***	125	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .27	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1,633	3,251	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.40	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Facility Parameter Comments		Unable to meet monthly average permit restriction with current equipment provided.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	<2	102	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	<43	64	lbs/day	***	< 3.2	3.7	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2021  
 DMR Effective To: 03/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2021	03	01	TO	2021	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	4525	7720	lbs/day	***	365	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	5389	10322	lbs/day	***	437	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, March 2021.pdf	Influent and Process Control Form	2021-04-15T13:04:08-04:00	
Sludge Report, March 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-04-15T13:05:22-04:00	
Daily Effluent Monitoring Report, March 2021.pdf	Daily Effluent Monitoring Form	2021-04-15T13:03:03-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
135207	03/01/2021	03/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Unable to meet monthly average Chlorine Residue permit limits with equipment provided.	William Harry Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Bill Jamison	TELEPHONE		DATE		
			(724)	866-9338	2021	04	15
jamisonw		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2021  
 DMR Effective To: 03/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	03	01	TO	2021	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.3	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.9	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	100	122	lbs/day	***	7.4	8.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00500)	Sample Measurement	277.15	***	lbs/day	***	19.17	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	14	***	lbs/day	***	1.0	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	11	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	2220.53	***	lbs/day	***	125	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .27	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1,633	3,251	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.40	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	62 IMAX		1/day	Grab
Facility Parameter Comments		Unable to meet monthly average permit restriction with current equipment provided.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	<2	102	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	<43	64	lbs/day	***	< 3.2	3.7	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2021  
 DMR Effective To: 03/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	03	01	TO	2021	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	4525	7720	lbs/day	***	365	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	5389	10322	lbs/day	***	437	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF CLEAN WATER  
 DISCHARGE MONITORING REPORT (DMR)

ATTACHMENT DETAILS

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Influent Monitoring Report, March 2021.pdf	Influent and Process Control Form	2021-04-15T13:04:08-04:00	
Sludge Report, March 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-04-15T13:05:22-04:00	
Daily Effluent Monitoring Report, March 2021.pdf	Daily Effluent Monitoring Form	2021-04-15T13:03:03-04:00	

PERMIT VIOLATIONS

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
135207	03/01/2021	03/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

UNAUTHORIZED DISCHARGES

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

OTHER PERMIT VIOLATIONS

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments

COMMENT DETAILS

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Unable to meet monthly average Chlorine Residue permit limits with equipment provided.	William Harry Jamison	S7240	(724)-588-2036

SUBMISSION INFORMATION

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Bill Jamison	TELEPHONE		DATE		
			(724)	866-9338	2021	04	15
jamisonw		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2021  
 DMR Effective To: 04/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
2021	04	01	TO	2021	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.9	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	8.1	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	122	176	lbs/day	***	9.6	16.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	163.96	***	lbs/day	***	16.31	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	8	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	13	***	lbs/day	***	1.1	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	890.41	***	lbs/day	***	84.80	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .2112	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1,460	4,373	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.24	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 1	6	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 51	< 112	lbs/day	***	< 3.7	< 6.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2021  
 DMR Effective To: 04/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2021	04	01	TO	2021	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	4568	11025	lbs/day	***	416	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	6219	19635	lbs/day	***	572	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										


PARAMETER	VALUE	UNITS	PERCENT	PERMIT	PERCENT	PERMIT	PERCENT	PERMIT	PERCENT	PERMIT
BOD5	4568	lbs/day	11025	***	416	mg/L	***	2/week	24-Hr Composite	
TSS	6219	lbs/day	19635	***	572	mg/L	***	2/week	24-Hr Composite	

DATE: \_\_\_\_\_  
 FACILITY: \_\_\_\_\_  
 SPECIAL: \_\_\_\_\_  
 LOCATION: \_\_\_\_\_  
 STAGE: \_\_\_\_\_

BY: \_\_\_\_\_  
 TITLE: \_\_\_\_\_

DATE: \_\_\_\_\_  
 FACILITY: \_\_\_\_\_  
 SPECIAL: \_\_\_\_\_  
 LOCATION: \_\_\_\_\_  
 STAGE: \_\_\_\_\_

BY: \_\_\_\_\_  
 TITLE: \_\_\_\_\_





**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, April 2021.pdf	Daily Effluent Monitoring Form	2021-05-26T09:21:08-04:00	
Influent Monitoring Report, April 2021.pdf	Influent and Process Control Form	2021-05-26T09:22:36-04:00	
Sludge Report, April 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-05-26T09:23:50-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
138015	04/01/2021	04/30/2021	Total Residual Chlorine (TRC)	Average Monthly	.24	.19	mg/L	Final Effluent (001)	Other	None taken	Unable to meet new permit restriction with equipment provided.
138016	04/01/2021	04/30/2021	Total Phosphorus	Average Monthly	1.1	1	mg/L	Final Effluent (001)	Insufficient/overdose chemical feed	Increased chemical feed	Received lab results to late to correct. Adjusted after results received. Problem corrected.

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William Harry Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Steven Vosler	TELEPHONE		DATE		
			(724)	588-2036	2021	05	26
voslerst		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

PA0027367	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2021  
 DMR Effective To: 04/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
2021	04	01	TO	2021	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.9	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***	***	4.0 Inst Min	***	***	***	1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	8.1	S.U.	1/day	Grab
	Permit Requirement	***	***	***	6.0 Inst Min	***	9.0 IMAX	***	1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	122	176	lbs/day	***	9.6	16.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg	***	***	30.0 Avg Mo	45.0 Wkly Avg	***	2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	163.96	***	lbs/day	***	16.31	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***	***	***	Monitor & Report Avg Mo	***	***	2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	8	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***	***	***	21.0 Avg Mo	***	***	2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	13	***	lbs/day	***	1.1	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***	***	***	1.0 Avg Mo	***	***	2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	890.41	***	lbs/day	***	84.80	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***	***	***	Monitor & Report Avg Mo	***	***	1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .2112	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***	***	***	.023 Avg Mo	***	***	1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1,460	4,373	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max	***	***	***	***	***	Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.24	.43	mg/L	1/day	Grab
	Permit Requirement	***	***	***	***	.19 Avg Mo	.62 IMAX	***	1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 1	6	No./100 ml	2/week	Grab
	Permit Requirement	***	***	***	***	2000 Geo Mean	10000 IMAX	***	2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 51	< 112	lbs/day	***	< 3.7	< 6.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg	***	***	25.0 Avg Mo	40.0 Wkly Avg	***	2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

PA0027367  
 PERMIT NUMBER

001  
 OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2021  
 DMR Effective To: 04/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2021	04	01	TO	2021	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	4568	11025	lbs/day	***	416	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	6219	19635	lbs/day	***	572	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										

PARAMETER	VALUE	UNITS	PERCENT	PERMIT	PERCENT	PERMIT	PERCENT	PERMIT	PERCENT	PERMIT	PERCENT
BOD5	4568	lbs/day	11025	416	mg/L	2/week	24-Hr Composite				
TSS	6219	lbs/day	19635	572	mg/L	2/week	24-Hr Composite				

DATE: \_\_\_\_\_  
 FACILITY: \_\_\_\_\_  
 SPECIAL: \_\_\_\_\_  
 LOCATION: \_\_\_\_\_  
 STAGE: \_\_\_\_\_

BY: \_\_\_\_\_  
 TITLE: \_\_\_\_\_

DATE: \_\_\_\_\_  
 FACILITY: \_\_\_\_\_  
 SPECIAL: \_\_\_\_\_  
 LOCATION: \_\_\_\_\_  
 STAGE: \_\_\_\_\_

BY: \_\_\_\_\_  
 TITLE: \_\_\_\_\_



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, April 2021.pdf	Daily Effluent Monitoring Form	2021-05-26T09:21:08-04:00	
Influent Monitoring Report, April 2021.pdf	Influent and Process Control Form	2021-05-26T09:22:36-04:00	
Sludge Report, April 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-05-26T09:23:50-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
138015	04/01/2021	04/30/2021	Total Residual Chlorine (TRC)	Average Monthly	.24	.19	mg/L	Final Effluent (001)	Other	None taken	Unable to meet new permit restriction with equipment provided.
138016	04/01/2021	04/30/2021	Total Phosphorus	Average Monthly	1.1	1	mg/L	Final Effluent (001)	Insufficient/overdose chemical feed	Increased chemical feed	Received lab results to late to correct. Adjusted after results received. Problem corrected.

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	William Harry Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Steven Vosler	TELEPHONE		DATE		
			(724)	588-2036	2021	05	26
voslerst		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2021  
 DMR Effective To: 05/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2021	05	01	FROM	2021	05	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.0	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	150	202	lbs/day	***	8.5	12.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	195.58	***	lbs/day	***	9.60	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	9	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1628	***	lbs/day	***	84.10	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .35	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	CWM Environmental Lab has lowered there reporting limit to 0.01 from a 0.02.								
Flow (50050)	Sample Measurement	2.034	7.941	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.44	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Unable to meet limit with equipment provided.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 2	20	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 49	< 65	lbs/day	***	< 3.1	< 3.3	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2021  
 DMR Effective To: 05/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	05	01	TO	2021	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1858	3778	lbs/day	***	133	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1843	4004	lbs/day	***	138	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, May 2021.pdf	Daily Effluent Monitoring Form	2021-06-24T09:05:54-04:00	
Daily Influent Monitoring Report, May 2021.pdf	Influent and Process Control Form	2021-06-24T09:07:21-04:00	
Sludge Report, May 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-06-24T09:08:44-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
139495	05/01/2021	05/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Unable to meet chlorine residual limits with equipment provided.	Steven Vosler	T2520	(724)-456-3240

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Bill Jamison	TELEPHONE		DATE		
jamisonw			(814)	790-8640	2021	06	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2021  
 DMR Effective To: 05/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	05	01	TO	2021	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.0	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	150	202	lbs/day	***	8.5	12.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	195.58	***	lbs/day	***	9.60	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	9	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1628	***	lbs/day	***	84.10	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .35	***	lbs/day	***	< .020	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	CWM Environmental Lab has lowered there reporting limit to 0.01 from a 0.02.								
Flow (50050)	Sample Measurement	2.034	7.941	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.44	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Unable to meet limit with equipment provided.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 2	20	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 49	< 65	lbs/day	***	< 3.1	< 3.3	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2021  
 DMR Effective To: 05/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	05	01	TO	2021	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1858	3778	lbs/day	***	133	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1843	4004	lbs/day	***	138	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report, May 2021.pdf	Daily Effluent Monitoring Form	2021-06-24T09:05:54-04:00	
Daily Influent Monitoring Report, May 2021.pdf	Influent and Process Control Form	2021-06-24T09:07:21-04:00	
Sludge Report, May 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-06-24T09:08:44-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
139495	05/01/2021	05/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Unable to meet chlorine residual limits with equipment provided.	Steven Vosler	T2520	(724)-456-3240

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Bill Jamison	TELEPHONE		DATE		
jamisonw			(814)	790-8640	2021	06	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2021  
 DMR Effective To: 06/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	06	01	TO	2021	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	4.6	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.7	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	170	226	lbs/day	***	13.0	16.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	394.54	***	lbs/day	***	20.97	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	6	***	lbs/day	***	.4	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1034.18	***	lbs/day	***	88.70	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .01	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.504	3.038	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.25	.40	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Unable to meet the new requirement with the system we have here.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 4	> 2420	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 39	< 56	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2021  
 DMR Effective To: 06/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	06	01	TO	2021	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2528	5540	lbs/day	***	192	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3438	11007	lbs/day	***	250	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Reort (June-2021).pdf	Daily Effluent Monitoring Form	2021-07-21T10:56:53-04:00	
Daily Influent Monitoring report (June-2021).pdf	Influent and Process Control Form	2021-07-21T10:59:03-04:00	
DMR Sludge Disposal June 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-08-13T11:30:58-04:00	This is the proper Bio Solid Disposal form

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
141372	06/01/2021	06/30/2021	Total Residual Chlorine (TRC)	Average Monthly	.25	.19	mg/L	Final Effluent (001)	See attached comments	None taken	Cannot meet requirements with equipment we have.
141373	06/01/2021	06/30/2021	Fecal Coliform	Instantaneous Maximum	>2420	1000	No./100 ml	Final Effluent (001)	Flooding conditions at plant	None taken	Flooding conditions.

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Steven Vosler	T2520	(724)-456-3240

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Steven Vosler	TELEPHONE		DATE		
voslerst			(724)	588-2036	2021	08	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2021  
 DMR Effective To: 07/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	07	01	TO	2021	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.4	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.8	***	7.7	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	162	404	lbs/day	***	7.0	8.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	275	***	lbs/day	***	13.07	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	17	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	13	***	lbs/day	***	.6	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1200.59	***	lbs/day	***	88.10	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .20	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.617	8.755	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.24	.44	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Cannot meet the current requirements for chlorine residual monthly average with the equipment we have.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 5	1414	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 74	< 183	lbs/day	***	< 3.2	< 3.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2021  
 DMR Effective To: 07/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	07	01	TO	2021	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2453	5863	lbs/day	***	128	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3652	7758	lbs/day	***	207	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report (July 2021).pdf	Daily Effluent Monitoring Form	2021-08-22T10:39:49-04:00	
Supplemental Report (Influent , July 2021).pdf	Influent and Process Control Form	2021-08-22T10:26:48-04:00	
DMR Sludge Report July 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-08-22T10:43:07-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
145779	07/01/2021	07/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.24	.19	mg/L	Final Effluent (001)			
145780	07/01/2021	07/31/2021	Fecal Coliform	Instantaneous Maximum	1414	1000	No./100 ml	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
145781	Late DMR Submission					

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
I was not aware that I also had to submit the edmr since my coworker submitted it under his account. I just now got the email about it needing submitted.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2021	08	31
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2021  
 DMR Effective To: 08/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	08	01	TO	2021	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.4	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.6	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	258	578	lbs/day	***	9.6	12.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	233	***	lbs/day	***	19	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	23	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	18	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	843	***	lbs/day	***	82.5	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .30	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.231	7.975	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.25	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	8	649	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
	<b>Facility Parameter Comments</b>	Excessive Rain Fall								
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 82	< 133	lbs/day	***	< 3.2	3.7	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2021  
 DMR Effective To: 08/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	08	01	TO	2021	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2343	4576	lbs/day	***	113	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	4101	9977	lbs/day	***	177	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report (August-2021).pdf	Daily Effluent Monitoring Form	2021-09-23T09:52:44-04:00	
Influent & Process Control Report (August-2021).pdf	Influent and Process Control Form	2021-09-23T09:51:53-04:00	
DMR Sludge Report, Bio Solids, August 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-09-23T09:53:35-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
146738	08/01/2021	08/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.25	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Cannot make Chlorine Residual Limit due to equipment on sight.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2021	09	23
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2021  
 DMR Effective To: 09/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2021	09	01	TO	2021	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	4.6	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.0	***	7.5	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 104	< 244	lbs/day	***	< 6.2	< 10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	137.42	***	lbs/day	***	10.25	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	34	***	lbs/day	***	2.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	7	***	lbs/day	***	.5	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1213.57	***	lbs/day	***	72	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .16	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.612	3.713	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.43	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Can not meet the low Residual Chlorine number that is on our Permit due to lack of equipment available. We have a consent order on it until the new Plant Upgrade.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 3	150	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 44	< 73	lbs/day	***	< 3.0	< 3.3	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2021  
 DMR Effective To: 09/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2021	09	01	TO	2021	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2709	4119	lbs/day	***	201	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	9562	19215	lbs/day	***	723	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Supplemental Report (Effluent , September 2021).pdf	Daily Effluent Monitoring Form	2021-10-20T10:13:17-04:00	
Supplemental Report (Influent , September 2021).pdf	Influent and Process Control Form	2021-10-20T10:11:15-04:00	
eDMR Sludge Report, September 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-10-20T10:32:12-04:00	I estimated the % Solids Result for the dumpster dated 9/15/21. CWM Lost our sample. Bothe samples for the month were taken from uncovered drying beds within weeks of eachother. So should be very similar
Greenville WWTP Percent Solids 9-15-21 Missed Analysis.pdf	Multiple Attachment Types	2021-10-20T10:24:54-04:00	Letter From CWM Environmental about missed % Solids Analysis

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
148576	09/01/2021	09/30/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Our Lab CWM Lost 1 % solids sample dated 9/15/21 So i estimated since both samples for the month were taken from uncovered drying beds. Can not meet our Residual Chlorine Limit due to lack of equipment. We have a Conccent Order till the new Plant upgrade	Isaiah Vernon	S22930	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2021	10	20
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2021  
 DMR Effective To: 10/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2021	10	01	TO	2021	10 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.37	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.12	***	7.78	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 151	394	lbs/day	***	< 7.4	11.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	195.33	***	lbs/day	***	17.65	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	6	***	lbs/day	***	.3	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	13	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	924.05	***	lbs/day	***	86.9	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .13	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.081	7.384	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.26	.46	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Can not meet our Permit limit for (TRC) due to lack of equipment and our set up. We currently have a Consent Order for it.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 2	18	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
	<b>Facility Parameter Comments</b>	The hold time for the Fecal Coliform Sample that was taken on 10/13/21 was exceeded. Our contracted Lab missed the sample pick up for that date. So the hold time was exceeded and it was not ran. So there is 1 missed Fecal Coliform test that is missing for the month. It's missing for the date 10/13/21. CWM takes full responsibility.								
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 55	< 118	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Hold Time for the CBOD5 sample taken on 10/13/21 was exceeded due to Lab missed pick up. The CBOD5 was ran with a Hold Time Qualifier, so the test was ran on 10/15/21 along with the Samples for that date.								
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2021  
 DMR Effective To: 10/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	10	01	TO	2021	10	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2800	8868	lbs/day	***	155	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Hold Time for the BOD5 sample taken on 10/13/21 was exceeded due to Lab missed pick up. The BOD5 was ran with a Hold Time Qualifier, so the test was ran on 10/15/21 along with the Samples for that date.								
Total Suspended Solids (00530)	Sample Measurement	3418	9853.21	lbs/day	***	198	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Daily Effluent Monitoring Report (October 2021).pdf	Daily Effluent Monitoring Form	2021-11-16T09:26:01-05:00	
Supplemental Report (Influent , October 2021).pdf	Influent and Process Control Form	2021-11-16T09:24:56-05:00	
Sludge Report, October 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-11-16T09:26:41-05:00	
CWM Letter, Missed Samples, 10-13-21.pdf	Other	2021-11-16T09:30:21-05:00	Letter from CWM taking full responsibility for the missed pick up for Samples dated 10/13/21. Missed Fecal Coliform, Hold Time Qualifier for BOD5 & CBOD5.

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
151229	10/01/2021	10/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.26	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
			(724)	813-1101	2021	11	16
ivernon		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2021  
 DMR Effective To: 11/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	11	01	TO	2021	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.2	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.3	***	7.8	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 93	129	lbs/day	***	< 5.9	< 7.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	220.43	***	lbs/day	***	15.15	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	11	***	lbs/day	***	.7	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12	***	lbs/day	***	.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1374.27	***	lbs/day	***	74.9	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .15	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.055	2.912	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.24	.41	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Can not meet permit limit due to current Treatment Plant Process. We are getting a upgrade in the future that will make this limit. We currently have a Conccent Order for this with DEP.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 8	210	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 48	< 52	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2021  
 DMR Effective To: 11/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	11	01	TO	2021	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	3234	6056	lbs/day	***	203	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	4015	5414	lbs/day	***	254	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report, November 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2021-12-13T13:05:11-05:00	
Daily Effluent Monitoring Report (November 2021).pdf	Daily Effluent Monitoring Form	2021-12-13T13:04:17-05:00	
Supplemental Influent & Process Control Report (November -2021).pdf	Influent and Process Control Form	2021-12-13T13:01:50-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
152927	11/01/2021	11/30/2021	Total Residual Chlorine (TRC)	Average Monthly	.24	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2021	12	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2021  
 DMR Effective To: 12/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2021	12	01	TO	2021	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.03	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.21	***	7.75	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	294	416	lbs/day	***	12.7	17.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	303.78	***	lbs/day	***	11.05	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	21	***	lbs/day	***	.9	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	20	***	lbs/day	***	.84	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	3237.5	***	lbs/day	***	110	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .26	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.988	5.711	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.25	.42	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Cannot meet the (TRC) limit due to lack of equipment. The Authority has a consent order from DEP for it.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 10	981	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 99	160.55	lbs/day	***	< 4.2	5.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2021  
 DMR Effective To: 12/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	12	01	TO	2021	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2935	5592	lbs/day	***	125	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	4247	10301	lbs/day	***	180	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Supplemental Daily Effluent Monitoring Report, Dec. 2021.pdf	Daily Effluent Monitoring Form	2022-01-13T14:02:37-05:00	
CWM Missed % Solids 12-10-21.pdf	Other	2022-01-13T14:06:34-05:00	Missed % Solids Result Dated 12/10/21 CWM takes full Responsibility.
Supplemental Influent Process Control Report, Dec. 2021.pdf	Influent and Process Control Form	2022-01-13T14:01:36-05:00	
Sludge Report, Dec 2021.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-01-13T14:04:57-05:00	The % Solids sample dated 12/10/21 is estimated off of the 2 other Pressed Sludge % Solids test because our contracted lab lost the % solids Sample for that specific dumpster.

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
154835	12/01/2021	12/31/2021	Total Residual Chlorine (TRC)	Average Monthly	.25	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Missed % Solis analysis dated 12/10/21 Cannot meet the (TRC) Compliance limit due to lack of equipment. The Authority has a Consent ordr for it.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	01	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 01/01/2021  
 DMR Effective To: 03/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	01	01	TO	2021	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.1188	***	lbs/day	***	.0050	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		***	1/quarter
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Nickel Lab Results, 1-6-21.pdf	Laboratory Analytical Report	2021-04-26T07:18:23-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Wet test results have not been received as of yet.	William Harry Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Bill Jamison	TELEPHONE		DATE		
jamisonw			(724)	866-9338	2021	04	26
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 04/01/2021  
 DMR Effective To: 06/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	04	01	TO	2021	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.042	***	lbs/day	***	.004	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/year	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/year	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/year	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Wet Test Summary Report, March 2021.pdf	WET Test Summary Report	2021-06-24T10:25:04-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
139503	Sample collection less frequent than required	Final Effluent (001)	Toxicity, Chronic - Pimephales Survival	1/year	1/quarter	Permit requires wet testing once a year after 4 passed tests the first year of permit.
139504	Sample collection less frequent than required	Final Effluent (001)	Toxicity, Chronic - Pimephales Growth	1/year	1/quarter	Permit requires wet testing once a year after 4 passed tests the first year of permit.
139505	Sample collection less frequent than required	Final Effluent (001)	Toxicity, Chronic - Ceriodaphnia Reproduction	1/year	1/quarter	Permit requires wet testing once a year after 4 passed tests the first year of permit.

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Wet Testing only required yearly after 4 passed tests the first year of permit.	William Harry Jamison	S7240	(724)-588-2036

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Bill Jamison	TELEPHONE		DATE		
jamisonw			(814)	790-8640	2021	06	24
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 07/01/2021  
 DMR Effective To: 09/30/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2021	07	01	TO	2021	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.01	***	lbs/day	***	.001	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***			
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
-----------	-----------------	---------------	---------------------

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Steven Vosler	T2520	(724)-456-3240

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Steven Vosler	TELEPHONE		DATE		
voslerst			(724)	588-2036	2021	08	25
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 10/01/2021  
 DMR Effective To: 12/31/2021  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2021	10	01	TO	2021	12	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0106	***	lbs/day	***	.0010	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	We Passed 1 for the Year. No more are required for 2021. Results are dated 3/29/21.								
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	We Passed 1 for the Year. No more are required for 2021.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	We Passed 1 for the Year. No more are required for 2021. Results are dated 3/29/21								
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Wet test. Quarterly Report,Dubia & Promelas October 2021.pdf	WET Test Summary Report	2021-11-15T15:08:18-05:00	only results from 2021 not whole summary
Nickel Results, Quarterly, October 2021.pdf	Other	2021-11-15T13:45:39-05:00	Quarterly Nickel Results October 2021

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2021	11	15
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2022  
 DMR Effective To: 01/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2022	01	01	FROM	2022	01	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.61	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.26	***	7.86	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	280	489	lbs/day	***	15.5	24.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	286.43	***	lbs/day	***	13.2	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	32	***	lbs/day	***	1.8	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	16	***	lbs/day	***	.89	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1478.28	***	lbs/day	***	65.6	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .19	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.255	3.814	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.21	.34	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Can not meet our permit requirement to be in compliance. We have a concent order.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	7	28	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	93	150	lbs/day	***	5.2	7.4	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2022  
 DMR Effective To: 01/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	01	01	TO	2022	01 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2639	3836	lbs/day	***	154	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3809	8996	lbs/day	***	221	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Not our Total Nitrogen Sample, COC to Prove, 1-19-22.pdf	Other	2022-02-11T13:36:40-05:00	Our Lad CWM had a total Nitrogen Sample in with our samples. It is not ours. We already did our 2 a month Total Nitrogen Samples. The COC and Result there is to Prove it.
Effluent Monitoring Report, Jan. 2022.pdf	Daily Effluent Monitoring Form	2022-02-11T13:29:22-05:00	
Influent Monitoring Report, Jan. 2022.pdf	Influent and Process Control Form	2022-02-11T13:27:55-05:00	
January 2022 DMR Sludge Report .pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-02-11T13:32:39-05:00	There is a Dumpster weight & sample dated 12/30/2021 on this report. I added it to January's because I did not get the weight ticket for the dumpster till Just now in Feb. It was hauled off sight on 1/3/22 to be taken to the Landfill.
2022 Supplemental Laboratory Accreditation Form.pdf	Laboratory Accreditation Form	2022-02-11T13:33:30-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
157762	01/01/2022	01/31/2022	Total Residual Chlorine (TRC)	Average Monthly	.21	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	02	11
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2022  
 DMR Effective To: 02/28/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2022	02	01	FROM	2022	02	28
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.43	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.28	***	7.89	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	549.85	808.47	lbs/day	***	11.75	12.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	416.13	***	lbs/day	***	16.35	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	37.91	***	lbs/day	***	.89	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	28.49	***	lbs/day	***	.68	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	2555.55	***	lbs/day	***	97.4	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .3710	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	4.503	10.813	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
	<b>Facility Parameter Comments</b>	For the Dates 2/17/22 & 2/18/22 I estimated the EFF Flow due to unrealistic EFF Flow Measurements that our meters wer reading. They were reading River Water that was backing up into the Treatment plant. It read 56 MGD for 2/17/22.								
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.19	.50	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	I was able to reach the Avg Mo TRC limit for this month. Going to try again next month. With our permit it is possible with the fecal limit during the winter, but totally impossible to reach it during the summer months.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	> 243	> 2420	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
	<b>Facility Parameter Comments</b>	Had a couple high IMAX due to washouts with Heavy Rain & snow melt. One on 2/18/22 the other on 2/25/22.								
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	300.25	498.78	lbs/day	***	5.8	8.2	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2022  
 DMR Effective To: 02/28/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	02	01	TO	2022	02	28

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	< 3179	5589	lbs/day	***	< 89	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Lots of Rain & Snow melts.								
Total Suspended Solids (00530)	Sample Measurement	5124	9812.88	lbs/day	***	141	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, Feb. 2022.pdf	Daily Effluent Monitoring Form	2022-03-10T09:57:55-05:00	
Influent Monitoring Report, Feb. 2022.pdf	Influent and Process Control Form	2022-03-10T09:57:19-05:00	
February 2022 DMR Sludge Report .pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-03-10T09:59:05-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
159056	02/01/2022	02/28/2022	Fecal Coliform	Geometric Mean	>243	2000	No./100 ml	Final Effluent (001)			
159057	02/01/2022	02/28/2022	Fecal Coliform	Instantaneous Maximum	>2420	10000	No./100 ml	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
On 2/24/22 our Chlorinator was not operating on a non sample day. I verbally notified DEP ASAP. once I did that I called a guy to vome up to help us resolve the issue. He was up in 40min and within 20min we were back online disinfection with chlorine. Just throwing it out there that I wasn't impressed with the results this month. We may have been in permit limit, but i do not like to see them this bad. Just not much we could do since we had a few big anow melt offs plus lots of rainfall on top that.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	03	10
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2022  
 DMR Effective To: 03/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	03	01	TO	2022	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.51	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.04	***	7.83	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 145.57	281.3	lbs/day	***	< 5.33	8.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	471.79	***	lbs/day	***	14.05	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	22.34	***	lbs/day	***	.84	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12.93	***	lbs/day	***	.51	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	2685.95	***	lbs/day	***	84	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .2708	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	3.238	7.702	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
	<b>Facility Parameter Comments</b>	I estimated the flow for the date 3/7/22. We had lots of rain causing the river to back up into the Treatment Plant which gave us false readings. It said we did 11.2MGD which is far off. I put that we did 7.7MGD.								
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.20	.37	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	140.66	518	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	95	125.8	lbs/day	***	3.6	4.3	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2022  
 DMR Effective To: 03/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	03	01	TO	2022	03 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1477	2328	lbs/day	***	62	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	Facility Parameter Comments	On 3/9/22 Our Influent Sampler Malfunctioned. So that Influent Composite Sample was 90% Grab Sample.								
Total Suspended Solids (00530)	Sample Measurement	1822	3393	lbs/day	***	74	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	Facility Parameter Comments	On 3/9/22 Our Influent Sampler Malfunctioned. So that Influent Composite Sample was 90% Grab Sample.								
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
DMR Sludge Report March 2022.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-04-19T10:06:09-04:00	
Influent Monitoring Report, March. 2022.pdf	Influent and Process Control Form	2022-04-19T10:04:01-04:00	
Effluent Monitoring Report, March. 2022.pdf	Daily Effluent Monitoring Form	2022-04-19T10:05:31-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
163247	03/01/2022	03/31/2022	Total Residual Chlorine (TRC)	Average Monthly	.2	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
See BOD & Flow. Those were my only 2 comments.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	04	19
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2022  
 DMR Effective To: 04/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	04	01	TO	2022	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.37	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.08	***	7.74	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	172.58	231.16	lbs/day	***	< 8.78	14.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	282.30	***	lbs/day	***	10.97	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	18.91	***	lbs/day	***	.99	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	15.79	***	lbs/day	***	.78	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	2197.97	***	lbs/day	***	92.7	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .2238	***	lbs/day	***	< .0100	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.503	6.530	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.21	.38	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Trying our best to keep as low as possible while still killing the Fecals.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	35.84	518	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	88.16	144.34	lbs/day	***	< 4.2	5.65	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2022  
 DMR Effective To: 04/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	04	01	TO	2022	04 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1620	3375	lbs/day	***	86	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1625	3785	lbs/day	***	89	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Arpil 2022 DMR Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-05-16T09:41:25-04:00	
Influent Monitoring Report, April, 2022.pdf	Influent and Process Control Form	2022-05-16T09:40:20-04:00	
Effluent Monitoring Report, April, 2022.pdf	Daily Effluent Monitoring Form	2022-05-16T09:39:36-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
165093	04/01/2022	04/30/2022	Total Residual Chlorine (TRC)	Average Monthly	.21	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Still Tring our best to keep the TRC down while still killing the Fecal Coliforms	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	05	16
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2022  
 DMR Effective To: 05/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	05	01	TO	2022	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.39	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.92	***	7.64	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	200.96	434.22	lbs/day	***	10.13	13.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	203.1	***	lbs/day	***	10.68	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	28.33	***	lbs/day	***	1.39	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	15.47	***	lbs/day	***	.87	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1989.90	***	lbs/day	***	76.4	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1579	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	2.144	6.381	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.24	.46	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Cannot meet the Monthly average (TRC) and kill the fecals at the same time during May 1st - Oct 31st. We have a concent order for this, also getting a Treatment Plant upgrade that will solve this problem.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 3.54	161	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 77	< 165.86	lbs/day	***	< 4.0	< 5.45	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2022  
 DMR Effective To: 05/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	05	01	TO	2022	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1289	3170	lbs/day	***	71	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1867	5164	lbs/day	***	94	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, May 2022.pdf	Daily Effluent Monitoring Form	2022-06-09T10:07:14-04:00	
Influent Monitoring Report, May 2022.pdf	Influent and Process Control Form	2022-06-09T10:08:09-04:00	
Sludge Report, May 2022.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-06-09T10:10:21-04:00	Sewage Sludge/Bio Solids Disposal form for May 2022 has a Sample Dated 4/27/22. The dumpster was not hauled out till 5/2/22. That is why it is on this months eDMR Sludge report.

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
166393	05/01/2022	05/31/2022	Total Residual Chlorine (TRC)	Average Monthly	.24	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Cannot meet the Monthly average (TRC) and kill the fecals at the same time during May 1st - Oct 31st. We have a conceent order for now for this issue, also getting a Treatment Plant upgrde that will solve this problem.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	06	09
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2022  
 DMR Effective To: 06/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	06	01	TO	2022	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.75	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.93	***	7.52	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	85.16	151.31	lbs/day	***	8.78	13.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	226.08	***	lbs/day	***	15.28	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	7.64	***	lbs/day	***	.73	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8.28	***	lbs/day	***	.80	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1487.54	***	lbs/day	***	97.2	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1122	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Sample on 6/8/22 for Copper our result was 0.01 mg/L. We are always <0.01 mg/L. I contacted our Lab "CWM Environmental" about it to see if it was a mistake but, I never got a reply back from email and phone call. I would say it is a typo on their part in my opinion.								
Flow (50050)	Sample Measurement	1.182	3.141	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
	<b>Facility Parameter Comments</b>	Effluent Flow did not record part of the day on 6/24/22 due to a power outage.								
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.23	.49	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Only under certain circumstances can we meet this TRC limit along with the fecals. It is possible for summer months, but is still a rare scenario and everything has to work right. We currently do not have the proper set up to meet it in the normal circumstances. We have a concent order with DEP till the new Plant upgrade.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 1.64	11	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 29	< 40.02	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2022  
 DMR Effective To: 06/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	06	01	TO	2022	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1507	3521	lbs/day	***	156	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Our Sample of BOD on 6/8/22 was >246. I was unable to put a > symbol in the monitoring & report section. Anyway, I did contact our Lab "CWM Environmental" about the >246 BOD result to see from now on if they can be more accurate, but once again along with the Copper Result on the same date I never recieved a email or phone call back.								
Total Suspended Solids (00530)	Sample Measurement	1634	2954	lbs/day	***	169	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, June 2022.pdf	Daily Effluent Monitoring Form	2022-07-14T08:26:16-04:00	See Copper & Flow Parameter on Effluent eDMR
Influent Monitoring Report, June 2022.pdf	Influent and Process Control Form	2022-07-14T08:24:13-04:00	See Influent BOD on the eDMR
Sludge Report June 2022 .pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-07-14T08:28:12-04:00	Sample Dated 5/26/22 dumpster was hauled out on 6/6/22 that is why it is on June's Sludge Report.

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
168627	06/01/2022	06/30/2022	Total Residual Chlorine (TRC)	Average Monthly	.23	.19	mg/L	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	07	14
			SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2022  
 DMR Effective To: 07/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	07	01	TO	2022	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.14	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.04	***	7.47	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 70.92	64.30	lbs/day	***	< 7.44	9.50	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	168.06	***	lbs/day	***	19.17	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	6.92	***	lbs/day	***	.76	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	6.35	***	lbs/day	***	.71	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	913.78	***	lbs/day	***	79.8	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1048	***	lbs/day	***	< .0100	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.043	1.992	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.16	.31	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	We were able to meet the TRC monthly average this month due to the flow being so low. The chlorine was able to have the contact time to kill a substantial amount of fecal coliforms in the chlorine contact tank. We also fully nitrify so there is not much if any nitrite in the effluent for the chlorine to bind to. Once the flow goes up it will be much harder to meet the monthly average limit. We will do our best.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	16.56	154	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 27	< 33.69	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2022  
 DMR Effective To: 07/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	07	01	TO	2022	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1273	2119	lbs/day	***	146	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1618	3013	lbs/day	***	187	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
July 2022 Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-08-16T10:13:20-04:00	Sample 6/29/22 was hauled out on 7/2/22 & sample 6/30/22 was hauled out 7/1/22.
Effluent Monitoring Report, July 2022.pdf	Daily Effluent Monitoring Form	2022-08-16T10:11:53-04:00	
Influent Monitoring Report, July 2022.pdf	Influent and Process Control Form	2022-08-16T10:11:12-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
We were able to meet the TRC lmonthly average this month due to the flow being so low. The chlorine was able to have the contact time to kill a substantial amount of fecal coliforms in the chlorine contact tank. We also fully nitrify so there is not much if any nitrite in the effluent for the chlorine to bind to. Once the flow goes uo it will be much harder to meet the monthly average limit. We will do our best. We have a Concent Order in place also.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	08	16
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2022  
 DMR Effective To: 08/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	08	01	TO	2022	08	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.83	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.85	***	7.68	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	35.06	44.92	lbs/day	***	5.67	8.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	132.82	***	lbs/day	***	18.61	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	2.90	***	lbs/day	***	.45	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	5.52	***	lbs/day	***	.87	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	655.95	***	lbs/day	***	90.3	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .0622	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.802	1.547	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.14	.30	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Once again we are able to keep the TRC low since the flow is low. We also fully nitrify, so no chlorine is binding to nitrite. Since we have low flow the Chlorine is able to get all the contact time it needs in the Chlorine contact tank to kill the fecals effectively.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 4.42	61	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 19	< 21.70	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2022  
 DMR Effective To: 08/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2022	08	01	FROM	2022	08	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	980	2048	lbs/day	***	150	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1136	1947	lbs/day	***	178	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, August, 2022.pdf	Influent and Process Control Form	2022-09-16T12:53:31-04:00	
August 2022 Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-09-16T12:54:29-04:00	
Effluent Monitoring Report, August, 2022.pdf	Daily Effluent Monitoring Form	2022-09-16T12:52:44-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Met the TRC limit once again, due to low flows, fully nitrifying, and having proper contact time in the chlorine contact tanks to kill the fecals effectivly. We will do our best to keep it up.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	09	16
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2022  
 DMR Effective To: 09/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	09	01	TO	2022	09	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.36	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	6.90	***	7.85	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	56.83	85.11	lbs/day	***	7.56	9.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	149.35	***	lbs/day	***	23.53	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	3.73	***	lbs/day	***	.44	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	6.41	***	lbs/day	***	.91	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	553.22	***	lbs/day	***	80.6	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .0916	***	lbs/day	***	< .0100	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.932	1.644	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.11	.27	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Met our limit once again due to low flow, so the Chlorine Contact Tank is getting enough detention time to kill the fecals. I am able to keep a very low TRC while still killing the fecals unless it rains then we have to bump it up. We also fully nitrify so there arent very many nitrites to bind with the chlorine.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 5.72	28	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 23	< 29.40	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2022  
 DMR Effective To: 09/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	09	01	TO	2022	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1311	2338	lbs/day	***	171	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1556	3319	lbs/day	***	194	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, September 2022.pdf	Daily Effluent Monitoring Form	2022-10-13T08:01:08-04:00	
Influent Monitoring Report, September, 2022.pdf	Influent and Process Control Form	2022-10-13T08:00:05-04:00	
September 2022 Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-10-13T08:02:04-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
I am pleased with the low flow we have been having so that we can meet the monthly average TRC limit and fecal limit. I am able to keep the TRC very low because of it.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon		(724)	813-1101	2022	10	13	
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2022  
 DMR Effective To: 10/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	10	01	TO	2022	10 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.07	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.21	***	7.76	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	50.93	79.84	lbs/day	***	7.13	9.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	212.91	***	lbs/day	***	27.20	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	4.40	***	lbs/day	***	.58	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	5.78	***	lbs/day	***	.80	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	437.33	***	lbs/day	***	83.9	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .0946	***	lbs/day	***	< .0100	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.709	1.617	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.11	.30	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Keeping the chlorine as low as possible. Low flow we are able to make the TRC limit while still killing all the fecals..								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 39.90	17330	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
	<b>Facility Parameter Comments</b>	Grab Sample that wa taken on 10/21/22 was the IMAX sample. We had put our new chlorinator system on, it worked great but we came to find out it was chlorinating directly after the chlorine contact tank. So the grab sample we had taken was before the chlorine hit the effluent. I typed up a whole paper on it explaining everything and it is attached. I am asking for DEP to please not fine the Greenville sanitary authority for this because it was being disinfected & the chlorine was kept low.								
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 22	< 28	lbs/day	***	< 3.1	< 3.45	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2022  
 DMR Effective To: 10/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	10	01	TO	2022	10 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1541	2819	lbs/day	***	209	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2321	4558	lbs/day	***	302	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
October 2022 Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-11-10T13:10:01-05:00	No Sludge was hauled out during October 2022
IMAX Fecal explanation 10-21-22.pdf	Letter Explaining Non-Compliance	2022-11-11T08:41:56-05:00	I am asking DEP to not fine the Greenville Borough Sanitary Authority since the effluent was being chlorinated after frome wheree the fecal was taken. Please contact me if you have any questions.
Influent Monitoring Report, October 2022.pdf	Influent and Process Control Form	2022-11-10T13:08:22-05:00	
Effluent Monitoring Report, October 2022.pdf	Daily Effluent Monitoring Form	2022-11-10T13:09:02-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
177210	10/01/2022	10/31/2022	Fecal Coliform	Instantaneous Maximum	17330	10000	No./100 ml	Final Effluent (001)			

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Please do call if you have any questions about the fecal IMAX that occured on 10/21/22. I wrote a letter explaining it with pictures and all "See letter explaining non compliance" Thank you	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	11	11
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2022  
 DMR Effective To: 11/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2022	11	01	FROM	2022	11	30
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.66	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.14	***	8.25	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
	Facility Parameter Comments	8.25 PH reading occurred on 11/21/22. The Probe Malfunctioned. We fixed it and did a reading later that day and it was in normal range where it usually is.								
Total Suspended Solids (00530)	Sample Measurement	225.38	526.37	lbs/day	***	10.11	14.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	209.50	***	lbs/day	***	26.95	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	20.19	***	lbs/day	***	.94	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	18.77	***	lbs/day	***	.76	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	763.77	***	lbs/day	***	80.9	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1649	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.730	10.172	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.12	.33	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	Facility Parameter Comments	Winter months are easier to meet the TRC and Fecal limits as long as the flow stays moderate and we continue to fully nitrify so the chlorine doesn't get used up by the Ammonia & Nitrites								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	32.31	3076	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 67	< 135.93	lbs/day	***	< 3.2	< 3.85	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 11/01/2022  
 DMR Effective To: 11/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	11	01	TO	2022	11	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	3054	13574	lbs/day	***	136	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	3812	13404	lbs/day	***	218	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, November 2022.pdf	Daily Effluent Monitoring Form	2022-12-13T10:41:28-05:00	
Influent Monitoring Report, November, 2022.pdf	Influent and Process Control Form	2022-12-13T10:40:36-05:00	
November 2022 Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2022-12-13T10:42:14-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
I am very pleased that we are able to stay in compliance with the TRC & Fecals. Weather has been good and has a lot to do with us being able to make it happen.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	12	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2022  
 DMR Effective To: 12/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2022	12	01	FROM	2022	12	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.08	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.24	***	7.74	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	173.26	223.36	lbs/day	***	12.0	15.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	231.08	***	lbs/day	***	15.8	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	9.58	***	lbs/day	***	.64	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	12.6	***	lbs/day	***	.86	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1236.5	***	lbs/day	***	70.5	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1315	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.798	2.869	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.09	.23	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Once again able to meet the limit. The weather has been on our side lately to achieve the limit while killing fecals to stay in permit limits. We ares still fully nitrifying so there isn't that much combined chlorne.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	320.53	2420	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 45.91	< 51.98	lbs/day	***	< 3.2	< 3.55	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 12/01/2022  
 DMR Effective To: 12/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2022	12	01	FROM	2022	12	31
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2203	3188	lbs/day	***	159	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2685	5479	lbs/day	***	196	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, December 2022.pdf	Daily Effluent Monitoring Form	2023-01-13T09:08:43-05:00	
Influent Monitoring Report, December 2022.pdf	Influent and Process Control Form	2023-01-13T09:08:05-05:00	
December 2022 DMR Sludge Report.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-01-13T09:09:20-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Weather has been good once again and warm for this month so it allows us to meet the TRC monthly average limit while still killing the fecals within Permit limits. Being warmer we nitrify much better so not much of the chlorine is combined with ammonia and nitrites.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	01	13
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 01/01/2022  
 DMR Effective To: 03/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2022	01	01	TO	2022	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	< .0451	***	lbs/day	***	< .002	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	Not Required yet. We have to do a Chronic Toxicity Test once a year now. Planning to do it during the second Quarter.								
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	We have to do a Chronic Toxicity Test once a year now. Planning to do it during the second Quarter.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	Not Required yet. We have to do a Chronic Toxicity Test once a year now. Planning to do it during the second Quarter.								
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
1st Quarter, Nickel Results, 1-5-22.pdf	Other	2022-02-10T10:30:52-05:00	Lab Results. Results are in Micrograms.

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Wett Test not required yet. We have to do a Chronic Toxicity Test once a year now. Planning to do it during the second Quarter.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
			(724)	813-1101	2022	02	10
ivernon		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>		<b>001</b>				
PERMIT NUMBER		OUTFALL NUMBER				
MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 2022	04	01	TO	2022	06	30

Reporting Frequency: Quarterly  
 DMR Effective From: 04/01/2022  
 DMR Effective To: 06/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	< .0474	***	lbs/day	***	< .0020	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
	Facility Parameter Comments	Was done on 4/6/22 the Flow was 2.843MGD								
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	8.3	***	TUc	1/year	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	Facility Parameter Comments	Permit requires Wet Testing once a year after 4 passed Tests the first year of Permit.								
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	1.0	***	TUc	1/year	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	Facility Parameter Comments	Permit requires Wet Testing once a year after 4 passed Tests the first year of Permit.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	8.3	***	TUc	1/year	24-Hr Composite
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	Facility Parameter Comments	Permit requires Wet Testing once a year after 4 passed Tests the first year of Permit.								
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF ENVIRONMENTAL PROTECTION**  
**BUREAU OF CLEAN WATER**  
**DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
2nd Quarter Effluent Monitoring Report, April, 2022.pdf	Daily Effluent Monitoring Form	2022-05-17T13:19:33-04:00	
2022 Wet Test Results April.pdf	WET Test Summary Report	2022-05-17T13:21:06-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
165224	Sample collection less frequent than required	Final Effluent (001)	Toxicity, Chronic - Pimephales Growth	1/year	1/quarter	
165225	Sample collection less frequent than required	Final Effluent (001)	Toxicity, Chronic - Ceriodaphnia Reproduction	1/year	1/quarter	
165226	Sample collection less frequent than required	Final Effluent (001)	Toxicity, Chronic - Pimephales Survival	1/year	1/quarter	

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Reporting our Quarterly Nickel & the Wet Test that is to be done once a year.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon		SUBMITTED BY FULL NAME	(724)	813-1101	2022	05	18
			AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 07/01/2022  
 DMR Effective To: 09/30/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	07	01	TO	2022	09 30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0245	***	lbs/day	***	.00214	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***			
	Facility Parameter Comments	We do this test annually since we have passed. This test has been done for this year.								
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***			
	Facility Parameter Comments	We do this test annually since we have passed. This test has been done for this year.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc	1/quarter	See Permit
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***			
	Facility Parameter Comments	We do this test annually since we have passed. This test has been done for this year.								
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
CWM Nickel Results 3rd quarter, 7-6-22.pdf	Other	2022-08-16T09:28:22-04:00	Our Lab Results for the 3rd quarterly Nickel.
Effluent Monitoring Report, July 2022.pdf	Daily Effluent Monitoring Form	2022-08-16T09:26:42-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	08	16
			SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Quarterly  
 DMR Effective From: 10/01/2022  
 DMR Effective To: 12/31/2022  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2022	10	01	TO	2022	12 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Nickel, Total (01067)	Sample Measurement	.0107	***	lbs/day	***	.00205	***	mg/L	1/quarter	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Qrtly	***		***	Monitor & Report Avg Qrtly	***		1/quarter	24-Hr Composite
	<b>Facility Parameter Comments</b>	Lab reports it as micrograms. DMR wants it as mg/L so I convert the microgram results into mg/L								
Toxicity, Chronic - Pimephales Growth (TTD6C)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
Toxicity, Chronic - Ceriodaphnia Reproduction (TTD3B)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	We passed our one for the year. No more needed till 2023.								
Toxicity, Chronic - Pimephales Survival (61428)	Sample Measurement	***	***	***	***	GG	***	TUc		
	Permit Requirement	***	***		***	8.3 Avg Qrtly	***		1/quarter	See Permit
	<b>Facility Parameter Comments</b>	We passed our one for the year. No more needed till 2023.								
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
4ht Quarter Nickel Results from CWM 10-5-22.pdf	Other	2022-11-10T09:16:05-05:00	4th Quarter Nickel. Lab reports in Micrograms. 1 report on this eDMR in mg/L
Effluent Monitoring Report, 4th Quarter 2022.pdf	Daily Effluent Monitoring Form	2022-11-10T09:11:17-05:00	Has Nickel Results form 10/5/2022

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2022	11	10
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2023  
 DMR Effective To: 01/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2023	01	01	TO	2023	01 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.86	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.18	***	7.51	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	500.97	688.73	lbs/day	***	15.38	19.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	345.39	***	lbs/day	***	11.18	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
	<b>Facility Parameter Comments</b>	The first sample we took on 1/4/23 was 6.05MGD, which is a lot for our WWTP.								
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	24.72	***	lbs/day	***	.76	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	27.71	***	lbs/day	***	.83	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	3743.91	***	lbs/day	***	74.2	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
	<b>Facility Parameter Comments</b>	When we took this sample the flow was 6.05MGD. That's why lbs/Day is higher than normally reported in the past.								
Copper, Total (01042)	Sample Measurement	< .3263	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	3.409	6.718	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
	<b>Facility Parameter Comments</b>	We recorded 6.27" Rain this month								
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.15	.33	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Had to keep Chlorine a little higher due to the rain.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	325.2	1120	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 222	< 431.12	lbs/day	***	< 6.1	< 11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2023  
 DMR Effective To: 01/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM	2023	01	01	TO	2023	01 31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	< 2430	< 4713	lbs/day	***	< 78	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	Sample taken on 1/20/23 was reported <39.1. Why the results are all <								
Total Suspended Solids (00530)	Sample Measurement	3260	6761	lbs/day	***	99	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, Jan. 2023.pdf	Influent and Process Control Form	2023-02-07T09:55:47-05:00	
Effluent Monitoring Report, Jan. 2023.pdf	Daily Effluent Monitoring Form	2023-02-07T09:56:36-05:00	
DMR Sludge Report January 2023.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-02-07T09:57:15-05:00	
Lab Accreditation Form 2023.pdf	Laboratory Accreditation Form	2023-02-07T09:58:09-05:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
We are continuing to work under our old NPDES Permit (which expired December 31, 2022) until the new NPDES Permit is completed.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	02	07
			SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2023  
 DMR Effective To: 02/28/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2023	02	01	FROM	2023	02	28
			TO			

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.64	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.17	***	7.82	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	134.16	182.95	lbs/day	***	8.75	11.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	179.21	***	lbs/day	***	12.3	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	8.64	***	lbs/day	***	.55	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	10.7	***	lbs/day	***	.66	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1466.65	***	lbs/day	***	80.3	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1801	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.866	4.631	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.13	.33	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Keeping the Chlorine low to meet the Avg Mo limit while still meeting the fecal limit.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 47.74	548	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 49.11	< 73.51	lbs/day	***	< 3.0	< 3.1	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 02/01/2023  
 DMR Effective To: 02/28/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	02	01	TO	2023	02	28

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1429	3602	lbs/day	***	84	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1776	3342	lbs/day	***	113	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, Feb. 2023.pdf	Influent and Process Control Form	2023-03-10T12:53:47-05:00	
Effluent Monitoring Report, Feb. 2023.pdf	Daily Effluent Monitoring Form	2023-03-10T12:54:35-05:00	
Sludge Report February 2023 .pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-03-10T12:57:18-05:00	The % solids sample dated 1/27/23 dumpster was hauled away on 2/3/23

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
			(724)	813-1101	2023	03	10
ivernon		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2023  
 DMR Effective To: 03/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	03	01	TO	2023	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.08	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.16	***	7.89	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	223.6	284	lbs/day	***	8.0	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	192.55	***	lbs/day	***	9.46	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	21	***	lbs/day	***	.77	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	17.13	***	lbs/day	***	.63	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1748.6	***	lbs/day	***	74.8	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1886	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	All our results are either <0.01mg/L or 0.01mg/L. I don't know if our Certified Lab CWM is forgetting to put the < symbol in some weeks or what is going on. I have contacted them in the past about it and I never hear back from them.								
Flow (50050)	Sample Measurement	2.892	6.679	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.12	.19	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	We once again made this limit while staying within the fecal limits. The Treatment Plant have been doing a great job fully acheiving full nitrification so the chlorine isn't bound up to too much nitrite.								
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	210.76	932	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 87.06	< 122.13	lbs/day	***	< 3.2	3.55	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2023  
 DMR Effective To: 03/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	03	01	TO	2023	03	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	2006	3956	lbs/day	***	80	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	2875	6016	lbs/day	***	105	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Sludge Report March 2023.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-04-07T09:27:27-04:00	
Effluent Monitoring Report, March. 2023.pdf	Daily Effluent Monitoring Form	2023-04-07T09:26:34-04:00	
Influent Monitoring Report, March. 2023.pdf	Influent and Process Control Form	2023-04-07T09:25:43-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
I filed a Non Compliance Report during this month due to a Power outage at the Greenville WWTP. It occurred from 3/25/2023 @ 3:20PM - 3/26/2023 @ 5:30PM. 3/26/2023 @ 5:30PM Power Was Restored & we had the WWTP Back up & running normally by 8:30PM. See Non-Compliance Reports.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon		(724)	813-1101	2023	04	07	
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2023  
 DMR Effective To: 04/30/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	04	01	TO	2023	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.44	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.06	***	7.69	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	102.09	196.18	lbs/day	***	7.38	10.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	212.98	***	lbs/day	***	13.25	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (Nov-Apr)	Sample Measurement	9.28	***	lbs/day	***	.68	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	700 Avg Mo	***		***	21.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	9.97	***	lbs/day	***	.74	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1603.74	***	lbs/day	***	69.9	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1339	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.746	4.047	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.11	.21	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (Oct-Apr)	Sample Measurement	***	***	***	***	< 22.92	452	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	2000 Geo Mean	10000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (Nov-Apr)	Sample Measurement	< 40.08	< 59.76	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	834 Avg Mo	1334 Wkly Avg		***	25.0 Avg Mo	40.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 04/01/2023  
 DMR Effective To: 04/30/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	04	01	TO	2023	04	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1694	4003	lbs/day	***	140	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
	<b>Facility Parameter Comments</b>	BOD Lab Result on 4/12/2023 was >365								
Total Suspended Solids (00530)	Sample Measurement	1585	3466	lbs/day	***	138	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, April, 2023.pdf	Influent and Process Control Form	2023-05-16T09:01:51-04:00	
Effluent Monitoring Report, April, 2023.pdf	Daily Effluent Monitoring Form	2023-05-16T09:04:25-04:00	
Sludge Report April 2023 .pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-05-16T09:04:54-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	05	16
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>			<b>001</b>			
PERMIT NUMBER			OUTFALL NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
2023	05	01	TO	2023	05	31

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2023  
 DMR Effective To: 05/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	7.06	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.20	***	7.76	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 67.37	190.78	lbs/day	***	< 5.56	12.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	289.71	***	lbs/day	***	15.45	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	6.66	***	lbs/day	***	.51	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	7.50	***	lbs/day	***	.67	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	1711.14	***	lbs/day	***	60.9	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1105	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.174	3.369	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.12	.25	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	36.4	933	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 31.06	< 67.29	lbs/day	***	< 3.0	< 3.15	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2023  
 DMR Effective To: 05/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	05	01	TO	2023	05	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1247	4215	lbs/day	***	125	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1403	5339	lbs/day	***	134	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, May 2023.pdf	Influent and Process Control Form	2023-06-22T09:08:26-04:00	
Effluent Monitoring Report, May 2023.pdf	Daily Effluent Monitoring Form	2023-06-22T09:08:58-04:00	
Sludge Report May 2023.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-06-22T09:09:26-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	06	22
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2023  
 DMR Effective To: 06/30/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	06	01	TO	2023	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	6.50	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.08	***	7.51	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	37.66	52.37	lbs/day	***	6.44	8.5	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	147.81	***	lbs/day	***	25.1	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	3.77	***	lbs/day	***	.51	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	4.32	***	lbs/day	***	.70	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	135.56	***	lbs/day	***	85.1	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .0558	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	.698	1.216	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
	<b>Facility Parameter Comments</b>	Flow was low on 6/7/2023. We were filling the South Flocculator Clarifier. Most of our flow was going to that Tank.								
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.12	.23	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 5.57	313	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 18.43	< 30.34	lbs/day	***	< 3.0	< 3.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 06/01/2023  
 DMR Effective To: 06/30/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	06	01	TO	2023	06	30

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1042	2642	lbs/day	***	163	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1175	3186	lbs/day	***	173	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Influent Monitoring Report, June 2023.pdf	Influent and Process Control Form	2023-07-20T09:14:54-04:00	
Sludge Report June 2023.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-07-20T09:15:52-04:00	
Effluent Monitoring Report, June 2023.pdf	Daily Effluent Monitoring Form	2023-07-20T09:15:26-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
Flow was low on 6/7/2023. We were filling the South Flocculator Clarifier. Most of our flow was going to that Tank.	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	07	20
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Final Effluent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2023  
 DMR Effective To: 07/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	07	01	TO	2023	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	Sample Measurement	***	***	***	5.37	***	***	mg/L	1/day	Grab
	Permit Requirement	***	***		4.0 Inst Min	***	***		1/day	Grab
pH (00400)	Sample Measurement	***	***	***	7.05	***	7.64	S.U.	1/day	Grab
	Permit Requirement	***	***		6.0 Inst Min	***	9.0 IMAX		1/day	Grab
Total Suspended Solids (00530)	Sample Measurement	< 79	< 117.92	lbs/day	***	< 6.13	9.0	mg/L	2/week	24-Hr Composite
	Permit Requirement	1000 Avg Mo	1500 Wkly Avg		***	30.0 Avg Mo	45.0 Wkly Avg		2/week	24-Hr Composite
Total Nitrogen (00600)	Sample Measurement	279.73	***	lbs/day	***	23.95	***	mg/L	2/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		2/month	24-Hr Composite
Ammonia-Nitrogen (00610) (May-Oct)	Sample Measurement	7.13	***	lbs/day	***	.53	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	233 Avg Mo	***		***	7.0 Avg Mo	***		2/week	24-Hr Composite
Total Phosphorus (00665)	Sample Measurement	8.82	***	lbs/day	***	.73	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	33 Avg Mo	***		***	1.0 Avg Mo	***		2/week	24-Hr Composite
Chloride (00940)	Sample Measurement	363.59	***	lbs/day	***	79.7	***	mg/L	1/month	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	***		***	Monitor & Report Avg Mo	***		1/month	24-Hr Composite
Copper, Total (01042)	Sample Measurement	< .1450	***	lbs/day	***	< .010	***	mg/L	1/week	24-Hr Composite
	Permit Requirement	.76 Avg Mo	***		***	.023 Avg Mo	***		1/week	24-Hr Composite
Flow (50050)	Sample Measurement	1.176	3.917	MGD	***	***	***	***	Continuous	Measured
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	***	***		Continuous	Measured
Total Residual Chlorine (TRC) (50060)	Sample Measurement	***	***	***	***	.11	.29	mg/L	1/day	Grab
	Permit Requirement	***	***		***	.19 Avg Mo	.62 IMAX		1/day	Grab
	<b>Facility Parameter Comments</b>	Flow was down for most of the month so I was able to keep the TRC really low.								
Fecal Coliform (74055) (May-Sep)	Sample Measurement	***	***	***	***	< 9.93	219	No./100 ml	2/week	Grab
	Permit Requirement	***	***		***	200 Geo Mean	1000 IMAX		2/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082) (May-Oct)	Sample Measurement	< 42.1	< 71.92	lbs/day	***	< 3.3	< 4.3	mg/L	2/week	24-Hr Composite
	Permit Requirement	667 Avg Mo	1000 Wkly Avg		***	20.0 Avg Mo	30.0 Wkly Avg		2/week	24-Hr Composite
<b>Facility Sampling Point Comments</b>										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

NAME: GREENVILLE BORO SANI AUTH MERCER CNTY  
 ADDRESS: PO BOX 604125 MAIN ST, GREENVILLE PA, 16125-0604  
 FACILITY: GREENVILLE SANI AUTH  
 LOCATION: 183 HAMBURG RD, GREENVILLE PA, 16125-1527  
 STAGE: Raw Sewage Influent

<b>PA0027367</b>	<b>001</b>
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 07/01/2023  
 DMR Effective To: 07/31/2023  
 Permit Expires: 12/31/2022  
 Permit Application Due: 07/04/2022  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
FROM	2023	07	01	TO	2023	07	31

**PARAMETERS REPORTED VALUES**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Biochemical Oxygen Demand (BOD5) (00310)	Sample Measurement	1084	2092	lbs/day	***	105	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Total Suspended Solids (00530)	Sample Measurement	1904	4573	lbs/day	***	139	***	mg/L	2/week	24-Hr Composite
	Permit Requirement	Monitor & Report Avg Mo	Monitor & Report Daily Max		***	Monitor & Report Avg Mo	***		2/week	24-Hr Composite
Facility Sampling Point Comments										



**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER  
DISCHARGE MONITORING REPORT (DMR)**

**ATTACHMENT DETAILS**

File Name	Attachment Type	Uploaded Time	Attachment Comments
Effluent Monitoring Report, July 2023.pdf	Daily Effluent Monitoring Form	2023-08-22T09:50:30-04:00	
Influent Monitoring Report, July 2023.pdf	Influent and Process Control Form	2023-08-22T09:50:03-04:00	
Sludge Report July 2023.pdf	Sewage Sludge / Biosolids Production and Disposal Form	2023-08-22T09:50:59-04:00	

**PERMIT VIOLATIONS**

Non-Compliance ID	Event Start Date	Event End Date	Parameter	Limit Type	Reported Value	Permit Limit	Unit	Sampling Point	Cause Of Non-Compliance	Corrective Action	Comments
-------------------	------------------	----------------	-----------	------------	----------------	--------------	------	----------------	-------------------------	-------------------	----------

**UNAUTHORIZED DISCHARGES**

Non-Compliance ID	Event Start Date	Event End Date	Date and Time Discovered	Substance Discharged	Event Location	Volume (gal)	Duration (hrs)	Receiving Waters	Impact On Waters	Cause Of Discharge	Date and Time DEP Notified Orally	Comments
-------------------	------------------	----------------	--------------------------	----------------------	----------------	--------------	----------------	------------------	------------------	--------------------	-----------------------------------	----------

**OTHER PERMIT VIOLATIONS**

Non-Compliance ID	Non-Compliance Type	Sampling Point	Parameter	Reported Value	Permit Limit	Comments
-------------------	---------------------	----------------	-----------	----------------	--------------	----------

**COMMENT DETAILS**

Comments	Operator Name	Operator Certification Number	Operator Contact Number
	Isaiah Vernon	S22930	(724)-813-1101

**SUBMISSION INFORMATION**

SUBMITTED BY GREENPORT USER	*Pursuant to the Pennsylvania Electronic Transactions Act - Act 69, effective January 15, 2002, you are about to engage in an electronic transaction with the Commonwealth of Pennsylvania. You are submitting official information. You certify under penalty of law that this document and all attachments were prepared under your direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on your inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of your knowledge and belief, true, accurate and complete. You are aware that any false statement may be subject to substantial civil and criminal penalties, including 18 P.S. section 4904 (relating to unsworn falsification to authorities).	Isaiah Vernon	TELEPHONE		DATE		
ivernon			(724)	813-1101	2023	08	22
		SUBMITTED BY FULL NAME	AREA CODE	NUMBER	YEAR	MO	DAY