



RCVD PUC SEC BUR
DEC 8 2023 AM 10:31

10700 W. Main Road
North East, PA 16428
(814) 725-4302

December 6, 2023

Rosemary Chiavetta, Secretary

Secretary's Bureau
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

M-2011-2271982


Dear Secretary Chiavetta,

North East Heat & Light Company ("NEHL") implemented its Frost Patrol plan between November 2022 and April 2023, as required by the Commission Order M-2011-2271982, dated December 22, 2011. There were three leaks on steel main, three leaks on wrought iron main, one leak on steel service line, and a leak on Medium Density Polyethylene saddle connection discovered by NEHL during the Frost Patrol.

The leaks on the steel main were replaced by Medium Density Polyethylene pipe which was classified as Grade 3 in 2021-2022 Frost Patrol report. The wrought iron main was cutoff and removed from service to stop the leaks. The one steel service line was replaced by Medium Density Polyethylene pipe. The Medium Density Polyethylene saddle connection nuts were retightened and stopped the leak.

If you have any questions about this report, please contact NEHL at (814) 725-4302.

Sincerely,


Shawn A Hubbard
Field Technician
North East Heat & Light Company



10700 West Main Rd, North East, PA 16428

PITTSBURGH PA 150

6 DEC 2023 PM 5 L



Secretary's Bureau
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

17120-007999

