



January 30, 2024

Office of Consumer Advocate  
555 Walnut Street  
Forum Place, 5<sup>th</sup> Floor  
Harrisburg, PA 17101-1923

Bureau of Investigation & Enforcement  
Commonwealth Keystone Building  
PO Box 3265  
Harrisburg, PA 17105-3265

Office of Small Business Advocate  
Commerce Building, Suite 202  
300 North 2nd Street  
Harrisburg, PA 17101

RE: Annual Valve Exercising Report; Columbia Water Company  
Docket No. R-2017-2598203

Dear Sir or Madam:

In compliance with the Order entered on March 1, 2018 at Docket No. R-2017-2598203, Columbia Water Company submits the following annual valve exercising report for the period ending 12/31/23.

Number of system isolation valves:	3,570
Number of valves exercised:	985
Number of critical isolation valves:	147
Number of critical valves exercised:	30
Number of valves that could not be exercised:	2
Remedial steps taken:	One valve was obscured by debris and needed to be relocated and one valve was replaced.

If you have any questions, please feel free to contact me.

Sincerely,

David T. Lewis, P.E.  
President and  
General Manager

Cc: Rosemary Chiavetta, Secretary, Pa Public Utility Commission

**Columbia Water Company**

220 Locust Street ■ P.O. Box 350 ■ Columbia, PA 17512  
Phone: 717-684-2188 ■ Fax: 717-684-4566