



ARRO Consulting, Inc.
1450 East Boot Road, Ste 100B
West Chester, PA 19380
P: (484) 999-6150

VIA ELECTRONIC MAIL

March 19, 2024

Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

RE: File: A-2024-3047184
PAWC – N. 11th Avenue Amtrak Bridge
Caln Township
ARRO No.: 11243.66

To Whom it May Concern:

On behalf of Caln Township, ARRO has completed a review of the Permit Plan for the Pennsylvania Water Company water main installation at the N. 11th Avenue Amtrak Bridge. The Plan proposes installation of a new underground sixteen (16) inch ductile iron water main within North 11th Street beneath the overhead Amtrak bridge.

I. SUBMISSION

The following information was received by ARRO:

- N. 11th Avenue / Amtrak Bridge No. 37/54 Water Main Installation Permit Plan, consisting of four (4) sheets, dated December 21, 2023, and prepared by Hydraterra Professionals LLC (Plan).

II. REVIEW COMMENTS

We offer the following comments for consideration:

1. The proposed trench will undermine a relatively long section of existing storm pipe. The Applicant shall provide detailed notes specifying the protection and/or restoration of the storm drainage system.
2. The Applicant shall provide Caln Township with the opportunity to observe the condition of existing stormwater pipes during construction. Deteriorated storm drainage pipes/structures shall be replaced as directed by Caln Township.

Corporate Headquarters - 108 West Airport Road, Lititz, PA 17543
P: (717) 569-7021 | www.arroconsulting.com

File: A-2024-3047184
PAWC – N. 11th Avenue Amtrak Bridge
March 19, 2024
Page 2

3. A road opening permit must be obtained for all work within Caln Township street(s) as required by the streets and sidewalks ordinance. Additional requirements may be included in the permit.
4. Additional comments may be provided as additional information is provided by the applicant.

Please do not hesitate to contact me via email at lowell.leaman@arroconsulting.com or by phone at our West Chester office with any questions.

Sincerely,

A handwritten signature in blue ink that reads "Lowell B. Leaman". The signature is fluid and cursive, with a long horizontal stroke at the end.

Lowell Leaman, P.E.
ARRO Consulting, Inc. – Township Engineer

LBL:law

- c: Raymond Stackhouse – Director of Building and Life Safety
Kristin Camp, Esquire – Township Solicitor
Elizabeth Nagy – Planning Commission Secretary
Karl Schmit – ARRO