



November 19, 2024

Secretary of the Commission
Pennsylvania Public Utility Commission
P.O. Box 3265
Harrisburg, PA 17105-3265

via: electronic filing

Re: Elverson Water Company, Inc. **P-2024-3050472**
Utility Code: A-210011
Lead Service Line Replacement Program Petition Filing

Dear Secretary Chiavetta:

Please accept the following documents in connection with the required filing of a petition for approval of a Lead Service Line Replacement (LSLR) program. Pursuant to Section 1311(b)(2) of the PA Public Utility Code, 66 Pa.C.S. § 1311(b)(2), and the PA Public Utility Commission's LSLR Regulations, 52 Pa. Code § 65.51, *et seq.*, Elverson Water Company, Inc. submits the following:

1. Lead Service Line Replacement Program Petition
2. Appendix A – Pro Forma LSLR Program Tariff Supplement
3. Appendix B – Data Responses to 52 Pa. Code § 53.52
4. Appendix C – Lead Service Line Replacement Plan
5. Appendix D – Original signed and notarized Verification Statement
6. Appendix E – Certificate of Service evidencing Petition was served
7. Appendix F – Service Line Inventory Electronic Working Copy
8. Appendix G – Service Line Inventory Hard Copy
9. Appendix H – LSLR Consent Agreement Form
10. Appendix J – LSLR Refusal and Non-Acceptance Form

Respectfully submitted,

Merle W. Stoltzfus, President
Elverson Water Company, Inc.

cc: Bureau of Investigation & Enforcement
Bureau of Technical Utility Services
Office of Consumer Advocate
Office of Small Business Advocate



**COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120**

LEAD SERVICE LINE REPLACEMENT PROGRAM PETITION

Re: Petition for Lead Service Line Replacement Program

Docket No. P-2024-_____

Pursuant to Section 1311(b)(2) of the Pennsylvania Public Utility Code, 66 Pa.C.S. § 1311(b)(2), and the Pennsylvania Public Utility Commission’s (Commission’s) Lead Service Line Replacement (LSLR) Regulations, 52 Pa. Code § 65.51, *et seq.*, the Company seeks Commission approval of its LSLR program and plan to replace Company-owned and customer-owned lead service lines (LSLs) and to recover the associated costs related to those replacements as set forth in the Company’s Lead Service Line Replacement Program (LSLR Program). In accordance with the LSLR Program and proposed tariff revisions, upon approval by the Commission, the Company will be able to begin replacing customer-owned LSLs at its sole cost and recover a return on and of those costs pursuant to Act 120.

Company Name: Elverson Water Company, Inc.

Company Address: PO Box 20, Elverson, PA 19520

Telephone No.: (610) 286-5116

Email Address: inbox@elversonwater.com

Point of Contact:
Name: Daniel Iya
Title: Operations Associate
Telephone No.: (610) 286-5116
Email Address: daniel@stoltzfus.com

Appendix A

Pro Forma LSLR Program Tariff Supplement to
Tariff Water - Pa P.U.C. No. 2

ELVERSON WATER COMPANY, INC.

RATES, RULES AND REGULATIONS GOVERNING

THE PROVISION OF WATER SERVICE

TO THE PUBLIC IN ELVERSON BOROUGH

AND PORTIONS OF WEST NANTMEAL TOWNSHIP,

EAST NANTMEAL TOWNSHIP AND WARWICK TOWNSHIP,

CHESTER COUNTY, PENNSYLVANIA

ISSUED: November 19, 2024

EFFECTIVE:

BY: Merle W. Stoltzfus, President
Elverson Water Company, Inc.
11 S. Pine Street
P.O. Box 20
Elverson, PA 19520
610-286-5116

NOTICE
THIS TARIFF SUPPLEMENT IMPLEMENTS THE COMPANY'S
LEAD SERVICE LINE REPLACEMENT PROGRAM

LIST OF CHANGES MADE BY THIS SUPPLEMENT

Change

Tariff Supplement No. 14 implements the Company's Lead Service Line Replacement Program, which (c)
addresses the Company's efforts to replace company-owned and customer-owned Lead Service Lines.

(c) denotes change

TABLE OF CONTENTS

	Page No.
Title Page	1
List of Changes	2
Table of Contents	3
PART I: SCHEDULE OF RATES AND CHARGES	4
Section A - Rates for Metered Service	4
Section B - Fire Protection Rates	5
Section C - Returned Check Charge	5
Section D - Construction Rates	5
Section E - Service Termination or Resumption Rates	5
Section F - Meter Test Rates	6
Section G - Bulk Water Sales	6
Section H - PENNVEST Surcharge	6A
PART II: DEFINITIONS	7
PART III: RULES AND REGULATIONS	10
Section A - Applications for Service	10
Section B - Construction and Maintenance of Facilities	11
Section C - Discontinuance, Termination and Restoration of Service	14
Section D - Meters	16
Section E - Billing and Collection	17
Section F - Deposits	19
Section G - Line Extensions	20
Section H - Fire Protection Service	23
Section I - Service Continuity	25
Section J - Waivers	26
Section K - Amendment of Commission Regulations	26
PART IV: WATER CONSERVATION CONTINGENCY PLAN	27
PART V: LEAD SERVICE LINE REPLACEMENT (LSLR) PROGRAM	29 (c)

PART V: LEAD SERVICE LINE REPLACEMENT (LSLR) PROGRAM

(1) Supersession

This section of the Company's tariff supersedes all other conflicting provisions of this tariff for purposes of implementing the Company's LSLR Program.

(2) Definitions

The following words and phrases, when used in Part V of this tariff, shall have the meanings assigned below unless the context clearly indicates otherwise:

Curb Stop: A water service shutoff valve located in a water service line near the curb or edge of the street and between the water main and the building.

Customer: A party contracting with an entity for service.

Customer-owned Lead Service Line (Customer-owned LSL): The portion of the lead service line extending from the curb, property line or entity connection to an entity's water meter or, if the entity's meter is located outside of the structure or water is not metered by the entity, at the first shutoff valve located within the interior of the structure.

Company: Elverson Water Company, Inc.

Company-owned Lead Service Line (Company-owned LSL): The portion of the lead service line extending from the Company's main to the Curb Stop.

Distribution system improvement charge (DSIC): The term as defined in 52 Pa. Code § 121.2.

Entity: A public utility as defined in 66 Pa.C.S. § 102 (relating to definitions) engaged in diverting, developing, pumping, impounding, distributing or furnishing water service to or for the public for compensation, a municipal corporation as defined in 52 Pa. Code § 65.52 (relating to definitions), and an authority as defined in 66 Pa.C.S. § 3201(1) (relating to definitions).

Galvanized service line: Iron or steel piping that has been dipped in zinc to prevent corrosion and rusting.

Independent Legal Restrictions: Commission regulations or Orders which otherwise prevent termination of water service at a property including but not limited to winter moratorium, medical certifications, or Commission directed moratoriums or suspensions.

Lead service line (LSL): A service line made of lead that connects the water main to a building inlet and a lead pigtail, gooseneck or other fitting that is connected to the lead line. A galvanized service line is considered a lead service line if it ever was or is currently downstream of any lead service line or service line of unknown material.

Lead service line replacement (LSLR): A service line, whether entity-owned or customer-owned, installed to replace a lead service line.

Lead service line replacement plan (LSLR Plan): A plan and supporting documents submitted to and approved by the Commission that specify how an entity intends to implement its lead service line replacement program.

Lead service line replacement program (LSLR Program): A program submitted to and approved by the Commission for the replacement of lead service lines by an entity.

Lead service line replacement project (LSLR Project): An entity-scheduled lead service line replacement activity either in conjunction with main replacements or as part of a lead service line replacement program.

Lead service line replacement project area (LSLR Project Area): The area encompassing an entity's scheduled lead service line replacement activities, which includes the area within a 1-mile radius of a lead service line replacement project if served by the entity.

LSLR Project Commencement: Installation of the first lead service line replacement within a lead service line replacement project area.

Partial lead service line replacement (Partial LSLR): A lead service line replacement that does not replace both the entity-owned and customer-owned portions of a lead service line.

Property Owner Agreement: An agreement between the Company and a property owner for the replacement of a customer-owned LSL that allows the Company's employees and contractors to gain access to their private property in order to replace their customer-owned LSL prior to the initiation of any work by the Company to replace the customer-owned LSL.

Service line: The pipe and appurtenances which connect any main to an entity's water meter or, if the entity's water meter is located outside of the structure or the connection is not metered by the entity, at the first shutoff valve located within the interior of the structure.

(3) LSLR Plan

Notwithstanding the Rules in this tariff relating to customer responsibility for customer service lines, the Company will replace customer-owned LSLs pursuant to its LSLR Program and LSLR Plan as initially approved by the Commission at Docket No. P-2024- , together with future Commission-approved updates. The Company may modify its annual cap for LSLRs with Commission approval.

The costs incurred by the Company to undertake remediation efforts pursuant to its LSLR Plan shall be recoverable in the Company's DSIC, PENNVEST Surcharge, and in base rates, as applicable.

The Company's LSLR Plan applies to any LSL serving any customer, the replacement of which is operationally feasible, and where the property owner authorizes the replacement or replaces the line in accordance with the Company's LSLR Program.

(4) LSLR Annual Cap

The Company will cap LSLR Projects at **2** customer-owned LSLRs on an annual basis. If a customer reimbursement provided pursuant to this tariff or an emergency LSLR causes the Company to exceed its annual cap, the Company will increase its current annual cap by the number of emergency repairs and/or reimbursements and decrease its annual cap by the same amount for the following year only.

(5) LSL Replacements

The Company will offer to replace customer-owned LSLs at no direct cost to the customer or property owner, if the customer is not the property owner: (i) at any residential or non-residential property where the Company replaces a Company-owned main connected to a customer-owned LSL; (ii) at any property where the Company replaces a company-owned LSL connected to a customer-owned LSL; and (iii) at any property with a private-side only LSL located within a LSLR Project Area where LSLRs are performed; (iv) when the Company's operations crew replaces a Company-owned facility regardless of material, in emergencies, including line breaks, leaks, or other unplanned emergency replacements, that is a LSL or that is connected to a LSL; (v) and any other circumstance as required to avoid the replacement of a partial LSL.

Except in the case of non-owner occupied properties at which the Company has received the customer's acceptance of the Company's offer to replace the customer-owned LSL as set forth in Section (7) below, the Company shall enter into a property owner Agreement with the property owner for replacement of a customer-owned LSL that allows the Company's employees and contractors to gain access to their private property in order to replace their customer-owned LSL prior to the initiation of any work by the Company to replace the customer-owned LSL. The Property Owner Agreement shall be in a form provided by the Company and shall include provisions that require property owners to release and hold harmless the Company from any and all claims, causes of action, damages or losses, of any nature, whatsoever with respect to the work performed by the Company or its contractors that are not covered by the Company's LSLR Program warranty.

(6) Customer Refusal

Except as set forth below, if after being notified of the Company's offer to replace at no cost a customer-owned LSL, the property owner has not provided an executed Property Owner Agreement authorizing the replacement of the customer service line or has refused replacement, the Company will (1) provide the customer and property owner, if the customer is not the property owner, with a complete disclosure of the known health hazards from the continued use of a LSL, (2) inform the customer or property owner, if

the customer is not the property owner, that refusal or failure to accept will require replacement of the customer-owned LSL, at the customer or property owner's expense, within 1 year from LSLR Project Commencement for the customer or property owner, if the customer is not the property owner, to be eligible for reimbursement, and (3) communicate to the customer and property owner, if the customer is not the property owner, that failure to allow the Company to complete the LSLR or to replace the customer-owned LSL concurrent with the Company replacing the Company-owned LSL will lead to termination of water service under the provisions of this tariff prior to the Company replacing the Company-Owned LSL.

If the customer or property owner, if the customer is not the property owner, does not sign the Property Owner Agreement or refuses replacement of the customer-owned LSL within ten days after the Company undertakes the aforementioned steps, the Company will require the customer or property owner, if the customer is not the property owner, to sign a form documenting their refusal. If the customer or property owner refuses or fails to sign the refusal form, the Company will make a record of and document the customer's refusal or failure to sign the refusal form. The Company will then schedule to replace its portion of the Company-owned LSL and notify the customer in writing of this replacement no later than ten days prior to the scheduled replacement and terminate water service at that location the day prior to replacing the Company-owned LSL. The Company will proceed with termination of water service to a location irrespective of whether Independent Legal Restrictions would otherwise delay or prohibit termination. Such notice and termination shall be deemed consistent with Chapter 14 of the Public Utility Code. Moreover, in these instances, the Company is not required to comply with termination procedures described in other portions of its tariff or the Commission's regulations.

At any time prior to completing termination, or, within ten days after termination, the property owner executes the Property Owner Agreement, water service will be restored to the property, provided that service will not be restored until either both the Company-owned LSL and the customer-owned LSL have been replaced or, in the Company's sole discretion, an alternative, non-lead temporary bypass is installed until both the Company-owned LSL and the customer-owned LSL have been replaced.

The Company will not connect an Applicant to water service where a property owner previously refused or failed to accept the Company's offer of a LSLR until the Applicant verifies the replacement of the customer-owned LSL by providing a paid invoice from a licensed contractor or a notarized statement from a licensed contractor attesting to completion of the LSLR.

(7) Service Line Demarcation

If a shutoff valve is not located within 12 inches of the structure wall of the property, the Company may install a shutoff valve during the LSLR to serve as a point of demarcation between the property's service line and the property's interior water distribution piping.

The Company shall perfect its ownership of the portion of the service line located within the then-existing right-of-way in conformance with its tariff to ensure that the Company can obtain necessary permits during the planning phase of a LSLR Project.

(8) Prohibition on Partial LSLRs and Notice Requirements

Neither a customer nor a property owner may install a Partial LSLR. A Partial LSLR installed after July 23, 2022, must result in termination of service until both the Company-owned LSL and customer-owned LSL have been replaced. The Company will proceed with immediate termination of water service to a location being served by a partial LSLR installed after July 23, 2022, irrespective of whether Independent Legal Restrictions would otherwise delay or prohibit termination. Such termination shall be deemed consistent with Chapter 14 of the Public Utility Code. Moreover, in these instances, the Company is not required to comply with termination procedures described in other portions of its tariff or the Commission's regulations.

Where a customer or a property owner, if the customer is not the property owner, elects to replace the customer-owned LSL, the customer or property owner shall replace the customer-owned LSL concurrent with the Company replacing the Company-owned LSL, provided that the customer or property owner, if the customer is not the property owner, provides the Company at least 180 days' notice prior to replacing the customer-owned LSL.

The Company shall not connect an Applicant for water service to the Company-owned service line at a property where a customer or property owner, if the customer is not the property owner, previously refused or failed to accept the Company's offer of a LSLR until the Applicant verifies the replacement of the customer-owned LSL by providing a paid invoice from a licensed contractor or a verified statement from a licensed contractor attesting to completion of the LSLR.

(9) Reimbursement

Where a customer or property owner, if the customer is not the property owner, has replaced its own customer-owned LSL, the customer or property owner shall submit to the Company a reimbursement form, which may be provided by the Company to a customer or property owner by mail or email upon request or on the Company's website, and which must be completed by the customer or property owner and provided to the Company by mail, email, fax, or hand delivery as specified by the Company on its reimbursement form, which contains, at a minimum, a detailed estimate and paid invoice from a licensed contractor verifying the replacement of the customer-owned LSL. Instead of a detailed estimate, a verified statement from the contractor attesting to completion of a LSLR may be sufficient in the Company's discretion. A paid invoice must be submitted.

Upon submission of the reimbursement form, the Company will review the information that was provided within 90 days of receiving the reimbursement form to determine eligibility for a reimbursement. If sufficient information has not been provided at the time of submitting the reimbursement form, the Company will contact the customer or property owner to request the necessary information to determine eligibility. The Company will have an additional 45 days from the time it receives the additional information to determine a customer's eligibility for reimbursement.

A customer or property owner, if the customer is not the property owner, is eligible to receive a reimbursement if the customer or property owner's service address is located within a LSLR Project Area and the customer-owned LSL is replaced within one year before or from LSLR Project Commencement. A customer or property owner, if the customer is not the property owner, located within a LSLR Project Area is eligible for a reimbursement of LSLR expenses up to 125% of the average cost the Company would have incurred to perform the replacement of a similarly-sized service line, not to exceed the actual cost to the customer or property owner.

Reimbursements will be paid directly to the customer or property owner, if the customer is not the property owner, through the issuance of a check. The Company will issue a check within 90 days after verifying that the customer or property owner is eligible for reimbursement.

(10) Warranty

For customer-owned LSLs replaced by the Company or its contractor, the Company will provide a two-year warranty for materials and workmanship of the Company's LSLR work, including the Company's restoration of surfaces consistent with this tariff, commencing from the date the LSLR is complete. This warranty shall cover repairs and replacements conducted by the Company or its contractor of the LSLR work up to a maximum warranty coverage amount of 125% of the Company's cost for the LSLR work, so long as the customer allows access to the property for repairs.

The warranty does not cover, among other things, damage caused by natural disasters, acts of God, fires, terrorism, excavation activities, acts of sabotage, or deliberate damage. The Company shall have no liability for any damages not covered by the warranty.

(11) Limitation of Liability

The Company's liability relating to LSLR efforts is limited as set forth in this tariff.

(12) Restoration

The Company will backfill to the previous grade any trenches excavated as part of the LSLR process and will fill and seal any wall or floor penetrations in the private home. The Company will restore roadways and sidewalks within the public right-of-way. No other restoration will be conducted for LSLRs. The Company will not replace any landscaping, interior finishes, paving, seeding, or walkways. All restoration costs shall be borne by the customer or property owner, if the customer is not the property owner, unless otherwise required by the Company's LSLR Program warranty.

(13) Ownership of Replacement Service Line

After a customer-owned LSL is replaced by the Company, the customer shall continue to own the customer portion of the Service Line and shall have full responsibility for the repair, replacement and maintenance of the new customer portion of the Service Line.

Appendix B

Data Responses to 52 Pa. Code § 53.52

Data Responses to 52 Pa. Code § 53.52

Part (a) Whenever a public utility, other than a canal, turnpike, tunnel, bridge or wharf company files a tariff, revision or supplement effecting changes in the terms and conditions of service rendered or to be rendered, it shall submit to the Commission, with the tariff, revision or supplement, statements showing all of the following:

(1) The specific reasons for each change.

Response: 52 Pa. Code § 65.51, et seq.

(2) The total number of customers served by the utility.

Response: 603

(3) A calculation of the number of customers, by tariff subdivision, whose bills will be affected by the change.

Response: 0

(4) The effect of the change on the utility's customers.

Response: See pro forma Tariff Supplement 14 included as Appendix A.

(5) The direct or indirect effect of the proposed change on the utility's revenue and expenses.

Response: Revenue - No effect.
Expenses - Elverson Water Company estimates costs of compliance of approximately \$5,000 for completion of the Service Line Inventory, Program Petition, and other associated costs and fees.

(6) The effect of the change on the service rendered by the utility.

Response: No effect; Elverson Water Company's system has no lead service lines.

(7) A list of factors considered by the utility in its determination to make the change. The list shall include a comprehensive statement about why these factors were chosen and the relative importance of each.

Response: N/A

(8) Studies undertaken by the utility in order to draft its proposed change.

Response: N/A

(9) Customer polls taken and other documents which indicate customer acceptance and desire for the proposed change. If the poll or other documents reveal discernible public opposition, an explanation of why the change is in the public interest shall be provided.

Response: N/A

(10) Plans the utility has for introducing or implementing the changes with respect to its ratepayers.

Response: Filing the required pro forma Tariff Supplement.

(11) Commission orders or rulings applicable to the filing.

Response: (a) *Rulemaking to Implement Act 120 of 2018 at 52 Pa. Code Chapters 65 and 66*, Docket No. L-2020-3019521 (Final Rulemaking Order entered Mar. 14, 2022)

Appendix C

Lead Service Line Replacement Plan

Lead Service Line Replacement Plan Requirements

52 Pa. Code § 65.56

(a) Service line inventory:

- (1) Entities subject to this chapter shall submit to the Commission a service line inventory that complies with United States Environmental Protection Agency regulation at 40 CFR 141.1—143.20 as enforced by the Department of Environmental Protection, inclusive of future changes as those regulations may be amended. Submit one electronic working copy and one hard copy of the Company’s current service line inventory in a worksheet format and specify the Petition appendices where this information is provided.

Response: See Appendix F and Appendix G.

- (2) Identify the assumptions that the entity used or will use in completing its service line inventory.

Response: No lead service lines exist within the system. All 603 service connections are material type Copper.

- (3) Until the inventory is complete, an entity shall provide detailed information regarding the progress of its service line inventory as part of its annual LSLR program report under § 65.59 (relating to LSLR program reports). Submit a statement acknowledging this requirement.

Response: Elverson Water Company acknowledges this requirement.

- (4) After an entity’s service line inventory is complete, it must be incorporated into the entity’s next LSLR plan update under § 65.57 (relating to periodic review of LSLR plan). Submit a statement acknowledging this requirement.

Response: Elverson Water Company acknowledges this requirement.

(b) Planning and replacements:

- (1) Provide the entity’s projected annual investment in LSLRs with an explanation of the entity’s anticipated sources of financing.

Response: Elverson Water Company does not expect any investment in replacing service lines because the Company believes there are no service lines present.

<p>(2) Provide the entity’s projected number of LSLRs per calendar year with an explanation of how the projection was determined and a statement that this number is consistent with the entity’s annual cap on LSLRs.</p>
<p>Response: N/A</p>
<p>(3) Identify the prioritization criteria considered by the entity when developing its LSLR schedule.</p>
<p>Response: N/A</p>
<p>(4) Provide an explanation of the entity’s processes and procedures to address emergency repairs or replacements which reveal LSLs.</p>
<p>Response: N/A</p>
<p>(5) Provide the entity’s processes and procedures to obtain acceptance of a LSLR prior to LSLR project commencement if the customer is the property owner, and the entity’s processes and procedures to obtain acceptance prior to LSLR project commencement if the customer is not the property owner</p>
<p>Response: See Appendix H.</p>
<p>(6) Provide the entity’s processes and procedures based upon acceptance of a LSLR, including:</p>
<p>(i) A copy of the consent agreement form by which the customer or property owner, if the customer is not the property owner, will authorize the LSLR. Specify the Petition appendices where this information is provided.</p>
<p>Response: See Appendix H.</p>
<p>(ii) A brief description of the entity’s process for LSLRs under normal conditions and under atypical conditions.</p>
<p>Response: N/A</p>
<p>(iii) An explanation of the entity’s process for coordination with the customer, and property owner, if the customer is not the property owner, and the information the entity will provide to the customer and the property owner throughout the LSLR process.</p>
<p>Response: See Appendix H and Appendix J.</p>


<p>(iv) The entity’s process for addressing LSLR completion or closeout, or both, with the customer and property owner, if the customer is not the property owner.</p>
<p>Response: See pro forma Tariff Supplement 14 included as Appendix A.</p>
<p>(7) Provide the entity’s lead/material recycling and disposal efforts, including a description of what the entity will do with proceeds from recycling and disposal efforts.</p>
<p>Response: N/A</p>
<p>(8) Provide a detailed explanation of the industry-accepted practices that the entity plans to use to replace entity-owned and customer-owned LSLs.</p>
<p>Response: N/A</p>
<p>(9) Provide a detailed explanation of how the entity’s acquisition of water distribution systems will be integrated into the entity’s efforts to complete LSLRs throughout its water distribution systems.</p>
<p>Response: N/A - No acquisitions are planned in the foreseeable future.</p>
<p>(10) Provide a copy of the entity’s procedure for documenting refusal of, or failure to accept, the offer by the entity to replace a LSL, including the entity’s duty to: (i) provide the customer and property owner, if the customer is not the property owner, with a complete disclosure of the known health hazards from the continued use of a LSL, (ii) inform the customer or property owner, if the customer is not the property owner, that refusal or failure to accept will require replacement of the customer-owned LSL, at the customer or property owner’s expense, within 1 year from LSLR project commencement for the customer or property owner, if the customer is not the property owner, to be eligible for reimbursement, and (iii) communicate to the customer and property owner, if the customer is not the property owner, that failure to allow the entity to complete the LSLR or to replace the customer-owned LSL concurrent with the entity replacing the entity-owned LSL will lead to termination of water service under the provisions of the entity’s tariff. Specify the Petition appendices where this information is provided.</p>
<p>Response: See Appendix J.</p>
<p>(c) Communications, outreach and education:</p>
<p>(1) Provide copies of all printed and broadcast material to be distributed under the entity’s LSLR program. Specify the Petition appendices where this information is provided.</p>
<p>Response: See Appendix H and Appendix J.</p>

Appendix D

Verification Statement

VERIFICATION STATEMENT

I, Merle W. Stoltzfus, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Signature: 
Title: PRESIDENT
Date: 11/18/2024

Sworn and subscribed before me this

18th day of November 2024

My Commission Expires Nov. 22, 2027

Commonwealth of Pennsylvania - Notary Seal
Keith A. DeWalt, Notary Public
Chester County
My commission expires November 22, 2027
Commission number 1038994
Member, Pennsylvania Association of Notaries


Signature of Official Administering Oath

Appendix E

Certificate of Service

CERTIFICATE OF SERVICE

I hereby certify that I have this day, the 19th day of November 2024, served a true copy of the foregoing documents upon the parties listed below in accordance with the requirements of §§ 1.54 (relating to service by a party) and 65.55(a) (relating to LSLR program requirements):


SERVED VIA ELECTRONIC MAIL

Bureau of Investigation & Enforcement
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120
akaster@pa.gov

Office of Consumer Advocate
555 Walnut Street
Forum Place, 5th Floor
Harrisburg, PA 17101
ra-oca@paoca.org

Office of Small Business Advocate
555 Walnut Street
Forum Place, 1st Floor
Harrisburg, PA 17101
ra-sba@pa.gov

Bureau of Technical Utility Services
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120
pzander@pa.gov, sdonnelly@pa.gov

Signature: 
Title: PRESIDENT
Date: 11/19/2024

Appendix F

Service Line Inventory Electronic Working Copy

An electronic working copy of the Company's Service Line Inventory is filed with the Commission's Secretary's Bureau electronically via the e-file system.

The electronic copy was uploaded via an Excel spreadsheet on 19 November 2024.

Appendix G

Service Line Inventory Hard Copy



Enter additional information in the "Comments" field

Answer not valid

Detailed Inventory

PWS Name: Elverson Water Company, Inc.

PWSID: 1150191

Unique Service Line ID is a required field

Export Location:

T:\poc1\FolderRedirection\wile\Desktop\PA_SLI\

Table with columns: Service Line Basic Information, System-Owned Portion of Service Line, and Information to Assign Tap Monitoring Tiering. Includes fields for Unique Service Line ID, Record Type, Date, Ownership Type, Street Address, City or Township, Zip Code, School, Childcare Facility, Material, Water Meter, Lead Pigeon, Installation Date, Installation Date Specific, Disrupter, Basis of Material, Basis of Material Classification, Date of Field Verification, Additional Comments, Service Line Connected To, POE Treatment Present?, Interior Building Plumbing Contaminant Lead Sampled?, and Current LCR Sampling Site?.



SERVICE LINE INVENTORY FORM

Enter additional information in the "Comments" field

Answer red valid

Detailed Inventory

PWS Name: Elverson Water Company, Inc.

PWSID: 1150191

Export Location:

T:\p01\FolderRedirection\wle\Desktop\PA_SLI\

Main data table with columns: Service Line Basic Information, System-Owned Portion of Service Line, Information to Assign Tap Monitoring Tiering. Includes fields for Unique Service Line ID, Record Type, Date, Ownership Type, Street Address, City or Township, Zip Code, School, Childcare Facility, Material, W. Mat. Eval., Lead Pigeon, Installation Date, Installation Date Specific, Disrupter, Basis of Material Classification, Basis of Material Classification - Non-Field Method, Basis of Material Classification - Field Method, Date of Field Verification, Additional Comments, Service Line Connected To, POE Treatment Present?, Interior Building Plumbing Contains Lead Solder?, Current LCR Sampling Site?



Enter additional information in the "Comments" field

Answer red void

Detailed Inventory

PWS Name: Elverson Water Company, Inc.

PWSID: 1150191

Unique Service Line ID is a required field

Export Location:

T:\p01\FolderRedirection\w\l\Desktop\PA_SLI

Main data table with columns: Service Line Basic Information, System-Owned Portion of Service Line, and Information to Assign Tap Monitoring Tiering. Includes fields for Unique Service Line ID, Record Type, Date, Ownership, Street Address, City or Township, Zip Code, School, Childcare Facility, Material, Material Classification, Installation Date, Installation Date Specific, Diameter, Basis of Material Classification, Basis of Material Classification - Non-Field Method, Date of Field Verification, Additional Comments, Service Line Connected To, POE Treatment Present?, Interior Building Plumbing Contains Lead Solder?, and Current LCR Sampling Site?.



Enter additional information in the "Comments" field

Answer red void

Detailed Inventory

PWS Name: Elverson Water Company, Inc.

PWSID: 1150191

Export Location:

Tapco1\Folder\Redirection\wfile\Desktop\PA_SLI

Service Line Basic Information										System-Owned Portion of Service Line										Information to Assign Tap Monitoring Tiering				
Unique Service Line ID (Required)	Record Type	Date Replacement Completed	Ownership Type	Street Address 1	Street Address 2	City or Township	Zip Code	School?	Childcare Facility?	Material	Was Material Ever Practically Lead?	Lead Pigeon, Resonant Connector (Upstream)	Installation Date Range	Installation Date Specific	Diameter (in. inch)	Basis of Material Classification - Non-Field Method	Basis of Material Classification - Non-Field Method	Basis of Material Classification - Field Method	Date of Field Verification	Additional Comments	Service Line Connected To	POE Treatment Present?	Interior Building Plumbing Contains Lead Solder?	Current LCR Sampling Site?
Initial	Joint									Select From List	No	Select From List	No		Non-Field method	Non-Field method	Field method			Select From List	Select From List	Select From List	No	No
25W-N0030T	Initial		System	30 West Sunnyside Drive		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2011	0.75	A) Records review					S) Single family residence	No	No	No
10A-N0030T	Initial		System	30 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					O) Building/Other	No	No	No
Q2S-W0030T	Initial		System	30 South Chestnut Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2006	0.75	A) Records review					S) Single family residence	No	No	No
01E-N0030T	Initial		System	30 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
11A-N0030T	Initial		System	30 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
22A-S0033T	Initial		System	24 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review					S) Single family residence	No	No	No
11A-S0003T	Initial		System	3 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
01W-S0029T	Initial		System	29 West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
15A-E0029T	Initial		System	29 Stoneridge Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
10A-S0029T	Initial		System	29 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q2S-E0029T	Initial		System	29 South Chestnut Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2006	0.75	A) Records review					S) Single family residence	No	No	No
01E-S0029T	Initial		System	29 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
51A-S2870T	Initial		System	2870 Ridge Road		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	1.00	A) Records review					O) Building/Other	No	No	No
01W-N0028T	Initial		System	28 West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
15A-W0028T	Initial		System	28 Stoneridge Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
10A-N0028T	Initial		System	28 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q2S-W0028T	Initial		System	28 South Chestnut Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2006	0.75	A) Records review					S) Single family residence	No	No	No
01E-N0028T	Initial		System	28 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
11A-N0028T	Initial		System	28 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
15A-E0027T	Initial		System	27 Stoneridge Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q2S-E0027T	Initial		System	27 South Chestnut Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2006	0.75	A) Records review					S) Single family residence	No	No	No
11A-S0027T	Initial		System	27 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
15A-W0026T	Initial		System	26 Stoneridge Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
10A-N0026T	Initial		System	26 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
22A-N0026T	Initial		System	26 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review					S) Single family residence	No	No	No
01E-N0026T	Initial		System	26 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
11A-N0026T	Initial		System	26 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
01W-S0025T	Initial		System	25 West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
15A-E0025T	Initial		System	25 Stoneridge Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
10A-S0025T	Initial		System	25 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
22A-N0025T	Initial		System	25 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review					S) Single family residence	No	No	No
01E-S0025T	Initial		System	25 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-E0249T	Initial		System	249 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					O) Building/Other	No	No	No
14A-W0246T	Initial		System	246 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-W0244T	Initial		System	244 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q3S-W0244T	Initial		System	244 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-E0243T	Initial		System	243 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q3S-E0243T	Initial		System	243 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-W0242T	Initial		System	242 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-E0241T	Initial		System	241 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q3S-E0241T	Initial		System	241 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-W0240T	Initial		System	240 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
01W-N0024T	Initial		System	24 West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
15A-W0024T	Initial		System	24 Stoneridge Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
10A-N0024T	Initial		System	24 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q3S-W0024T	Initial		System	24 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					O) Building/Other	No	No	No
22A-N0024T	Initial		System	24 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
01E-N0024T	Initial		System	24 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review					S) Single family residence	No	No	No
11A-N0024T	Initial		System	24 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-E0239T	Initial		System	239 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q3S-E0239T	Initial		System	239 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-W0238T	Initial		System	238 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-E0237T	Initial		System	237 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
Q3S-E0237T	Initial		System	237 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
14A-W0236T	Initial		System	236 Steeplechase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review					S) Single family residence	No	No	No
54A-N0236T	Initial		System	236 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No												



Enter additional information in the "Comments" field
Answer not valid

Detailed Inventory

PWS Name: Elverson Water Company, Inc.
PWSID: 1150191

Export Location:
T:\p01\FolderRedirection\wile\Desktop\PA_SLI\

Service Line Basic Information				System-Owned Portion of Service Line												Information to Assign Tap Monitoring Tiering								
Unique Service Line ID (Required)	Record Type	Date Replacement Completed	Ownership Type	Street Address 1	Street Address 2	City or Township	Zip Code	School?	Childcare Facility?	Material	Was Material Ever Previously Used?	Lead Pigeon, Resonance, Connector (Yes/No)	Installation Date Range	Installation Date Specific	Diameter (in. inch)	Basis of Material Classification - Non-Field Method	Basis of Material Classification - Non-Field Method	Basis of Material Classification - Field Method	Date of Field Verification	Additional Comments	Service Line Connected To	POE Treatment Present?	Interior Building Plumbing Contains Lead Solder?	Current LCR Sampling Site?
Initial	Joint							No	No	Select From List	No	No	Select From List			Non-Field method	Non-Field method	Field method			Select From List	Select From List	Select From List	No
03S-E0217T	Initial	System		217 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-S0217T	Initial	System		217 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-W0216T	Initial	System		216 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-N0216T	Initial	System		216 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-E0215T	Initial	System		215 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-W0214T	Initial	System		214 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-E0213T	Initial	System		213 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-S0213T	Initial	System		213 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-W0212T	Initial	System		212 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-N0212T	Initial	System		212 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-E0211T	Initial	System		211 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01W-S0209T	Initial	System		209 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-S0209T	Initial	System		209 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-E0207T	Initial	System		207 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
56A-N0206T	Initial	System		206 Privet Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2005	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-E0205T	Initial	System		205 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-S0205T	Initial	System		205 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
56A-N0205T	Initial	System		202 Privet Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2005	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-N0202T	Initial	System		202 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
54A-S0201T	Initial	System		201 Ironstone Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
10A-N0020T	Initial	System		20 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
04A-W0020T	Initial	System		20 Park Avenue		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2005	1.00	A) Records review		Field method			S) Single family residence	No	No	No
06A-W0020T	Initial	System		20 Hill Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2011	0.75	A) Records review		Field method			S) Single family residence	No	No	No
11A-N0020T	Initial	System		20 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
03S-E0020T	Initial	System		2 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
22A-N0020T	Initial	System		2 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01W-S0019T	Initial	System		19 West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
05S-E0019T	Initial	System		19 South Brick Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2001	0.75	A) Records review		Field method			S) Single family residence	No	No	No
22A-S0019T	Initial	System		19 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
07A-W0019T	Initial	System		19 Meadowview Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-S0019T	Initial	System		19 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
11A-S0019T	Initial	System		19 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01W-N0018B	Initial	System		18B West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01W-N0018A	Initial	System		18A West Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
10A-N0018T	Initial	System		18 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
22A-N0018T	Initial	System		18 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
07A-W0018T	Initial	System		18 Meadowview Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0018T	Initial	System		18 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
11A-N0018T	Initial	System		18 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0172T	Initial	System		172 East Main Street		Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0170T	Initial	System		170 East Main Street		Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
05S-E0017T	Initial	System		17 South Brick Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2001	0.75	A) Records review		Field method			S) Single family residence	No	No	No
22A-W0017T	Initial	System		17 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
07A-W0017T	Initial	System		17 Meadowview Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0166T	Initial	System		166 East Main Street		Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0160T	Initial	System		160 East Main Street		Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
10A-N0016T	Initial	System		16 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
02S-W0016T	Initial	System		16 South Chestnut Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2006	1.00	A) Records review		Field method			S) Single family residence	No	No	No
22A-N0016T	Initial	System		16 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
07A-W0016T	Initial	System		16 Meadowview Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0016T	Initial	System		16 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
11A-N0016T	Initial	System		16 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0158T	Initial	System		158 East Main Street		Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0156T	Initial	System		156 East Main Street	Apartment 2	Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0154T	Initial	System		154 East Main Street	Apartment 1	Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0154T	Initial	System		154 East Main Street	Apartment 1	Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
01E-N0150T	Initial	System		150 East Main Street	Apartment 1	Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review		Field method			S) Single family residence	No	No	No
05S-E0015T	Initial	System		15 South Brick Lane		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2001	0.75	A) Records review		Field method			S) Single family residence	No	No	No
22A-S0015T	Initial	System		15 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review		Field method			S) Single family residence	No	No	No
07A-W0015T	Initial	System		15 Meadowview Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
11A-S0015T	Initial	System		15 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review		Field method			S) Single family residence	No	No	No
25E-N0149T	Initial	System		149 East Sunnyside Drive		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2011	0.75	A) Records review		Field method			S) Single family residence	No	No	No
30A-E0142T	Initial	System		142 Wildflower Court		Elverson	19520	No	No	D) Copper	No	No	P) 2021 - 2030	2021	0.75	A) Records review		Field method			S) Single family residence	No	No	No
25E-N0141T	Initial	System		141 East Sunnyside Drive		Elverson	19520	No	No	D) Copper														



Enter additional information in the "Comments" field

Answer red void

Detailed Inventory

PWS Name: Elverson Water Company, Inc.

PWSID: 1150191

Export Location:

\\pco11f\FolderRedirection\wle\Desktop\PA_SLI

Service Line Basic Information				System-Owned Portion of Service Line														Information to Assign Tap Monitoring Tiering								
Unique Service Line ID (Required)	Record Type	Date Replacement Completed	Ownership Type	Street Address 1	Street Address 2	City or Township	Zip Code	School?	Childcare Facility?	Material	Was Material Ever Previously Used?	Lead Pkg. (lbs)	Lead Pkg. (lbs)	Installation Date Range	Installation Date Specific	Diameter (in. inch)	Basis of Material Classification - Non-Field Method	Basis of Material Classification - Field Method	Date of Field Verification	Additional Comments	Service Line Connected To	POE Treatment Present?	Interior Building Plumbing Contains Lead Solder?	Current LCR Sampling Site?		
Initial	Joint									Select From List	No	No	Select From List	No	No	No	Non-field method	Non-field method	Field method		Select From List	Select From List	Select From List	No	No	
Non-Lead	Yes	Tier 5	30A-W0125T	Initial	System	125 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-E0125T	Initial	System	125 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0125T	Initial	System	125 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0124T	Initial	System	124 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0124T	Initial	System	124 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0124T	Initial	System	124 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	30A-W0123T	Initial	System	123 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-E0123T	Initial	System	123 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0123T	Initial	System	123 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0122T	Initial	System	122 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0122T	Initial	System	122 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0122T	Initial	System	122 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	30A-W0121T	Initial	System	121 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	02S-E0121T	Initial	System	121 South Chestnut Street	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2018	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-E0121T	Initial	System	121 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0121T	Initial	System	121 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0120T	Initial	System	120 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0120T	Initial	System	120 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0120T	Initial	System	120 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	54A-E0120T	Initial	System	120 Ironstone Lane	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2007	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	10A-N0012T	Initial	System	12 Stable Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	22A-N0012T	Initial	System	12 Parkside Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2007	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	07A-E0012T	Initial	System	12 Meadowview Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	11A-N0012T	Initial	System	12 Churchill Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	30A-W0119T	Initial	System	119 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-E0119T	Initial	System	119 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0119T	Initial	System	119 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0118T	Initial	System	118 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0118T	Initial	System	118 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0118T	Initial	System	118 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	30A-W0117T	Initial	System	117 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-E0117T	Initial	System	117 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0117T	Initial	System	117 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0116T	Initial	System	116 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0116T	Initial	System	116 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0116T	Initial	System	116 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	30A-W0115T	Initial	System	115 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	02S-E0115T	Initial	System	115 South Chestnut Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2006	0.75	A	Records review		S	Single family residence	No	Not sure	No
Non-Lead	Yes	Tier 5	23N-E0115T	Initial	System	115 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0115T	Initial	System	115 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0114T	Initial	System	114 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0114T	Initial	System	114 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0114T	Initial	System	114 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	30A-W0113T	Initial	System	113 Wildflower Court	Elverson	19520	No	No	D	Copper	No	No	P	2021 - 2030	2021	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	02S-E0113T	Initial	System	113 South Chestnut Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2006	0.75	A	Records review		S	Single family residence	No	Not sure	No
Non-Lead	Yes	Tier 5	23N-E0113T	Initial	System	113 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	08A-S0113T	Initial	System	113 Derby Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	14A-W0112T	Initial	System	112 Steeplechase Drive	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2002	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	03S-W0112T	Initial	System	112 South Pine Street	Elverson	19520	No	No	D	Copper	No	No	M	2001 - 2010	2006	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	23N-W0112T	Initial	System	112 North Yeingst Drive	Elverson	19520	No	No	D	Copper	No	No	O	2011 - 2020	2011	0.75	A	Records review		S	Single family residence	No	No	No
Non-Lead	Yes	Tier 5	54A-E0112T	Initial	System	112 Ironstone Lane	Elverson	19520	No	No	D	Copper	No	No	M	2001										

Enter additional information in the "Comments" field
 Answer not valid
 Unique Service Line ID is a required field

Export Location:

\\azp01\Folder\Redirect\wfile\Desktop\PA_SLI

Detailed Inventory

PWS Name: Elverson Water Company, Inc.

PWSID: 1150191

Service Line Classification	Sufficient Evidence for Non-Lead?	LCR Sampling Tier
Answer all system & customer owned questions	Not Applicable	Answer all questions
Non-Lead	Yes	Tier 5
Non-Lead	Yes	Tier 5 (if not enough SFR & I)

Service Line Basic Information										System-Owned Portion of Service Line										Information to Assign Tap Monitoring Tiering			
Unique Service Line ID (Required)	Record Type	Date Replacement Completed	Ownership Type	Street Address 1	Street Address 2	City or Township	Zip Code	School?	Childcare Facility?	Material	Was Material Ever Replaced? (Previously Lead?)	Lead Pictal, Non-soldered Connector, Uglystream?	Installation Date Range	Installation Date Specific	Diameter (in inches)	Basis of Material Classification - Non-Field Method	Basis of Material Classification - Field Method	Date of Field Verification	Additional Comments	Service Line Connected To	POE Treatment Present?	Interior Building Plumbing Contains Lead Solder?	Current LCR Sampling Site?
Initial	Joint							No	No	Select From List	No	No	Select From List		Non-field method	Non-field method	Field method		Select From List	Select From List	Select From List	No	
14A-W0102T	Initial		System	102 Sleepchase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review			S) Single family residence	No	No	No	
03S-W0102T	Initial		System	102 South Pine Street		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review			O) Building/Other	No	No	No	
01E-N0102T	Initial		System	102 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
30A-W0101T	Initial		System	101 Wildflower Court		Elverson	19520	No	No	D) Copper	No	No	P) 2021 - 2030	2021	0.75	A) Records review			S) Single family residence	No	No	No	
14A-E0101T	Initial		System	101 Sleepchase Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review			S) Single family residence	No	No	No	
23N-E0101T	Initial		System	101 North Yeingst Drive		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2011	0.75	A) Records review			S) Single family residence	No	No	No	
01E-S0101T	Initial		System	101 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
08A-S0101T	Initial		System	101 Derby Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review			S) Single family residence	No	No	No	
26A-N0100T	Initial		System	101 Dengler Drive		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2011	0.75	A) Records review			S) Single family residence	No	No	No	
10A-N0010T	Initial		System	10 Stable Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review			S) Single family residence	No	No	No	
22A-N0010T	Initial		System	10 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review			S) Single family residence	No	No	No	
05N-W0010T	Initial		System	10 North Brick Lane	House	Elverson	19520	No	No	D) Copper	No	No	L) 1991 - 2000	1999	0.75	A) Records review			O) Building/Other	No	No	No	
01E-N00106	Initial		System	10 East Main Street		Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
01E-N00107	Initial		System	10 East Main Street	Del	Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
01E-N00105	Initial		System	10 East Main Street	Apartment 5	Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
01E-N00104	Initial		System	10 East Main Street	Apartment 4	Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
01E-N00103	Initial		System	10 East Main Street	Apartment 3	Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
01E-N00102	Initial		System	10 East Main Street	Apartment 2	Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
01E-N00101	Initial		System	10 East Main Street	Apartment 1	Elverson	19520	No	No	D) Copper	No	No	O) 2011 - 2020	2002	0.75	A) Records review			S) Single family residence	No	Not sure	No	
11A-N0010T	Initial		System	10 Churchill Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2002	0.75	A) Records review			S) Single family residence	No	No	No	
22A-S0001T	Initial		System	1 Parkside Drive		Elverson	19520	No	No	D) Copper	No	No	M) 2001 - 2010	2007	0.75	A) Records review			S) Single family residence	No	No	No	

Appendix H

LSLR Consent Agreement Form



**Elverson Water Company, Inc.
Lead Service Line Replacement Agreement**

This **LEAD SERVICE LINE REPLACEMENT AGREEMENT** ("Agreement") is made on the _____ day of _____, 20____ by and between **Elverson Water Company, Inc.** (the "Company") and _____, an adult individual or individuals with an address of _____ (the "Owner").

In consideration of the Company's efforts to identify and remove lead water service lines, the Owner represents and agrees as follows.

Owner holds title to the property located at _____ (the "Premises").

The Company's Tariff shall govern all terms and conditions not listed herein.

The Owner agrees and gives all necessary permission for the Company, including through its contractors, to:

- access Owner's water service line on the Premises for any necessary testing or inspection to determine the lead status of the line;
- enter any building located at the address above to collect a water sample at a time mutually agreeable to the Owner to test for lead in the water; and
- take all steps necessary to replace the water service line on the premises if a lead service line replacement is required by the Company's lead service line replacement program.

Owner – Signature

Company – Signature

Owner – Name

Company – Name

Date

Date

Appendix J

Company LSLR Refusal and Non-Acceptance Procedure



**Lead Service Line Replacement
Refusal and Non-Acceptance Form**

I DECLINE to have Elverson Water Company (the “Company”) address my privately-owned lead service line (“LSL”). I understand that lead is a toxic metal that can be harmful to human health even at low exposure levels. Lead is persistent, and it can accumulate in the human body over time. All persons, especially pregnant women, children, and infants, are vulnerable to the dangerous effects of lead in drinking water. More information on the harmful effects of lead in drinking water can be found at the following website maintained by the United States Environmental Protection Agency:

<https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>

I understand that my refusal or non-acceptance of the Company’s offer to replace my privately-owned LSL will require replacement of my LSL at my own expense within one (1) year from the date when work on my LSL would have begun in order for me to be eligible for reimbursement by the Company.

I further understand that my refusal or failure to allow the Company or its representative to replace my privately-owned LSL may lead to termination of my water service under the applicable provisions of the Company’s Tariff.

Owner – Signature

Property Address

Owner – Name

Phone Number

Date

Email