
Garrett P. Lent
Associate

glent@postschell.com
717-612-6032 Direct
717-731-1979 Direct Fax
File #: 208298

November 26, 2024

VIA ELECTRONIC FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
P.O. Box 3265
Harrisburg, PA 17105-3265

**Re: Letter of Notification Of PPL Electric Utilities Corporation, Filed Pursuant To 52 Pa. Code Chapter 57 Subchapter G, For Approval To Rebuild The Three Existing Sections of the Double-Circuit 230 kV Transmission Lines Connecting The UGI Utilities, Inc. Owned Mountain 230-69 kV Substation To The PPL Electric Owned Jenkins 230-69 kV Substation And Stanton 230-69kV Substation That Are Respectively Located In Luzerne County, Pennsylvania
Docket No. A-2024-3052129**

Dear Secretary Chiavetta:

Enclosed, on behalf of PPL Electric Utilities Corporation (“PPL Electric”), is information being supplied to the Pennsylvania Public Utility Commission’s (“Commission”) Bureau of Technical Utility Services (“TUS”) in response to TUS Set I Data Requests regarding the above-captioned proceeding. PPL Electric’s responses to these data requests include the following **CONFIDENTIAL** and **PROPRIETARY** attachments.

CONFIDENTIAL Attachment TUS-A-1

CONFIDENTIAL Attachment TUS-A-2

Each of these attachments contain **CONFIDENTIAL** and **PROPRIETARY** information and are being filed separately with the Commission via ShareFile.

Rosemary Chiavetta, Secretary
November 26, 2024
Page 2

**REQUEST FOR CONFIDENTIAL TREATMENT
OF PROPRIETARY INFORMATION**

Each of the above-referenced enclosures and marked **CONFIDENTIAL AND PROPRIETARY** because they contain commercially sensitive information, including, but not limited to, details about the condition of existing PPL Electric transmission structures and analysis of the same. PPL Electric requests that the copies of the materials that have been labeled **CONFIDENTIAL AND PROPRIETARY** be given confidential treatment by the Commission, including its various offices and bureaus. That is, PPL Electric requests that the confidential materials be excluded from the Commission's public document folder and that the confidential copies not be disclosed to the public.

If there are any questions concerning this matter, please contact me at the address or telephone number provided above.

Respectfully submitted,



Garrett P. Lent

GPL/dmc
Enclosures

cc: Jordan Van Order (*via email; w/attachments*)
Certificate of Service

WITNESS: Joseph B. Lookup

**PPL Electric Utilities Corporation
Response to Set I Data Requests of the
Bureau of Technical Utility Services
A-2024-3052129
Dated November 21, 2024**

A-1. Reference the Letter of Notification, Paragraph 25. Please provide a copy of the 2013 inspection report for the Mountain—Jenkins—Stanton 230 kV Transmission Line.

PPL
Response Please see the attached **CONFIDENTIAL** attachment A-1 for the 2013 steel structure inspection report for the Mountain-Jenkins-Stanton 230 kV Transmission Lines.

WITNESS: Joseph B. Lookup

**PPL Electric Utilities Corporation
Response to Set I Data Requests of the
Bureau of Technical Utility Services
A-2024-3052129
Dated November 21, 2024**

A-2. Reference the Letter of Notification, Paragraph 29. Please provide a copy of the inspection report for the Mountain—Jenkins—Stanton 230 kV Transmission Line.

PPL
Response Please see the attached **CONFIDENTIAL** attachment A-2 for the RTR Energy Solutions, Inc. Inspection Reports for the Mountain-Jenkins-Stanton 230 kV Transmission Lines.

WITNESS: Joseph B. Lookup

**PPL Electric Utilities Corporation
Response to Set I Data Requests of the
Bureau of Technical Utility Services
A-2024-3052129
Dated November 21, 2024**

A-3. Reference the Letter of Notification, Paragraph 22. Please clarify whether the total length of line to be rebuilt is approximately 18 miles or 18.3 miles.

PPL Response The total length of line to be rebuilt is approximately 18.3 miles. Within Paragraph 22 of the Letter of Notification, the stated total length of line to be rebuilt was rounded down to approximately 18 miles.

VERIFICATION

I, JOSEPH B. LOOKUP, being the Vice President – Transmission & Distribution Planning and Asset Management at PPL Services Corporation, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief and that I expect PPL Electric Utilities Corporation to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 relating to unsworn falsification to authorities.

Date: 11/26/2024


Joseph Lookup (Nov 26, 2024 15:45 EST)
Joseph B. Lookup