



10700 W. Main Road
North East, PA 16428
(814) 725-4302

December 11, 2024

RCVD PUC SEC BUR
DEC 13 2024 AM 11:05

Rosemary Chiavetta, Secretary

Secretary's Bureau
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

Dear Secretary Chiavetta,

North East Heat & Light Company ("NEHL") implemented its Frost Patrol plan between November 2023 and April 2024, as required by the Commission Order (M:2011-2271982) dated December 22, 2011. There was one leak on a steel main discovered by NEHL during the Frost Patrol. There were no leaks detected on wrought iron mains, steel service lines and service connections, and Medium Density Polyethylene service lines and service connections during the Frost Patrol.

The leak on the steel main was repaired with stainless steel leak clamp which was classified as Grade 3 in 2023-2024 Frost Patrol report.

If you have any questions about this report, please contact NEHL at (814) 725-4302.

Sincerely,

Shawn A. Hubbard
Field Technician
North East Heat & Light Company

N *North East
Heat & Light*

10700 West Main Rd, North East, PA 16428

ADDRESS SERVICE REQUESTED

Secretary's Bureau
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

PITTSBURGH PA 150
11 DEC 2024 PM 5 L



17120-007999

