

M-2025-3052787

## PUC Notification – Major Construction Report

### PECO Gas Projects Exceeding \$300,000

Notification Date: 2/13/2025

PA §59.38	Information Requested by PUC	Data Provided by PECO
1	<b>Description of Proposed Work</b> (e.g., replace 700' of 4" cast iron, new regulator station, etc.)	Install 1140ft of 6in plastic Install 166ft of 4in plastic Install 96ft of 2in plastic Renew/Transfer 28 services Retire 1160ft of 6in plastic Retire 71ft of 4in plastic Retire 230ft of 2in plastic Retire 3ft of 2in bare steel
	<b>City/Borough/Township and County</b>	Ambler Boro., Montgomery County
	<b>Extents of Project</b> (e.g., Main St. from 4th to 7th)	Ambler Rd from Bannockburn Ave to S/O Stuart Ln
2	<b>Type of Facility</b> (if other, please describe)	<input checked="" type="checkbox"/> Distribution Main/Services <input type="checkbox"/> Transmission Main <input type="checkbox"/> Regulator/Gate Station <input type="checkbox"/> Other: Click or tap here to enter text.
3	<b>Estimated Starting Date</b>	7/1/2025
4	<b>Estimated Completion Date</b>	9/30/2025
5	<b>Design Pressure</b>	MP-20
6	<b>Estimated Cost</b>	\$819,736
7	<b>Reporting Company</b> (name and address)	PECO, an Exelon Company 2301 Market St Philadelphia, PA 19103
8	<b>Project Contact</b> (name, address and phone number)	Evan DiPillo 300 Front St—Building #2 Conshohocken, PA 19428-2723 Phone: 267-533-0255
9	<b>Actual Completion Date</b> (to be sent after project complete)	