

M-2025-3052787

## PUC Notification – Major Construction Report

### PECO Gas Projects Exceeding \$300,000

Notification Date: 2/13/2025

PA §59.38	Information Requested by PUC	Data Provided by PECO
<b>1</b>	<b>Description of Proposed Work</b> (e.g., replace 700' of 4" cast iron, new regulator station, etc.)	Install 975ft of 4in plastic Renew/Transfer 22 services Retire 950ft of 4in ductile iron Retire 25ft of 2in ductile iron
	<b>City/Borough/Township and County</b>	Norwood Boro., Delaware County
	<b>Extents of Project</b> (e.g., Main St. from 4th to 7th)	Summit Ave and Mohawk Ave from Chester Pike to Seneca Ave
<b>2</b>	<b>Type of Facility</b> (if other, please describe)	<input checked="" type="checkbox"/> Distribution Main/Services <input type="checkbox"/> Transmission Main <input type="checkbox"/> Regulator/Gate Station <input type="checkbox"/> Other: Click or tap here to enter text.
<b>3</b>	<b>Estimated Starting Date</b>	5/5/2025
<b>4</b>	<b>Estimated Completion Date</b>	7/7/2025
<b>5</b>	<b>Design Pressure</b>	MP-20
<b>6</b>	<b>Estimated Cost</b>	\$406,342
<b>7</b>	<b>Reporting Company</b> (name and address)	PECO, an Exelon Company 2301 Market St Philadelphia, PA 19103
<b>8</b>	<b>Project Contact</b> (name, address and phone number)	Evan DiPillo 300 Front St—Building #2 Conshohocken, PA 19428-2723 Phone: 267-533-0255
<b>9</b>	<b>Actual Completion Date</b> (to be sent after project complete)	