

Joey T. Chen
Corporate CounselCell Phone (443) 683-1765
Fax (330) 315-9657
jchen@firstenergycorp.com

February 24, 2025

VIA ELECTRONIC FILINGRosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, Second Floor
Harrisburg, Pennsylvania 17120**Re: Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Grand Point-Guilford 138 Kilovolt Transmission Line Tap to Cider Press Substation Project in Guilford Township, Franklin County, Pennsylvania****Docket Nos. A-2025-3053251 & A-2025-3053293**

Dear Secretary Chiavetta:

Enclosed please find the responses of Keystone Appalachian Transmission Company (“KATCo”) and FirstEnergy Pennsylvania Electric Company (“FE PA”) to certain data requests issued by the Bureau of Technical Utility Services (“TUS”) via the Secretary’s letter, received on February 12, 2025, in the above-referenced matter.

Should you have any questions or concerns regarding this information, please feel free to contact me.

Sincerely,

Joey Chen
Attorney ID #334709
76 South Main Street
Akron, OH 44308
(610) 921-6784
jchen@firstenergycorp.com*Counsel for Keystone Appalachian Transmission Company
and FirstEnergy Pennsylvania Electric Company*

Enclosures

cc: Jordan Van Order – Bureau of Technical Utility Services (via electronic service)

Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Grand Point-Guilford 138 Kilovolt Transmission Line Tap to Cider Press Substation Project in Guilford Township, Franklin County, Pennsylvania

February 24, 2025

QUESTION A-1

Reference the Letter of Notification, Paragraph 8. Please explain whether Martin’s Famous Pastry Shoppe, Inc. is currently a customer of KATCo or FirstEnergy Pennsylvania Electric Company.

Response:

Martin’s Famous Pastry Shoppe, Inc. is an active distribution customer of FirstEnergy Pennsylvania Electric Company.

Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Grand Point-Guilford 138 Kilovolt Transmission Line Tap to Cider Press Substation Project in Guilford Township, Franklin County, Pennsylvania

February 24, 2025

QUESTION A-2

Reference the Letter of Notification, Paragraph 12. Please state the approximate height of the existing structure to be removed.

Response:

Existing Structure #31 has an above-ground height of approximately 67.5 feet.

Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Grand Point-Guilford 138 Kilovolt Transmission Line Tap to Cider Press Substation Project in Guilford Township, Franklin County, Pennsylvania

February 24, 2025

QUESTION A-3

Reference the Letter of Notification, Paragraph 27. Please provide a detailed explanation as to how the proposed cost allocation was determined. Additionally, please provide any relevant tariff references.

Response:

KATCo is a signatory to the PJM Open Access Transmission Tariff (“PJM OATT”)¹. Projects such as this one for new customer service fall under the Attachment M-3 process as a Supplemental Project (see PJM OATT, Attachment M-3)². It is KATCo’s business practice to assume cost responsibility for upgrades, new connection or installation of equipment along the networked path of its transmission system and located on the transmission side of the delivery point to the extent the facilities support the transmission network and are anticipated to benefit all customers connected to the network (“Network Costs”). For this Project, Network Costs include the modifications to the existing Grand Point-Guilford 138 kV Transmission Line and the span from the tap structure (Structure #31B) to Structure #31B-1, i.e., the transmission point of interconnection (POI#1). KATCo will seek recovery of these Network Costs in Network Transmission Rates in accordance with its formula rate (see PJM OATT Attachment H-34).

The remaining project costs are considered non-network, and the line extension charges to the End Customer, Martin’s Famous Pastry Shoppe, Inc. were determined in accordance with FE PA’s Electric Service Tariff. These components consist of: the radial tap line and 138 kV switch extending from the proposed Structure #31B-1 (owned by FE PA) into the End Customer’s Cider Press Substation (POI #2); and the integration of the End Customer’s protection and controls.

¹ KATCo does not have a separate, Pennsylvania-specific tariff that governs this Project.

² <https://agreements.pjm.com/oatt/31552>

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

:

JOINT LETTER OF NOTIFICATION OF :
KEYSTONE APPALACHIAN :
TRANSMISSION COMPANY AND :
FIRSTENERGY PENNSYLVANIA : **Docket Nos. A-2025-3053251 &**
ELECTRIC COMPANY FOR THE :
GRAND POINT-GUILFORD 138 : **A-2025-3053293**
KILOVOLT TRANSMISSION LINE TAP :
TO CIDER PRESS SUBSTATION :
PROJECT IN GUILFORD TOWNSHIP, :
FRANKLIN COUNTY, PENNSYLVANIA :

VERIFICATION

I, Colin Nahill, state that I am a Transmission Specialist II for FirstEnergy Service Company; that I am authorized to make this Verification on behalf of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company; and that the facts set forth are true and correct to the best of my knowledge, information and belief. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 (relating to unsworn falsification to authorities).

Date: February 24, 2025



Colin Nahill