

Joey T. Chen
Corporate CounselCell Phone (443) 683-1765
Fax (330) 315-9657
jchen@firstenergycorp.com

March 14, 2025

VIA ELECTRONIC FILINGRosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, Second Floor
Harrisburg, Pennsylvania 17120**Re: Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Grand Point-Guilford 138 Kilovolt Transmission Line Tap to Cider Press Substation Project in Guilford Township, Franklin County, Pennsylvania****Docket Nos. A-2025-3053251 & A-2025-3053293**

Dear Secretary Chiavetta:

Enclosed please find the responses of Keystone Appalachian Transmission Company (“KATCo”) and FirstEnergy Pennsylvania Electric Company (“FE PA”) to certain data requests issued by the Bureau of Technical Utility Services (“TUS”) via the Secretary’s letter, received on March 11, 2025, in the above-referenced matter.

Should you have any questions or concerns regarding this information, please feel free to contact me.

Sincerely,

Joey Chen
Attorney ID #334709
76 South Main Street
Akron, OH 44308
(610) 921-6784
jchen@firstenergycorp.com*Counsel for Keystone Appalachian Transmission Company
and FirstEnergy Pennsylvania Electric Company*

Enclosures

cc: Jordan Van Order – Bureau of Technical Utility Services (via electronic service)

Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Grand Point-Guilford 138 Kilovolt Transmission Line Tap to Cider Press Substation Project in Guilford Township, Franklin County, Pennsylvania

March 14, 2025

QUESTION A-4

Reference TUS Data Requests, Response to A-1. Please provide a detailed explanation as to why the current electric service provided to Martin's Famous Pastry Shoppe, Inc. is not sufficient to support the additional load.

Response:

Martin's Famous Pastry Shoppe, Inc.'s current load of 5.5 MVA is served from FirstEnergy Pennsylvania Electric Company's FE PA's distribution system at 12.47 kV. This system is not currently designed to provide adequate service for the additional load of 6.5 MVA requested by this customer for a total load of 12 MVA. The 11 MVA reference in paragraph 8 of the Letter of Notification should be revised to reflect a total customer requested load of 12 MVA.

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**JOINT LETTER OF NOTIFICATION
OF KEYSTONE APPALACHIAN
TRANSMISSION COMPANY AND
FIRSTENERGY PENNSYLVANIA
ELECTRIC COMPANY FOR THE
GRAND POINT-GUILFORD 138
KILOVOLT TRANSMISSION LINE
TAP TO CIDER PRESS SUBSTATION
PROJECT IN GUILFORD TOWNSHIP,
FRANKLIN COUNTY, PENNSYLVANIA**

:
:
:
: **Docket Nos. A-2025-3053251 &**
:
: **A-2025-3053293**
:
:
:
:
:

VERIFICATION

I, Colin Nahill, state that I am a Transmission Specialist II for FirstEnergy Service Company; that I am authorized to make this Verification on behalf of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company; and that the facts set forth are true and correct to the best of my knowledge, information and belief. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S. § 4904 (relating to unsworn falsification to authorities).

Date: March 14, 2025



Colin Nahill