

Morgan Lewis

Kenneth M. Kulak

Partner

+1.215.963.5384

ken.kulak@morganlewis.com

March 28, 2025

VIA ELECTRONIC FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
Harrisburg, PA 17120

**Re: Application of PECO Energy Company Filed Pursuant to 52 Pa. Code §§
57.71 *et seq.* for Approval of the Siting and Construction of the PJM 2022
Reliability Window # 3 Project Located in Peach Bottom Township, York
County, Pennsylvania and Petition for Waiver of 52 Pa. Code § 57.72(c)(10)
Docket Nos. A-2024-3051463 & P-2025-3053955**

Dear Secretary Chiavetta:

Enclosed for filing in the above-captioned proceeding is the Certificate of Service evidencing service of PECO Energy Company's Responses to the Data Requests of the Bureau of Technical Utility Services, Question Nos. A-1 to A-3.

As indicated on the enclosed Certificate of Service, copies have been served upon all parties of record.

If you have any questions, please call me directly at 215.963.5384.

Very truly yours,



Kenneth M. Kulak

KMK/ap

Enclosure

c: Per Certificate of Service (w/encls.)

Morgan, Lewis & Bockius LLP

2222 Market Street
Philadelphia, PA 19103
United States

T +1.215.963.5000
F +1.215.963.5001

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Application of PECO Energy Company :
Filed Pursuant to 52 Pa. Code §§ 57.71 *et* :
***seq.* for Approval of the Siting and :**
Construction of the PJM 2022 Reliability : **Docket Nos. A-2024-3051463**
Window # 3 Project Located in Peach : **P-2025-3053955**
Bottom Township, York County, :
Pennsylvania and Petition for Waiver of 52 :
Pa. Code § 57.72(c)(10) :

**RESPONSE OF PECO ENERGY COMPANY
TO DATA REQUESTS OF THE BUREAU OF TECHNICAL UTILITY SERVICES**

TUS-A-1:

Reference the Application, Paragraph 6. Please state the name of the entity that will pay for the proposed project.

RESPONSE:

PECO Energy Company will fund the upfront construction costs for the proposed Project. The costs for the Project will then be recovered through PECO's transmission rates based on PJM's allocation rules, which allocate costs based on load ratio share and by a solution-based distribution factor (also known as DFAX).

TUS-A-2:

Reference the Application, Paragraph 26. Please state the approximate width of the new and existing right-of-way for each of the proposed transmission lines.

RESPONSE:

The approximate widths of the new and existing rights-of-way for each of the proposed transmission lines of the Project are below.

	Approximate Proposed ROW Width (ft)						Total*
	5012	5014	5041	5042	5047	5056	
Cross Section #1	--	--	--	100	100	--	300
Cross Section #2	--	--	--	--	100	--	955
Cross Section #3	--	--	--	--	100	--	690
Cross Section #4	--	--	80	--	--	--	490
Cross Section #5	--	--	--	--	--	--	150
Cross Section #6	--	--	145	--	--	--	290
Cross Section #7	185	--	185	--	--	--	370

* The total width is composed of proposed transmission lines of the Project, as well as for the proposed transmission lines of the Brandon Shores Retirement Mitigation Project filed in Docket No. A-2024-3051467.

	Approximate Existing ROW Width (ft)						Total
	1T	2T	220-08	220-93	5012	5014	
Cross Section #1	--	--	--	140	160	--	300
Cross Section #2	--	--	200*	--	175	--	375
Cross Section #3	--	--	140	--	160	--	300
Cross Section #4	--	--	140	--	160	--	300
Cross Section #5	--	--	120	--	--	--	120
Cross Section #6	--	--	--	--	--	--	0
Cross Section #7	185	--	--	--	185	--	370

* Cooper Substation

Two proposed transmission lines are not included in the cross sections above:

- The existing 2T and proposed 5056 Line right-of-way width is 200 feet.
- The existing and proposed 5014 Line right-of-way width is 300 feet.

TUS-A-3:

Reference the Application, Paragraph 26. Please state the approximate height of the existing transmission structures to be removed.

RESPONSE:

Within the scope of the Project, existing transmission structures will only be removed for the existing 5012 Line, and the height of those existing structures is approximately 90 to 150 feet.

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Application of PECO Energy Company Filed :
Pursuant to 52 Pa. Code §§ 57.71 et seq. for :
Approval of the Siting and Construction of : Docket Nos. A-2024-3051463
the PJM 2022 Reliability Window # 3 Project : P-2025-3053955
Located in Peach Bottom Township, York :
County, Pennsylvania and Petition for :
Waiver of 52 Pa. Code § 57.72(c)(10) :**

VERIFICATION

I, William J. Patterer, hereby state the facts set forth are true and correct to the best of my knowledge, information and belief. I understand that the statements herein are made subject to the penalties of 18 Pa.C.S § 4904 (relating to unsworn falsification to authorities).

DATE: 3/27/2025



WILLIAM J. PATTERER
Vice President, Projects and Contracts

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Application of PECO Energy Company Filed :
Pursuant to 52 Pa. Code §§ 57.71 *et seq.* for :
Approval of the Siting and Construction of : Docket Nos. A-2024-3051463
the PJM 2022 Reliability Window # 3 Project : P-2025-3053955
Located in Peach Bottom Township, York :
County, Pennsylvania and Petition for :
Waiver of 52 Pa. Code § 57.72(c)(10) :**

CERTIFICATE OF SERVICE

I hereby certify and affirm that I have this day served a copy of the Responses of PECO Energy Company to Data Requests of the Bureau of Technical Utility Services (Public version) on the following persons in the manner specified in accordance with the requirements of 52 Pa. Code § 1.54:

VIA ELECTRONIC MAIL

Darryl A. Lawrence
Office of Consumer Advocate
555 Walnut Street
Forum Place – 5th Floor
Harrisburg, PA 17101-1921
dlawrence@paoca.org

Allison C. Kaster
Bureau of Investigation and Enforcement
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
akaster@pa.gov

Jordan Van Order
Bureau of Technical Utility Services
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
jvanorder@pa.gov

NazAarah Sabree
Office of Small Business Advocate
Suite 1102, Commerce Building
300 North Second Street
Harrisburg, PA 17101
nsabree@pa.gov

John F. Povilaitis
Alan M. Seltzer
Buchanan
409 N. Second Street, Suite 500
Harrisburg, PA 1710
john.povilaitis@bipc.com
alan.seltzer@bipc.com

Counsel for Transource Pennsylvania, LLC

Dated: March 28, 2025

Hector Garcia Santana
American Electric Power Service Corporation
1 Riverside Plaza, 29th Floor
Columbus, OH 43215
hgarcia1@aep.com

Counsel for Transource Pennsylvania, LLC



Kenneth M. Kulak
Morgan Lewis & Bockius LLP
2222 Market Street
Philadelphia, PA 19103-2921
(215) 963-5384
ken.kulak@morganlewis.com