



**COMMONWEALTH OF PENNSYLVANIA**  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
COMMONWEALTH KEYSTONE BUILDING  
400 NORTH STREET  
HARRISBURG, PENNSYLVANIA 17120

April 1, 2025

Docket No. A-2025-3054291

Utility Code: 110500

GARRETT P LENT  
POST & SCHELL P C  
17 NORTH SECOND STREET 12<sup>TH</sup> FLOOR  
HARRISBURG PA 17101-1601

Re: Letter of Notification of PPL Electric Utilities Corporation to Reconstruct the Fox Hill – Shawnee and Shawnee – Bushkill 230 kV Transmission Lines in Monroe County, Pennsylvania.

Dear Mr. Lent:

On March 28, 2025, PPL Electric Utilities Corporation (PPL Electric) filed a Letter of Notification for approval to reconstruct the Fox Hill – Shawnee and Shawnee – Bushkill 230 kV transmission lines in Monroe County, Pennsylvania. In order for us to complete our analysis of the subject application, the Bureau of Technical Utility Services requires answers to the enclosed data requests. This information is necessary for completion of our review of the filing.

Please forward the requested information to the Secretary of the Commission **within ten (10) days** of receipt of this letter. Failure to respond may result in the Letter of Notification being denied. As well, if PPL Electric has decided to withdraw its filing, please reply notifying the Commission of such a decision.

All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilings with the Secretary of the Commission by opening an efilings account through the Commission's website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilings system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response and mark the materials "CONFIDENTIAL" in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

The overnight address for hard-copy or confidential responses is:

Rosemary Chiavetta, Secretary  
Pennsylvania Public Utility Commission  
400 North Street, 2<sup>nd</sup> Floor  
Harrisburg, PA 17120

**Your answers should be verified per 52 Pa Code § 1.36.** Accordingly, you must provide the following statement with your responses:

*I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).*


Signature \_\_\_\_\_

Title \_\_\_\_\_

Date \_\_\_\_\_

In addition, to expedite analysis of the Letter of Notification, send a copy of your response to Jordan Van Order at [jvanorder@pa.gov](mailto:jvanorder@pa.gov). If any problems arise that prevent a full timely response or if any clarification of these data requests is needed, contact Jordan Van Order, Bureau of Technical Utility Services, at [jvanorder@pa.gov](mailto:jvanorder@pa.gov) (preferred) or 717-787-8763.

Sincerely,



Rosemary Chiavetta  
Secretary

Enclosure

**Bureau of Technical Utility Services**  
**Data Requests**  
Docket No. A-2025-3054291

- A-1 Reference the Letter of Notification, Paragraph 25. Please provide a copy of the Osmose inspection report.
- A-2 Reference the Letter of Notification, Paragraph 26. Please provide a copy of the third-party inspection report.
- A-3 Reference the Letter of Notification, Paragraph 27. Please provide a 5-year history of maintenance expenses on the subject transmission lines.
- A-4 Reference the Letter of Notification, Paragraph 28. Please provide the specific IEEE reference.
- A-5 Reference the Letter of Notification, Paragraph 35. Please provide the date(s) the proposed project was presented at the PJM TEAC meetings.
- A-6 Reference the Letter of Notification, Attachment 1, page 6. Please provide a detailed explanation as to why PPL Electric is replacing the six existing steel poles.
- A-7 Reference the Letter of Notification, Attachment 1, page 7. Please provide the approximate cost to apply protect coatings.
- A-8 Reference the Letter of Notification, Attachment 1, Section 5.0. Please explain whether advanced composite core conductors were considered as part of the solution. If not, please provide a detailed explanation as to why.
- A-9 Reference the Letter of Notification, Attachment 1, Section 5.0. Please explain whether dynamic line rating was considered as part of the solution. If not, please provide a detailed explanation as to why.
- A-10 Reference the Letter of Notification, Attachment 2, page 2. Please explain whether the existing 795 kcmil, 54/7 stranding, “Condor” ACSR conductor will remain on spans that will not be replaced. If so, please explain whether this conductor will be the capacity limiting section of the rebuilt line.
- A-11 Reference the Letter of Notification, Attachment 2, page 2, Please explain whether the proposed project will increase the capacity of the Fox Hill – Shawnee and Shawnee – Bushkill 230 kV lines. If so, please provide the capacity before and after the proposed project.