

April 4, 2025

VIA ELECTRONIC FILING

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

***Re: Completed Restoration of Momentary and Sustained Interruptions –
FirstEnergy Pennsylvania Electric Company; Docket No. M-2021-3023564***


Dear Secretary Chiavetta:

Pursuant to 52 Pa. Code § 67.1, FirstEnergy Pennsylvania Electric Company on behalf of West Penn Rate District (“West Penn”) submits written notification of completed restoration efforts following storm conditions that began on March 16, 2025 that caused multiple service interruptions in the West Penn service territory.

Attached please find the details relative to the impact of this recent outage event and the restoration activities that took place. It should be noted that the review and approval process of this outage information is still in progress at the time of filing this report and as such, all outage information contained in this report should be considered preliminary.

If you have any questions, please contact me at (610) 921-6202.

Sincerely,



Angelina Umstead

Enclosures

c: Dan Searfoorce - PaPUC Bureau of Technical Utility Services (via electronic mail)
Derek Ruhl - PaPUC Bureau of Technical Utility Services (via electronic mail)
John Van Zant - PaPUC Bureau of Technical Utility Services (via electronic mail)

ELECTRIC UTILITY REPORT OF OUTAGE TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU
P O BOX 3265
HARRISBURG, PA 17105-3265

1. Reporting Utility: FirstEnergy Pennsylvania Electric Company ("FE PA")
on behalf of West Penn Rate District ("West Penn")
Address: 800 Cabin Hill Drive
Greensburg, PA 15601

2. Name and title of person making report:

John Hawkins
(Name)

President Pennsylvania
(Title)

3. Telephone number: (330) 384-4795
(Telephone Number)

4. Date and time report was made to Commission:

March 16, 2025
(Date)

1808
(Time)

5. Interruption or Outage:

(a) Number of customers affected: 68,081 (Represents 9.4% of West Penn's total customers).

(b) Approximate number of outage cases and trouble cases for each county affected during event: See response to 5(c)

- (c) Approximate number of outages for each county affected during the event:

County	Outages	Outage Cases	Trouble Cases
Allegheny	3,517	49	64
Armstrong	1,587	56	88
Butler	1,737	28	31
Cameron	1,246	30	61
Centre	12,822	192	461
Clarion	37	9	13
Clinton	731	28	65
Elk	1,228	39	80
Fayette	18,880	234	359
Franklin	1,112	29	22
Fulton	1	1	3
Greene	3,826	56	76
Indiana	34	3	2
McKean	17	4	2
Potter	524	16	39
Washington	5,979	77	95
Westmoreland	14,803	221	410
Total	68,081	1,072	1,871

- (d) Approximate number of outage cases exceeding 6 or more hours in duration: 750

- (e) A listing of each outage case exceeding 6 or more hours in duration:
See Attachment A.

- (f) Reason for the interruption or outages: Beginning the morning of Saturday, March 15, 2025, a weather system began moving through Pennsylvania including the West Penn service territory, producing thunderstorms and wind gusts of approximately 44 miles per hour. In the morning hours of Sunday, March 16, 2025, several tornadoes and widespread non-tornadic wind damage occurred from an intense line of storms that crossed western Pennsylvania. Four tornadoes have been confirmed in Westmoreland and Centre Counties, with additional damage in Fayette County. The system produced storms with heavy precipitation and high winds of approximately 89 miles per hour. The persistent wind prolonged storm activity as well as restoration efforts, since crews cannot safely handle materials if winds exceed 30 mph, or operate bucket trucks if winds exceed 40 mph¹. This delay

¹ Per the Standard Number 1926.968, the Occupational Safety and Health Administration (“OSHA”) normally considers winds exceeding 64.4 kilometers per hour (40 miles per hour), or 48.3 kilometers per hour (30 miles per hour) if the work involves material handling, as a threshold that is likely to create hazards that jeopardize employee safety.

hampered restoration efforts as West Penn crews were not able to access its damaged infrastructure until the use of bucket trucks was resumed, and roads were cleared of debris and downed trees. See Attachment B for the maximum wind gusts for March 15 through March 18, tornado touch down locations and damage reports, and the 24-hour total precipitation for Sunday, March 16, 2025. In addition to the persistent wind, there were 32 sub-transmission outages which prolonged restoration.

Damage as a result of high winds included downed wires, damaged/broken poles, trees, and branches. The Latrobe, Jenette, Charleroi Jefferson, State College, St. Marys, Uniontown, and Pleasant Valley regions were the hardest hit areas. Approximately 62.2% of the total outages that occurred were tree related and an additional 15.0% were wind related.

Preliminary data indicates the reliability impact of the storm was 71.5 minutes of SAIDI, 0.09 of SAIFI, and an overall storm CAIDI of 763.6 minutes.

- (g) Projected time of restoration: It was estimated that the majority of customers would be restored by 2300 on Wednesday, March 19, 2025.

See Attachment C for the restoration curve and Attachment D for the order restoration graphs.

- (h) The number of utility workers, contract workers, and workers received as mutual aid assigned specifically to the repair work by general function:

Company	# of Workers	General Function
Asplundh Tree Expert, LLC	134	Forestry
Davey Tree Experts	5	Forestry
FirstEnergy Service Company	13	Forestry
Penn Line Services, Inc.	73	Forestry
Townsend Tree Service	12	Forestry
Subtotal	237	Forestry
Cleveland Electric Illuminating Co	4	Hazard Responder
FirstEnergy Service Company	66	Hazard Responder
Met-Ed Rate District	2	Hazard Responder
Ohio Edison Company	30	Hazard Responder
Penn Power Rate District	2	Hazard Responder
Toledo Edison Company	12	Hazard Responder
West Penn	71	Hazard Responder
Subtotal	187	Hazard Responder
Cleveland Electric Illuminating Co	7	Hazard Responder Support
FirstEnergy Service Company	26	Hazard Responder Support
Ohio Edison Company	1	Hazard Responder Support
West Penn	12	Hazard Responder Support
Subtotal	46	Hazard Responder Support
Agostino Utilities LLC	45	Line
Arc American	24	Line
Harlan Electric Co	4	Line
Haugland Energy Group LLC	32	Line
Henkels & McCoy	10	Line
I.B. Abel	73	Line
JW Didado	48	Line
Main Lite Electric	17	Line
Met-Ed Rate District	41	Line
NG Gilbert	22	Line
Penelec Rate District	9	Line

Company	# of Workers	General Function
Thayer PC	4	Line
Thompson Electric	19	Line
Valiant Energy Service	28	Line
West Penn	160	Line
Subtotal	536	Line
West Penn	9	Substation/Network
Subtotal	9	Substation/Network
Agostino Utilities LLC	2	Support
Arc American	2	Support
FirstEnergy Service Company	21	Support
Haugland Energy Group LLC	2	Support
Henkels & McCoy	1	Support
I.B. Abel	1	Support
JW Didado	1	Support
Main Lite Electric	1	Support
Met-Ed Rate District	2	Support
Thompson Electric	1	Support
Valiant Energy Service	2	Support
West Penn	4	Support
Subtotal	40	Support
Grand Total	1,055	

- (i) The date and time of the first information of a service interruption: March 15, 2025, at 1110.
- (j) The date and time that repair crews were assembled: March 15, 2025, at 1100.
- (k) The actual time that service was restored to the last affected customer: March 21, 2025, at 0649.

- (l) A general description of the physical damage sustained by the utility facilities as a result of the interruption/outage:

Equipment	Number
Primary Spans	538
Secondary Spans	71
Crossarms Replaced	423
Cutouts Replaced	248
Poles Replaced	179
Transformers Replaced	101
Wire & Cable Replaced (feet)	145,048

- (m) If the interruption/outage event was weather-related, the utility's weather reports, outlooks, or scenarios for the day before and the day of the interruption/outage event:

See Attachment E for the weather forecast reports.

- (n) If the interruption/outage event caused approximate outages that exceed 10% or more of the number of customers in the utility's entire service territory, rank the event in terms of the number and duration of outages and provide 2 comparable events, including the number and duration of outages for those comparable events.

The outages that were a result of this event did not exceed 10% or more of customers in the utility's entire service territory.

Remarks: The storm statistics contained in this report are preliminary. The review and approval of the storm statistics were still in progress as of the time this report was filed.

Attachment A: A listing of each outage case exceeding six or more hours in duration, including the following information²:

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
875614	Centre	57	6,710	03/16/2025 1459	03/21/2025 0649
875617	Centre	1	6,556	03/16/2025 1459	03/21/2025 0415
875821	Centre	2	6,544	03/16/2025 1459	03/21/2025 0403
871375	Centre	4	6,311	03/16/2025 1459	03/21/2025 0010
871624	Centre	1	5,802	03/16/2025 1519	03/20/2025 1601
863744	Centre	3	5,739	03/16/2025 1501	03/20/2025 1440
871662	Centre	1	5,701	03/16/2025 1459	03/20/2025 1400
868824	Clinton	1	5,622	03/16/2025 1526	03/20/2025 1308
865228	Centre	1	5,616	03/16/2025 1618	03/20/2025 1354
864061	Centre	1	5,611	03/16/2025 1517	03/20/2025 1248
868822	Clinton	1	5,574	03/16/2025 1540	03/20/2025 1234
864440	Centre	1	5,538	03/16/2025 1532	03/20/2025 1150
864471	Centre	4	5,511	03/16/2025 1535	03/20/2025 1126
870684	Centre	3	5,486	03/16/2025 1502	03/20/2025 1028
874989	Clinton	1	5,193	03/16/2025 1825	03/20/2025 0858
874727	Fayette	1	5,098	03/16/2025 1307	03/20/2025 0205
866222	Cameron	1	5,068	03/16/2025 1723	03/20/2025 0551
874726	Fayette	2	4,988	03/16/2025 1307	03/20/2025 0015
874725	Fayette	1	4,873	03/16/2025 1307	03/19/2025 2220
870037	Centre	1	4,667	03/17/2025 1034	03/20/2025 1621
867350	Fayette	3	4,650	03/16/2025 1307	03/19/2025 1837
874547	Fayette	6	4,604	03/16/2025 1338	03/19/2025 1822
864048	Centre	2	4,593	03/16/2025 1517	03/19/2025 1950
874622	Centre	4	4,584	03/16/2025 1520	03/19/2025 1944
866913	Centre	9	4,559	03/16/2025 1502	03/19/2025 1901
861992	Westmoreland	1	4,558	03/16/2025 1347	03/19/2025 1745
871727	Westmoreland	9	4,533	03/16/2025 1323	03/19/2025 1656
872186	Westmoreland	6	4,524	03/16/2025 1311	03/19/2025 1635
864123	Centre	1	4,510	03/16/2025 1520	03/19/2025 1830
867945	Centre	5	4,471	03/16/2025 1459	03/19/2025 1730
860516	Greene	2	4,456	03/16/2025 1311	03/19/2025 1527
870884	Centre	5	4,453	03/16/2025 1519	03/19/2025 1732
873166	Centre	1	4,448	03/16/2025 1427	03/19/2025 1635

² When applicable, the individual restoration steps for an order are provided for those customers that were out of service for 6 hours or more.

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
864122	Centre	9	4,430	03/16/2025 1520	03/19/2025 1710
860822	Westmoreland	1	4,421	03/16/2025 1319	03/19/2025 1500
870544	Fayette	11	4,421	03/16/2025 1257	03/19/2025 1438
873521	Clinton	1	4,401	03/16/2025 1529	03/19/2025 1650
868480	Greene	1	4,394	03/16/2025 1231	03/19/2025 1345
872189	Westmoreland	1	4,389	03/16/2025 1311	03/19/2025 1420
866994	Fayette	4	4,389	03/16/2025 1254	03/19/2025 1403
867166	Fayette	5	4,380	03/16/2025 1425	03/19/2025 1525
872227	Fayette	6	4,375	03/16/2025 1250	03/19/2025 1345
870166	Fayette	45	4,373	03/16/2025 1624	03/19/2025 1717
871562	Centre	3	4,356	03/16/2025 1514	03/19/2025 1550
867769	Centre	2	4,342	03/16/2025 1653	03/19/2025 1715
874368	Fayette	5	4,340	03/16/2025 1624	03/19/2025 1644
874309	Fayette	1	4,326	03/16/2025 1303	03/19/2025 1309
873812	Centre	1	4,321	03/16/2025 1510	03/19/2025 1511
867158	Fayette	3	4,317	03/16/2025 1303	03/19/2025 1300
873525	Clinton	63	4,301	03/16/2025 1523	03/19/2025 1504
860490	Fayette	1	4,296	03/16/2025 1311	03/19/2025 1247
863521	Cameron	1	4,294	03/16/2025 1502	03/19/2025 1436
870755	Fayette	1	4,292	03/16/2025 1428	03/19/2025 1400
868879	Fayette	2	4,286	03/16/2025 1304	03/19/2025 1230
860816	Westmoreland	2	4,271	03/16/2025 1319	03/19/2025 1230
863890	Centre	1	4,254	03/16/2025 1511	03/19/2025 1405
867780	Clinton	3	4,247	03/16/2025 2009	03/19/2025 1856
873390	Fayette	1	4,244	03/16/2025 1301	03/19/2025 1145
873286	Fayette	2	4,242	03/16/2025 1253	03/19/2025 1135
868817	Fayette	3	4,240	03/16/2025 1300	03/19/2025 1140
861823	Fayette	4	4,227	03/16/2025 1341	03/19/2025 1208
871663	Centre	31	4,220	03/16/2025 1459	03/19/2025 1319
867637	Westmoreland	2	4,218	03/16/2025 1637	03/19/2025 1455
868827	Centre	8	4,215	03/16/2025 1525	03/19/2025 1340
873360	Centre	5	4,207	03/16/2025 1511	03/19/2025 1318
864351	Cameron	3	4,207	03/16/2025 1528	03/19/2025 1335
873437	Centre	6	4,207	03/16/2025 1511	03/19/2025 1318
870774	Fayette	4	4,204	03/16/2025 1311	03/19/2025 1115
870995	Fayette	1	4,199	03/16/2025 1320	03/19/2025 1119
865247	Centre	8	4,190	03/16/2025 1619	03/19/2025 1409
873451	Elk	7	4,174	03/16/2025 1946	03/19/2025 1720

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
869923	Centre	1	4,173	03/16/2025 1522	03/19/2025 1255
862439	Westmoreland	1	4,173	03/16/2025 1405	03/19/2025 1138
874024	Fayette	8	4,169	03/16/2025 1311	03/19/2025 1040
873602	Westmoreland	24	4,166	03/16/2025 1342	03/19/2025 1108
873541	Westmoreland	2	4,150	03/16/2025 1325	03/19/2025 1035
864928	Fayette	3	4,139	03/16/2025 1600	03/19/2025 1259
872199	Cameron	3	4,129	03/16/2025 1456	03/19/2025 1145
862239	Fayette	3	4,128	03/16/2025 1356	03/19/2025 1044
871416	Centre	11	4,120	03/16/2025 1514	03/19/2025 1154
869167	Fayette	2	4,114	03/16/2025 1304	03/19/2025 0938
872614	Centre	2	4,111	03/16/2025 1839	03/19/2025 1510
866810	Fayette	1	4,103	03/16/2025 1333	03/19/2025 0956
868724	Centre	7	4,094	03/16/2025 1501	03/19/2025 1115
860334	Fayette	6	4,072	03/16/2025 1306	03/19/2025 0858
873604	Fayette	2	4,050	03/16/2025 1446	03/19/2025 1016
873738	Centre	3	4,040	03/16/2025 1755	03/19/2025 1315
864698	Centre	2	4,032	03/16/2025 1548	03/19/2025 1100
869203	Fayette	3	4,019	03/16/2025 1501	03/19/2025 1000
871854	Centre	32	4,001	03/16/2025 1459	03/19/2025 0940
862848	Elk	5	3,997	03/16/2025 1427	03/19/2025 0904
871066	Westmoreland	4	3,987	03/16/2025 2006	03/19/2025 1433
873432	Fayette	1	3,980	03/16/2025 1310	03/19/2025 0730
868012	Centre	1	3,954	03/16/2025 2046	03/19/2025 1440
864192	Centre	13	3,930	03/16/2025 1523	03/19/2025 0853
868120	Centre	5	3,928	03/16/2025 2108	03/19/2025 1436
867578	Centre	1	3,917	03/16/2025 1938	03/19/2025 1255
864699	McKean	1	3,895	03/16/2025 1548	03/19/2025 0843
860714	Westmoreland	9	3,871	03/16/2025 1316	03/19/2025 0547
867806	Westmoreland	1	3,868	03/16/2025 2012	03/19/2025 1240
870537	Westmoreland	1	3,815	03/16/2025 1921	03/19/2025 1056
873473	Potter	1	3,814	03/16/2025 1903	03/19/2025 1037
871203	Clinton	3	3,765	03/17/2025 0455	03/19/2025 1940
872108	Centre	1	3,743	03/17/2025 2326	03/20/2025 1349
859547	Fayette	2	3,726	03/16/2025 0929	03/18/2025 2335
872071	Fayette	21	3,681	03/16/2025 1246	03/19/2025 0207
861826	Westmoreland	8	3,653	03/16/2025 1341	03/19/2025 0234
873588	Elk	1	3,639	03/16/2025 1909	03/19/2025 0748
870672	Clinton	1	3,615	03/17/2025 0415	03/19/2025 1630

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
860428	Fayette	2	3,612	03/16/2025 1309	03/19/2025 0121
873434	Fayette	1	3,610	03/16/2025 1250	03/19/2025 0100
873308	Fayette	17	3,608	03/16/2025 1252	03/19/2025 0100
873787	Centre	15	3,530	03/16/2025 1510	03/19/2025 0200
864039	Cameron	4	3,504	03/16/2025 1516	03/19/2025 0140
866710	Fayette	9	3,499	03/16/2025 1246	03/18/2025 2305
869926	Centre	1	3,463	03/17/2025 1007	03/19/2025 1950
871572	Centre	1	3,453	03/16/2025 1510	03/19/2025 0043
873784	Centre	35	3,435	03/16/2025 1515	03/19/2025 0030
873350	Fayette	1	3,409	03/16/2025 1246	03/18/2025 2135
857955	Fayette	2	3,383	03/16/2025 0944	03/18/2025 1807
868890	Centre	3	3,351	03/17/2025 0439	03/19/2025 1230
873184	Westmoreland	9	3,345	03/16/2025 1330	03/18/2025 2115
868839	Centre	5	3,343	03/17/2025 0357	03/19/2025 1140
869326	Centre	2	3,329	03/17/2025 0801	03/19/2025 1530
869348	Westmoreland	43	3,321	03/17/2025 0810	03/19/2025 1531
868721	Westmoreland	14	3,309	03/16/2025 1306	03/18/2025 2015
869209	Centre	2	3,304	03/17/2025 0726	03/19/2025 1430
863803	Cameron	2	3,291	03/16/2025 1509	03/18/2025 2200
873179	Fayette	17	3,287	03/16/2025 1247	03/18/2025 1934
866298	Fayette	4	3,287	03/16/2025 1243	03/18/2025 1930
866708	Fayette	23	3,280	03/16/2025 1250	03/18/2025 1930
873606	Fayette	1	3,278	03/16/2025 1312	03/18/2025 1950
873590	Fayette	201	3,275	03/16/2025 1239	03/18/2025 1914
872329	Westmoreland	11	3,269	03/16/2025 1316	03/18/2025 1945
873732	Cameron	2	3,266	03/16/2025 1513	03/18/2025 2139
860503	Fayette	14	3,265	03/16/2025 1311	03/18/2025 1936
870697	Fayette	1	3,256	03/16/2025 1251	03/18/2025 1907
859603	Fayette	46	3,253	03/16/2025 1244	03/18/2025 1857
872926	Fayette	87	3,248	03/16/2025 1252	03/18/2025 1900
863963	Cameron	4	3,247	03/16/2025 1513	03/18/2025 2120
866962	Fayette	114	3,246	03/16/2025 1239	03/18/2025 1845
874258	Cameron	20	3,240	03/17/2025 0823	03/19/2025 1423
873570	Allegheny	5	3,239	03/16/2025 1313	03/18/2025 1912
868474	Fayette	1	3,235	03/16/2025 2248	03/19/2025 0443
862697	Elk	2	3,222	03/16/2025 1418	03/18/2025 2000
868789	Fayette	3	3,220	03/16/2025 1247	03/18/2025 1827
873609	Fayette	1	3,219	03/16/2025 1411	03/18/2025 1950

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
873311	Centre	1	3,218	03/16/2025 1437	03/18/2025 2015
873309	Fayette	1	3,218	03/16/2025 1252	03/18/2025 1830
873321	Fayette	3	3,217	03/16/2025 1252	03/18/2025 1829
872032	Fayette	113	3,212	03/16/2025 1306	03/18/2025 1838
870295	Fayette	11	3,206	03/16/2025 1310	03/18/2025 1836
867351	Washington	1	3,197	03/16/2025 1243	03/18/2025 1800
864147	Elk	1	3,189	03/16/2025 1521	03/18/2025 2030
872510	Westmoreland	8	3,185	03/16/2025 1228	03/18/2025 1733
871962	Cameron	40	3,185	03/16/2025 1455	03/18/2025 2000
868720	Fayette	25	3,183	03/16/2025 1238	03/18/2025 1741
868436	Fayette	40	3,179	03/16/2025 1243	03/18/2025 1742
858161	Fayette	20	3,172	03/16/2025 1126	03/18/2025 1618
868662	Westmoreland	2	3,171	03/16/2025 1334	03/18/2025 1825
867129	Centre	37	3,167	03/16/2025 1509	03/18/2025 1956
872667	Westmoreland	1	3,152	03/16/2025 1325	03/18/2025 1757
865078	Potter	24	3,148	03/16/2025 1452	03/18/2025 1920
868141	Fayette	11	3,147	03/16/2025 1240	03/18/2025 1707
866181	Fayette	6	3,141	03/16/2025 1257	03/18/2025 1718
866376	Fayette	2	3,134	03/16/2025 1254	03/18/2025 1708
872878	Fayette	23	3,133	03/16/2025 1302	03/18/2025 1715
873654	Centre	4	3,130	03/16/2025 1515	03/18/2025 1925
861005	Fayette	1	3,124	03/16/2025 1323	03/18/2025 1727
872269	Fayette	22	3,124	03/16/2025 1248	03/18/2025 1652
864089	Centre	9	3,116	03/16/2025 1519	03/18/2025 1915
860172	Fayette	6	3,115	03/16/2025 1300	03/18/2025 1655
873180	Fayette	6	3,112	03/16/2025 1253	03/18/2025 1645
860178	Fayette	9	3,111	03/16/2025 1301	03/18/2025 1652
872270	Fayette	11	3,111	03/16/2025 1248	03/18/2025 1639
862881	Fayette	7	3,106	03/16/2025 1429	03/18/2025 1815
873138	Greene	12	3,105	03/16/2025 1235	03/18/2025 1620
868702	Centre	39	3,104	03/16/2025 1515	03/18/2025 1859
862497	Westmoreland	7	3,102	03/16/2025 1407	03/18/2025 1749
873530	Clinton	2	3,092	03/16/2025 1523	03/18/2025 1855
868824	Clinton	13	3,089	03/16/2025 1526	03/18/2025 1855
872953	Fayette	293	3,088	03/16/2025 1252	03/18/2025 1620
869932	Fayette	30	3,087	03/16/2025 1257	03/18/2025 1624
868772	Greene	16	3,084	03/16/2025 1234	03/18/2025 1558
871358	Fayette	1	3,081	03/16/2025 2204	03/19/2025 0125

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
866709	Fayette	143	3,080	03/16/2025 1250	03/18/2025 1610
862860	Westmoreland	1	3,078	03/16/2025 1341	03/18/2025 1659
870300	Westmoreland	5	3,071	03/16/2025 1338	03/18/2025 1649
864875	Fayette	1	3,067	03/16/2025 1558	03/18/2025 1905
863930	Cameron	18	3,065	03/16/2025 1512	03/18/2025 1817
863327	Potter	7	3,064	03/16/2025 1456	03/18/2025 1800
871061	Clinton	213	3,063	03/16/2025 1523	03/18/2025 1826
870237	Centre	10	3,059	03/16/2025 1511	03/18/2025 1810
861273	Fayette	3	3,059	03/16/2025 1327	03/18/2025 1626
859699	Fayette	94	3,059	03/16/2025 1247	03/18/2025 1546
873732	Cameron	3	3,047	03/16/2025 1513	03/18/2025 1800
863000	Elk	42	3,047	03/16/2025 1436	03/18/2025 1723
862410	Westmoreland	5	3,039	03/16/2025 1404	03/18/2025 1643
861121	Westmoreland	6	3,038	03/16/2025 1325	03/18/2025 1603
871851	Fayette	3	3,035	03/16/2025 1253	03/18/2025 1528
863960	Centre	5	3,035	03/16/2025 1513	03/18/2025 1748
871904	Centre	8	3,033	03/16/2025 1507	03/18/2025 1740
871888	Centre	13	3,033	03/16/2025 1527	03/18/2025 1800
867342	Fayette	35	3,031	03/16/2025 1254	03/18/2025 1525
863326	Potter	26	3,027	03/16/2025 1456	03/18/2025 1723
872659	Fayette	9	3,026	03/16/2025 1244	03/18/2025 1510
872564	Centre	1	3,025	03/16/2025 0835	03/18/2025 1100
857846	Centre	29	3,025	03/16/2025 0835	03/18/2025 1100
861667	Westmoreland	4	3,024	03/16/2025 1337	03/18/2025 1601
859142	Greene	31	3,019	03/16/2025 1235	03/18/2025 1454
873655	Centre	10	3,017	03/16/2025 1933	03/18/2025 2150
859842	Fayette	245	3,016	03/16/2025 1251	03/18/2025 1507
873056	Fayette	139	3,015	03/16/2025 1238	03/18/2025 1453
869963	Greene	31	3,012	03/16/2025 1242	03/18/2025 1454
868335	Fayette	19	3,011	03/16/2025 1302	03/18/2025 1513
863269	Potter	2	3,009	03/16/2025 1453	03/18/2025 1702
873181	Westmoreland	49	3,008	03/16/2025 1325	03/18/2025 1533
863288	Cameron	2	3,000	03/16/2025 1454	03/18/2025 1654
865014	Elk	3	2,997	03/16/2025 1606	03/18/2025 1803
861246	Fayette	1	2,995	03/16/2025 1327	03/18/2025 1522
873044	Fayette	3	2,986	03/16/2025 1544	03/18/2025 1730
869070	Westmoreland	13	2,985	03/16/2025 1315	03/18/2025 1500
863009	Centre	28	2,983	03/16/2025 1437	03/18/2025 1620

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
860336	Fayette	12	2,983	03/16/2025 1306	03/18/2025 1449
865066	Fayette	5	2,982	03/16/2025 1255	03/18/2025 1437
873476	Centre	1	2,979	03/18/2025 1738	03/20/2025 1917
872607	Fayette	19	2,978	03/16/2025 1257	03/18/2025 1435
872177	Fayette	31	2,970	03/16/2025 0054	03/18/2025 0224
870262	Elk	1	2,964	03/17/2025 1142	03/19/2025 1306
868566	Potter	42	2,960	03/16/2025 1504	03/18/2025 1624
867391	Greene	1	2,954	03/16/2025 1306	03/18/2025 1420
872156	Centre	18	2,952	03/16/2025 1513	03/18/2025 1625
872605	Centre	3	2,944	03/18/2025 0956	03/20/2025 1100
863174	Elk	5	2,943	03/16/2025 1447	03/18/2025 1550
871972	Westmoreland	2	2,940	03/16/2025 1228	03/18/2025 1328
870633	Elk	10	2,940	03/16/2025 1424	03/18/2025 1524
868600	Fayette	299	2,940	03/16/2025 1252	03/18/2025 1352
868780	Fayette	9	2,939	03/16/2025 1247	03/18/2025 1346
868554	Westmoreland	42	2,938	03/16/2025 1325	03/18/2025 1423
862288	Fayette	11	2,933	03/16/2025 1359	03/18/2025 1452
871973	Westmoreland	4	2,927	03/16/2025 1228	03/18/2025 1315
864109	Clinton	35	2,923	03/16/2025 1519	03/18/2025 1602
864729	Westmoreland	6	2,919	03/16/2025 1330	03/18/2025 1409
870896	Greene	3	2,910	03/16/2025 1648	03/18/2025 1718
860454	Fayette	1	2,896	03/16/2025 1310	03/18/2025 1326
858200	Fayette	21	2,894	03/16/2025 0931	03/18/2025 0945
867421	Fayette	4	2,891	03/16/2025 1919	03/18/2025 1930
867336	Greene	13	2,881	03/16/2025 1237	03/18/2025 1238
860363	Westmoreland	14	2,881	03/16/2025 1307	03/18/2025 1308
864380	Centre	9	2,875	03/16/2025 1530	03/18/2025 1525
868688	Centre	21	2,870	03/16/2025 1452	03/18/2025 1442
860063	Fayette	16	2,865	03/16/2025 1257	03/18/2025 1242
871815	Westmoreland	19	2,861	03/16/2025 1319	03/18/2025 1300
860124	Fayette	12	2,854	03/16/2025 1258	03/18/2025 1232
867379	Greene	195	2,850	03/16/2025 1235	03/18/2025 1205
862819	Elk	17	2,849	03/16/2025 1425	03/18/2025 1354
861038	Fayette	28	2,846	03/16/2025 1324	03/18/2025 1250
872276	Allegheny	12	2,841	03/16/2025 1250	03/18/2025 1211
859828	Allegheny	10	2,841	03/16/2025 1250	03/18/2025 1211
872180	Fayette	248	2,834	03/16/2025 1252	03/18/2025 1206
869098	Washington	2	2,827	03/16/2025 1253	03/18/2025 1200

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
861382	Westmoreland	64	2,824	03/16/2025 1329	03/18/2025 1233
872690	Allegheny	3	2,823	03/16/2025 1317	03/18/2025 1220
868131	Allegheny	8	2,823	03/16/2025 1317	03/18/2025 1220
868328	Allegheny	11	2,823	03/16/2025 1317	03/18/2025 1220
863599	Centre	22	2,816	03/16/2025 1504	03/18/2025 1400
871448	Washington	4	2,814	03/16/2025 1244	03/18/2025 1138
867840	Elk	9	2,793	03/16/2025 1556	03/18/2025 1429
870769	Elk	41	2,791	03/16/2025 1420	03/18/2025 1251
872764	Westmoreland	15	2,787	03/16/2025 1323	03/18/2025 1150
861299	Washington	5	2,785	03/16/2025 1328	03/18/2025 1153
863025	Centre	6	2,780	03/16/2025 1438	03/18/2025 1258
869263	Centre	27	2,780	03/16/2025 1438	03/18/2025 1258
871638	Centre	5	2,778	03/16/2025 1520	03/18/2025 1338
873202	Centre	1	2,777	03/16/2025 1751	03/18/2025 1608
868848	Fayette	1	2,771	03/17/2025 1346	03/19/2025 1157
868841	Fayette	14	2,767	03/16/2025 1303	03/18/2025 1110
858198	Fayette	21	2,765	03/16/2025 1140	03/18/2025 0945
861601	Westmoreland	13	2,756	03/16/2025 1334	03/18/2025 1130
871516	Fayette	32	2,753	03/16/2025 1254	03/18/2025 1047
858517	Greene	9	2,749	03/16/2025 1211	03/18/2025 1000
874217	McKean	2	2,748	03/17/2025 1411	03/19/2025 1159
862762	Elk	16	2,743	03/16/2025 1423	03/18/2025 1206
863711	Centre	4	2,738	03/17/2025 1730	03/19/2025 1508
860316	Fayette	10	2,735	03/16/2025 1305	03/18/2025 1040
866678	Greene	6	2,732	03/16/2025 1508	03/18/2025 1240
866722	Centre	26	2,727	03/16/2025 1503	03/18/2025 1230
869190	Centre	13	2,721	03/16/2025 1516	03/18/2025 1237
859766	Washington	10	2,720	03/16/2025 1249	03/18/2025 1009
866818	Westmoreland	5	2,711	03/16/2025 1323	03/18/2025 1034
872629	Washington	1	2,700	03/16/2025 1317	03/18/2025 1017
872152	Potter	42	2,700	03/16/2025 1521	03/18/2025 1221
868960	Centre	7	2,699	03/16/2025 1501	03/18/2025 1200
872517	Westmoreland	1	2,696	03/16/2025 1349	03/18/2025 1045
862820	Elk	24	2,694	03/16/2025 1426	03/18/2025 1120
871814	Westmoreland	47	2,692	03/16/2025 1319	03/18/2025 1011
868342	Westmoreland	7	2,690	03/16/2025 1325	03/18/2025 1015
866185	Fayette	19	2,688	03/16/2025 1306	03/18/2025 0954
869546	Fayette	7	2,682	03/16/2025 2009	03/18/2025 1651

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
871060	Westmoreland	2	2,679	03/16/2025 1921	03/18/2025 1600
859838	Fayette	29	2,633	03/16/2025 1250	03/18/2025 0843
860438	Fayette	7	2,633	03/16/2025 1310	03/18/2025 0903
871886	Fayette	3	2,623	03/16/2025 1247	03/18/2025 0830
862823	Elk	48	2,620	03/16/2025 1426	03/18/2025 1006
865644	Cameron	1	2,618	03/16/2025 1642	03/18/2025 1220
868552	Westmoreland	39	2,611	03/16/2025 1325	03/18/2025 0856
868920	Greene	12	2,609	03/17/2025 0511	03/19/2025 0040
870912	Elk	1	2,604	03/16/2025 1414	03/18/2025 0938
872478	Centre	6	2,595	03/17/2025 1648	03/19/2025 1203
864643	Centre	9	2,593	03/16/2025 1545	03/18/2025 1058
866186	Westmoreland	10	2,593	03/16/2025 1349	03/18/2025 0902
869587	Westmoreland	37	2,580	03/16/2025 1417	03/18/2025 0917
872173	Westmoreland	2	2,549	03/16/2025 1822	03/18/2025 1251
872248	Westmoreland	20	2,479	03/16/2025 1316	03/18/2025 0635
869547	Fayette	1	2,478	03/17/2025 0919	03/19/2025 0237
862706	Westmoreland	25	2,471	03/16/2025 1419	03/18/2025 0730
872219	Clinton	2	2,402	03/18/2025 0210	03/19/2025 1812
863269	Potter	22	2,398	03/17/2025 0104	03/18/2025 1702
872110	Washington	10	2,366	03/16/2025 1244	03/18/2025 0410
867087	Greene	14	2,363	03/16/2025 1852	03/18/2025 1015
866972	Centre	1	2,356	03/16/2025 1839	03/18/2025 0955
869226	Fayette	1	2,349	03/17/2025 0733	03/18/2025 2242
869918	Greene	6	2,345	03/16/2025 2205	03/18/2025 1310
872072	Fayette	32	2,322	03/16/2025 1248	03/18/2025 0330
868649	Greene	1	2,308	03/17/2025 0039	03/18/2025 1507
869269	Centre	16	2,304	03/16/2025 1536	03/18/2025 0600
861081	Westmoreland	5	2,300	03/16/2025 1325	03/18/2025 0345
870887	Fayette	1	2,261	03/16/2025 2003	03/18/2025 0944
872047	Greene	19	2,256	03/16/2025 1234	03/18/2025 0210
872226	Fayette	14	2,248	03/16/2025 1250	03/18/2025 0218
870287	Westmoreland	11	2,246	03/16/2025 1339	03/18/2025 0305
872470	Fayette	2	2,240	03/17/2025 2155	03/19/2025 1115
860506	Westmoreland	435	2,239	03/16/2025 1311	03/18/2025 0230
869135	Fayette	2	2,220	03/17/2025 0655	03/18/2025 1955
863966	Centre	20	2,207	03/16/2025 1513	03/18/2025 0400
872385	Clinton	2	2,199	03/18/2025 0738	03/19/2025 2017
869046	Washington	2	2,184	03/17/2025 0626	03/18/2025 1850

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
868676	Elk	115	2,175	03/16/2025 1413	03/18/2025 0228
863968	Centre	12	2,144	03/16/2025 1513	03/18/2025 0257
865641	Centre	9	2,138	03/16/2025 1642	03/18/2025 0420
868598	Fayette	15	2,132	03/16/2025 1321	03/18/2025 0053
859875	Fayette	28	2,122	03/16/2025 1252	03/18/2025 0014
862850	Fayette	302	2,107	03/16/2025 1246	03/17/2025 2353
860601	Allegheny	6	2,097	03/16/2025 1313	03/18/2025 0010
866291	Washington	2	2,084	03/16/2025 1236	03/17/2025 2320
867562	Centre	2	2,055	03/16/2025 1935	03/18/2025 0550
872033	Clinton	2	2,046	03/16/2025 1604	03/18/2025 0210
871714	Armstrong	3	2,042	03/16/2025 1311	03/17/2025 2313
872064	Fayette	184	2,034	03/16/2025 1246	03/17/2025 2240
872066	Fayette	3	2,031	03/16/2025 1246	03/17/2025 2237
872065	Fayette	292	2,029	03/16/2025 1246	03/17/2025 2235
866741	Fayette	3	2,018	03/16/2025 1248	03/17/2025 2226
864375	Allegheny	4	2,010	03/16/2025 1530	03/18/2025 0100
872047	Greene	67	2,006	03/16/2025 1234	03/17/2025 2200
872151	Centre	9	1,995	03/16/2025 1513	03/18/2025 0028
859823	Washington	17	1,984	03/16/2025 1250	03/17/2025 2154
866867	Fayette	205	1,980	03/16/2025 1306	03/17/2025 2206
859980	Fayette	38	1,973	03/16/2025 1255	03/17/2025 2148
870005	Westmoreland	3	1,973	03/17/2025 1024	03/18/2025 1917
871074	Westmoreland	33	1,972	03/16/2025 1228	03/17/2025 2120
862662	Westmoreland	5	1,964	03/16/2025 1416	03/17/2025 2300
860230	Washington	3	1,963	03/16/2025 1302	03/17/2025 2145
872728	Centre	3	1,961	03/18/2025 0729	03/19/2025 1610
868143	Potter	76	1,955	03/16/2025 1457	03/17/2025 2332
864228	Centre	109	1,954	03/16/2025 1524	03/17/2025 2358
866959	Greene	26	1,936	03/16/2025 1239	03/17/2025 2055
868521	Westmoreland	12	1,930	03/16/2025 1325	03/17/2025 2135
871864	Washington	27	1,914	03/16/2025 1236	03/17/2025 2030
861683	Westmoreland	11	1,913	03/16/2025 1337	03/17/2025 2130
870205	Fayette	74	1,903	03/16/2025 1247	03/17/2025 2030
860390	Fayette	278	1,872	03/16/2025 1308	03/17/2025 2020
870248	Fayette	19	1,871	03/16/2025 1323	03/17/2025 2034
859943	Fayette	17	1,868	03/16/2025 1302	03/17/2025 2010
873134	Westmoreland	1	1,866	03/18/2025 1309	03/19/2025 2015
859726	Fayette	16	1,863	03/16/2025 1247	03/17/2025 1950

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
870762	Westmoreland	3	1,857	03/16/2025 1323	03/17/2025 2020
860307	Centre	130	1,853	03/16/2025 1305	03/17/2025 1958
859594	Fayette	336	1,850	03/16/2025 1244	03/17/2025 1934
863661	Centre	25	1,846	03/16/2025 1506	03/17/2025 2152
863620	Centre	22	1,844	03/16/2025 1501	03/17/2025 2145
863052	Westmoreland	2	1,840	03/16/2025 1440	03/17/2025 2120
871578	Westmoreland	86	1,836	03/16/2025 1319	03/17/2025 1955
860522	Westmoreland	599	1,827	03/16/2025 1311	03/17/2025 1938
860778	Westmoreland	24	1,826	03/16/2025 1317	03/17/2025 1943
870427	Westmoreland	9	1,824	03/17/2025 1221	03/18/2025 1845
860267	Fayette	21	1,819	03/16/2025 1303	03/17/2025 1922
870109	Centre	1	1,814	03/17/2025 1056	03/18/2025 1710
860132	Westmoreland	70	1,812	03/16/2025 1259	03/17/2025 1911
868605	Clinton	136	1,811	03/16/2025 1523	03/17/2025 2134
868553	Westmoreland	41	1,809	03/16/2025 1325	03/17/2025 1934
863351	Centre	31	1,809	03/16/2025 1457	03/17/2025 2106
860466	Armstrong	3	1,804	03/16/2025 1311	03/17/2025 1915
871571	Greene	149	1,798	03/16/2025 1236	03/17/2025 1834
870761	Westmoreland	37	1,791	03/16/2025 1323	03/17/2025 1914
870808	Fayette	2	1,788	03/17/2025 1412	03/18/2025 2000
865937	Westmoreland	19	1,787	03/16/2025 1323	03/17/2025 1910
860422	Fayette	1	1,780	03/16/2025 1309	03/17/2025 1849
870321	Centre	4	1,779	03/17/2025 1058	03/18/2025 1637
871727	Westmoreland	74	1,767	03/16/2025 1323	03/17/2025 1850
863320	Cameron	41	1,762	03/16/2025 1456	03/17/2025 2018
863397	Centre	10	1,756	03/16/2025 1459	03/17/2025 2015
866419	Cameron	28	1,754	03/16/2025 1458	03/17/2025 2012
863182	Cameron	101	1,753	03/16/2025 1447	03/17/2025 2000
874370	Cameron	1	1,740	03/19/2025 1400	03/20/2025 1900
868515	Westmoreland	69	1,740	03/16/2025 1325	03/17/2025 1825
868692	Centre	22	1,740	03/16/2025 1527	03/17/2025 2027
863062	Cameron	83	1,732	03/16/2025 1441	03/17/2025 1933
869251	Centre	16	1,731	03/17/2025 0737	03/18/2025 1228
865053	Fayette	46	1,729	03/16/2025 1254	03/17/2025 1743
859923	Fayette	16	1,725	03/16/2025 1253	03/17/2025 1738
861581	Greene	26	1,721	03/16/2025 1334	03/17/2025 1815
862934	Elk	77	1,720	03/16/2025 1431	03/17/2025 1911
871495	Allegheny	9	1,720	03/16/2025 1300	03/17/2025 1740

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
866182	Westmoreland	16	1,720	03/16/2025 1325	03/17/2025 1805
871456	Fayette	174	1,717	03/16/2025 1243	03/17/2025 1720
863375	Centre	32	1,715	03/16/2025 1458	03/17/2025 1933
862787	Fayette	5	1,710	03/16/2025 1424	03/17/2025 1854
858951	Greene	41	1,710	03/16/2025 1230	03/17/2025 1700
862761	Westmoreland	187	1,710	03/16/2025 1319	03/17/2025 1749
871120	Cameron	55	1,707	03/16/2025 1455	03/17/2025 1922
864078	Centre	17	1,704	03/16/2025 1518	03/17/2025 1942
859810	Fayette	161	1,702	03/16/2025 1243	03/17/2025 1705
871595	Westmoreland	2	1,700	03/17/2025 1817	03/18/2025 2237
871525	Centre	18	1,698	03/16/2025 1512	03/17/2025 1930
871217	Washington	21	1,698	03/16/2025 1242	03/17/2025 1700
868971	Westmoreland	39	1,698	03/16/2025 1322	03/17/2025 1740
861674	Westmoreland	22	1,691	03/16/2025 1337	03/17/2025 1748
864272	Westmoreland	34	1,690	03/16/2025 1310	03/17/2025 1720
863387	Armstrong	1	1,689	03/16/2025 1446	03/17/2025 1855
870499	Clinton	2	1,688	03/16/2025 1522	03/17/2025 1930
863056	Greene	6	1,685	03/16/2025 1440	03/17/2025 1845
862849	Westmoreland	9	1,681	03/16/2025 1427	03/17/2025 1828
870626	McKean	1	1,680	03/17/2025 1315	03/18/2025 1715
862451	Westmoreland	55	1,675	03/16/2025 1405	03/17/2025 1800
867165	Westmoreland	3	1,673	03/16/2025 1927	03/17/2025 2320
861184	Armstrong	2	1,669	03/16/2025 1326	03/17/2025 1715
870534	Centre	25	1,668	03/16/2025 1519	03/17/2025 1907
866439	Allegheny	11	1,664	03/16/2025 1311	03/17/2025 1655
859081	Greene	5	1,660	03/16/2025 1834	03/17/2025 2214
863690	Centre	54	1,660	03/16/2025 1507	03/17/2025 1847
868969	Westmoreland	23	1,656	03/16/2025 1325	03/17/2025 1701
868802	Westmoreland	57	1,653	03/16/2025 1329	03/17/2025 1702
870620	Greene	76	1,653	03/16/2025 1231	03/17/2025 1604
873274	Westmoreland	2	1,646	03/18/2025 1613	03/19/2025 1939
864570	Potter	1	1,646	03/16/2025 1540	03/17/2025 1906
870100	Centre	128	1,641	03/16/2025 1459	03/17/2025 1820
859446	Washington	76	1,631	03/16/2025 1242	03/17/2025 1553
870541	Centre	9	1,629	03/16/2025 1519	03/17/2025 1828
870947	Centre	9	1,619	03/16/2025 1512	03/17/2025 1811
861521	Westmoreland	64	1,618	03/16/2025 1332	03/17/2025 1630
864114	Westmoreland	11	1,616	03/16/2025 1519	03/17/2025 1815

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
863707	Centre	6	1,610	03/16/2025 1510	03/17/2025 1800
870043	Westmoreland	26	1,608	03/16/2025 1657	03/17/2025 1945
863993	Centre	6	1,596	03/16/2025 1514	03/17/2025 1750
860368	Fayette	17	1,594	03/16/2025 1307	03/17/2025 1541
863694	Centre	9	1,593	03/16/2025 1507	03/17/2025 1740
870714	Centre	15	1,592	03/16/2025 1506	03/17/2025 1738
871186	Westmoreland	1	1,591	03/17/2025 1537	03/18/2025 1808
866412	Fayette	1	1,588	03/16/2025 1744	03/17/2025 2012
868959	Centre	17	1,587	03/16/2025 1501	03/17/2025 1728
864068	Cameron	34	1,583	03/16/2025 1518	03/17/2025 1741
866174	Westmoreland	123	1,581	03/16/2025 1324	03/17/2025 1545
870277	Westmoreland	277	1,578	03/16/2025 1317	03/17/2025 1535
862869	Elk	10	1,577	03/16/2025 1428	03/17/2025 1645
871182	Westmoreland	11	1,572	03/16/2025 1258	03/17/2025 1510
871441	Centre	51	1,570	03/16/2025 1513	03/17/2025 1723
866805	Centre	292	1,561	03/16/2025 1459	03/17/2025 1700
868348	Centre	2	1,560	03/16/2025 1524	03/17/2025 1724
864942	Westmoreland	6	1,559	03/16/2025 1500	03/17/2025 1659
869338	Fayette	10	1,553	03/17/2025 0807	03/18/2025 1000
871152	Armstrong	6	1,552	03/16/2025 1526	03/17/2025 1718
872480	Franklin	2	1,550	03/17/2025 1341	03/18/2025 1531
865593	Fayette	10	1,543	03/16/2025 1329	03/17/2025 1512
869254	Westmoreland	58	1,536	03/16/2025 1327	03/17/2025 1503
872404	Fayette	2	1,536	03/18/2025 0750	03/19/2025 0926
863983	Centre	20	1,529	03/16/2025 1521	03/17/2025 1650
860430	Allegheny	1	1,528	03/16/2025 1309	03/17/2025 1437
867874	Fayette	1	1,526	03/16/2025 1521	03/17/2025 1647
860884	Fayette	13	1,520	03/16/2025 1320	03/17/2025 1440
864612	Fayette	1	1,518	03/16/2025 1542	03/17/2025 1700
866776	Armstrong	3	1,512	03/16/2025 1333	03/17/2025 1445
864971	Elk	2	1,511	03/16/2025 1603	03/17/2025 1714
870683	Centre	2	1,508	03/16/2025 1502	03/17/2025 1610
868808	Fayette	5	1,503	03/16/2025 1311	03/17/2025 1414
867361	Allegheny	2	1,490	03/16/2025 1309	03/17/2025 1359
870805	Centre	2	1,484	03/16/2025 1523	03/17/2025 1607
866877	Centre	45	1,481	03/16/2025 1829	03/17/2025 1910
873580	Elk	2	1,479	03/18/2025 1841	03/19/2025 1920
865939	Westmoreland	187	1,476	03/16/2025 1323	03/17/2025 1359

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
864748	Armstrong	5	1,474	03/16/2025 1320	03/17/2025 1354
863295	Cameron	8	1,460	03/16/2025 1455	03/17/2025 1515
870619	Greene	489	1,457	03/16/2025 1231	03/17/2025 1248
868832	Westmoreland	71	1,457	03/16/2025 1328	03/17/2025 1345
868266	Armstrong	8	1,454	03/16/2025 1327	03/17/2025 1341
870363	Greene	18	1,449	03/16/2025 1231	03/17/2025 1240
860189	Westmoreland	86	1,449	03/16/2025 1301	03/17/2025 1310
869793	Elk	44	1,448	03/16/2025 1414	03/17/2025 1422
860755	Armstrong	5	1,443	03/16/2025 1317	03/17/2025 1320
865381	Armstrong	1	1,442	03/16/2025 1627	03/17/2025 1629
860062	Fayette	68	1,441	03/16/2025 1257	03/17/2025 1258
872778	Westmoreland	1	1,439	03/17/2025 2021	03/18/2025 2020
866805	Centre	19	1,431	03/16/2025 1459	03/17/2025 1450
866921	Westmoreland	3	1,428	03/16/2025 1332	03/17/2025 1320
870769	Elk	45	1,425	03/16/2025 1420	03/17/2025 1405
868635	Clinton	54	1,422	03/16/2025 1523	03/17/2025 1505
870977	Clinton	13	1,422	03/16/2025 1523	03/17/2025 1505
862862	Fayette	17	1,418	03/16/2025 1428	03/17/2025 1406
869222	Westmoreland	20	1,418	03/16/2025 1332	03/17/2025 1310
868850	Centre	162	1,403	03/16/2025 1507	03/17/2025 1430
868368	Greene	59	1,395	03/16/2025 1231	03/17/2025 1146
867111	Greene	5	1,394	03/16/2025 1239	03/17/2025 1153
864070	Westmoreland	1	1,392	03/16/2025 1518	03/17/2025 1430
859995	Fayette	29	1,381	03/16/2025 1255	03/17/2025 1156
859725	Fayette	19	1,379	03/16/2025 1249	03/17/2025 1148
864094	Centre	37	1,371	03/16/2025 1519	03/17/2025 1410
868639	Centre	173	1,369	03/16/2025 1523	03/17/2025 1412
874580	Centre	1	1,368	03/19/2025 1429	03/20/2025 1317
862794	Elk	14	1,361	03/16/2025 1424	03/17/2025 1305
860450	Fayette	16	1,359	03/16/2025 1310	03/17/2025 1149
866669	Armstrong	1	1,356	03/16/2025 1809	03/17/2025 1645
870296	Westmoreland	276	1,349	03/16/2025 1317	03/17/2025 1146
863519	Centre	67	1,346	03/16/2025 1502	03/17/2025 1328
871034	Fayette	5	1,344	03/17/2025 1458	03/18/2025 1322
865399	Westmoreland	389	1,340	03/16/2025 1317	03/17/2025 1137
868845	Centre	101	1,338	03/16/2025 1502	03/17/2025 1320
864952	Westmoreland	103	1,336	03/16/2025 1317	03/17/2025 1133
873703	Centre	1	1,331	03/18/2025 2037	03/19/2025 1848

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
870520	Cameron	321	1,324	03/16/2025 1449	03/17/2025 1253
871936	Centre	1	1,318	03/17/2025 2102	03/18/2025 1900
872114	Centre	2	1,315	03/19/2025 1238	03/20/2025 1033
861750	Washington	4	1,304	03/16/2025 1339	03/17/2025 1123
861091	Westmoreland	2	1,295	03/16/2025 1325	03/17/2025 1100
869792	Cameron	40	1,291	03/16/2025 1449	03/17/2025 1220
873581	Westmoreland	4	1,287	03/18/2025 1627	03/19/2025 1354
860169	Fayette	19	1,285	03/16/2025 1300	03/17/2025 1025
870435	Centre	30	1,279	03/16/2025 1519	03/17/2025 1238
864185	Clinton	27	1,273	03/16/2025 1522	03/17/2025 1235
860064	Fayette	70	1,261	03/16/2025 1257	03/17/2025 0958
868738	Armstrong	4	1,256	03/16/2025 1322	03/17/2025 1018
861159	Armstrong	7	1,243	03/16/2025 1326	03/17/2025 1009
859375	Washington	6	1,232	03/16/2025 1241	03/17/2025 0913
872061	Centre	6	1,230	03/17/2025 2225	03/18/2025 1855
862687	Westmoreland	26	1,220	03/16/2025 1417	03/17/2025 1037
862295	Indiana	1	1,215	03/16/2025 1400	03/17/2025 1015
864182	Centre	10	1,209	03/16/2025 1511	03/17/2025 1120
869283	Armstrong	2	1,189	03/16/2025 1355	03/17/2025 0944
861549	Armstrong	4	1,187	03/16/2025 1333	03/17/2025 0920
867453	Westmoreland	43	1,187	03/16/2025 1921	03/17/2025 1508
871311	Armstrong	7	1,187	03/16/2025 2131	03/17/2025 1718
865742	Fayette	173	1,181	03/16/2025 1308	03/17/2025 0849
867889	Washington	24	1,178	03/16/2025 1239	03/17/2025 0817
868437	Westmoreland	146	1,175	03/16/2025 1326	03/17/2025 0901
860406	Westmoreland	17	1,172	03/16/2025 1308	03/17/2025 0840
873111	Fayette	1	1,169	03/18/2025 1447	03/19/2025 1016
862636	Elk	8	1,166	03/16/2025 1414	03/17/2025 0940
868561	Washington	4	1,156	03/16/2025 2331	03/17/2025 1847
860162	Westmoreland	4	1,156	03/16/2025 1300	03/17/2025 0816
862841	Armstrong	219	1,138	03/16/2025 1355	03/17/2025 0853
866362	Centre	51	1,138	03/16/2025 1459	03/17/2025 0957
868336	Fayette	1	1,136	03/16/2025 2204	03/17/2025 1700
863213	Cameron	95	1,126	03/16/2025 1449	03/17/2025 0935
864183	Centre	16	1,118	03/16/2025 1522	03/17/2025 1000
863763	Centre	176	1,115	03/16/2025 1508	03/17/2025 0943
861089	Fayette	6	1,110	03/16/2025 1325	03/17/2025 0755
860496	Westmoreland	10	1,100	03/16/2025 1311	03/17/2025 0731

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
860554	Westmoreland	8	1,099	03/16/2025 1312	03/17/2025 0731
871959	Westmoreland	1	1,098	03/17/2025 2115	03/18/2025 1533
860320	Fayette	5	1,095	03/16/2025 1305	03/17/2025 0720
860295	Fayette	34	1,088	03/16/2025 1304	03/17/2025 0712
868870	Westmoreland	3	1,075	03/16/2025 1620	03/17/2025 1015
859909	Washington	52	1,072	03/16/2025 1253	03/17/2025 0645
867983	Elk	7	1,069	03/16/2025 2040	03/17/2025 1429
865309	Fayette	38	1,056	03/16/2025 1325	03/17/2025 0701
873366	Fayette	3	1,054	03/18/2025 1651	03/19/2025 1025
860673	Westmoreland	27	1,046	03/16/2025 1315	03/17/2025 0641
860673	Westmoreland	17	1,039	03/16/2025 1315	03/17/2025 0634
862031	Fayette	2	999	03/16/2025 1349	03/17/2025 0628
874112	Westmoreland	1	991	03/19/2025 1049	03/20/2025 0320
858907	Westmoreland	415	980	03/16/2025 1228	03/17/2025 0448
866461	Westmoreland	119	972	03/16/2025 1750	03/17/2025 1002
871710	Greene	3	966	03/17/2025 1917	03/18/2025 1123
872099	Washington	1	957	03/17/2025 2258	03/18/2025 1455
873283	Westmoreland	1	949	03/18/2025 1616	03/19/2025 0805
869239	Centre	13	937	03/17/2025 0514	03/17/2025 2051
872763	Westmoreland	10	936	03/17/2025 2014	03/18/2025 1150
860276	Fayette	10	935	03/16/2025 1304	03/17/2025 0439
860910	Westmoreland	279	929	03/16/2025 1321	03/17/2025 0450
860994	Westmoreland	284	925	03/16/2025 1323	03/17/2025 0448
868149	Westmoreland	3	912	03/16/2025 2114	03/17/2025 1226
866470	Westmoreland	103	912	03/16/2025 1338	03/17/2025 0450
873666	Fayette	2	909	03/18/2025 2007	03/19/2025 1116
873598	Westmoreland	4	907	03/18/2025 1854	03/19/2025 1001
859662	Fayette	25	907	03/16/2025 1246	03/17/2025 0353
868677	Fayette	364	905	03/16/2025 1252	03/17/2025 0357
859878	Fayette	89	905	03/16/2025 1252	03/17/2025 0357
863941	Centre	78	902	03/16/2025 1512	03/17/2025 0614
874819	Cameron	40	894	03/20/2025 0206	03/20/2025 1700
868633	Armstrong	39	886	03/16/2025 1312	03/17/2025 0358
860170	Fayette	74	870	03/16/2025 1300	03/17/2025 0330
861307	Westmoreland	15	859	03/16/2025 1328	03/17/2025 0347
869106	Fayette	10	857	03/17/2025 0448	03/17/2025 1905
859694	Fayette	233	845	03/16/2025 1245	03/17/2025 0250
861166	Armstrong	10	844	03/16/2025 1326	03/17/2025 0330

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
868847	Centre	317	828	03/16/2025 1502	03/17/2025 0450
859866	Fayette	9	827	03/16/2025 1251	03/17/2025 0238
868604	Greene	4	827	03/16/2025 1234	03/17/2025 0221
861406	Armstrong	16	823	03/16/2025 1330	03/17/2025 0313
861334	Westmoreland	17	813	03/16/2025 1329	03/17/2025 0302
859184	Washington	16	804	03/16/2025 1236	03/17/2025 0200
868883	Centre	58	801	03/16/2025 1459	03/17/2025 0420
860874	Fayette	22	800	03/16/2025 1320	03/17/2025 0240
870660	Westmoreland	4	800	03/17/2025 1322	03/18/2025 0242
863032	Elk	44	787	03/16/2025 1433	03/17/2025 0340
868847	Centre	455	784	03/16/2025 1502	03/17/2025 0406
867598	Greene	27	781	03/16/2025 1234	03/17/2025 0135
868844	Centre	239	776	03/16/2025 1502	03/17/2025 0358
859273	Fayette	126	776	03/16/2025 1238	03/17/2025 0134
860931	Armstrong	23	763	03/16/2025 1322	03/17/2025 0205
870167	Clinton	2	759	03/18/2025 0738	03/18/2025 2017
860347	Westmoreland	43	759	03/16/2025 1306	03/17/2025 0145
859824	Washington	19	754	03/16/2025 1250	03/17/2025 0124
859865	Washington	5	752	03/16/2025 1251	03/17/2025 0123
871203	Clinton	84	725	03/17/2025 0455	03/17/2025 1700
863091	Clarion	3	724	03/16/2025 1443	03/17/2025 0247
868664	Washington	34	723	03/16/2025 1238	03/17/2025 0041
868665	Washington	39	714	03/16/2025 1238	03/17/2025 0032
869223	Westmoreland	10	708	03/17/2025 0732	03/17/2025 1920
862840	Westmoreland	4	698	03/16/2025 1427	03/17/2025 0205
868728	Franklin	2	694	03/16/2025 1454	03/17/2025 0228
868946	Armstrong	2	691	03/17/2025 0537	03/17/2025 1708
865578	Franklin	9	690	03/16/2025 1445	03/17/2025 0215
864083	Indiana	13	690	03/16/2025 1320	03/17/2025 0050
867800	Allegheny	311	689	03/16/2025 1226	03/16/2025 2355
860552	Armstrong	16	688	03/16/2025 1312	03/17/2025 0040
861595	Westmoreland	19	688	03/16/2025 1334	03/17/2025 0102
872293	Fayette	4	682	03/18/2025 0528	03/18/2025 1650
861024	Westmoreland	20	672	03/16/2025 1323	03/17/2025 0035
867598	Greene	21	665	03/16/2025 1234	03/16/2025 2339
867598	Greene	34	664	03/16/2025 1234	03/16/2025 2338
859720	Fayette	13	653	03/16/2025 1247	03/16/2025 2340
860890	Westmoreland	31	652	03/16/2025 1320	03/17/2025 0012

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
862638	Elk	26	648	03/16/2025 1421	03/17/2025 0109
863513	Centre	33	644	03/16/2025 1506	03/17/2025 0150
863372	Centre	2174	640	03/16/2025 1501	03/17/2025 0141
870894	Westmoreland	2	637	03/17/2025 1423	03/18/2025 0100
857728	Allegheny	16	633	03/16/2025 0603	03/16/2025 1636
861610	Westmoreland	99	630	03/16/2025 1335	03/17/2025 0005
863290	Franklin	16	629	03/16/2025 1454	03/17/2025 0123
863359	Centre	581	623	03/16/2025 1502	03/17/2025 0125
863258	Centre	52	621	03/16/2025 1453	03/17/2025 0114
873837	Fayette	8	619	03/19/2025 0504	03/19/2025 1523
868262	Greene	39	617	03/16/2025 1235	03/16/2025 2252
868330	Armstrong	77	615	03/16/2025 2202	03/17/2025 0817
875567	Fayette	3	606	03/20/2025 1838	03/21/2025 0444
860653	Westmoreland	44	600	03/16/2025 1315	03/16/2025 2315
868315	Washington	2	599	03/16/2025 1238	03/16/2025 2237
868422	Westmoreland	356	599	03/16/2025 1326	03/16/2025 2325
873017	Fulton	1	595	03/18/2025 0758	03/18/2025 1753
861116	Westmoreland	68	595	03/16/2025 1325	03/16/2025 2320
872508	Fayette	2	595	03/18/2025 0859	03/18/2025 1854
859028	Greene	58	590	03/16/2025 1231	03/16/2025 2221
874849	Elk	98	588	03/20/2025 0527	03/20/2025 1515
873365	Fayette	3	584	03/18/2025 1651	03/19/2025 0235
873712	Centre	5	581	03/18/2025 2049	03/19/2025 0630
864092	Franklin	1	580	03/16/2025 1519	03/17/2025 0059
873578	Potter	5	577	03/18/2025 0938	03/18/2025 1915
867947	Allegheny	45	567	03/16/2025 1254	03/16/2025 2221
871696	Greene	32	566	03/17/2025 1910	03/18/2025 0436
864931	Fayette	5	563	03/16/2025 1653	03/17/2025 0216
861954	Clarion	1	562	03/16/2025 1345	03/16/2025 2307
859242	Fayette	148	561	03/16/2025 1239	03/16/2025 2200
863132	Franklin	9	560	03/16/2025 1655	03/17/2025 0215
872187	Fayette	28	557	03/18/2025 0107	03/18/2025 1024
860648	Armstrong	62	554	03/16/2025 1314	03/16/2025 2228
860932	Westmoreland	37	550	03/16/2025 1322	03/16/2025 2232
861119	Westmoreland	373	549	03/16/2025 1325	03/16/2025 2234
868146	Washington	3	548	03/16/2025 1238	03/16/2025 2146
861114	Westmoreland	523	545	03/16/2025 1325	03/16/2025 2230
868865	Clinton	23	545	03/17/2025 0415	03/17/2025 1320

West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
864211	Clinton	14	545	03/16/2025 1523	03/17/2025 0028
860236	Fayette	63	542	03/16/2025 1302	03/16/2025 2204
859130	Greene	30	540	03/16/2025 1235	03/16/2025 2135
864190	Centre	435	537	03/16/2025 1523	03/17/2025 0020
869032	Greene	3	536	03/17/2025 0619	03/17/2025 1515
872170	Westmoreland	30	523	03/17/2025 1602	03/18/2025 0045
867945	Centre	217	521	03/16/2025 1459	03/16/2025 2340
868599	Washington	2	510	03/16/2025 1730	03/17/2025 0200
863245	Potter	25	508	03/16/2025 1504	03/16/2025 2332
859368	Fayette	178	506	03/16/2025 1240	03/16/2025 2106
861204	Allegheny	1	504	03/16/2025 1326	03/16/2025 2150
864340	Washington	35	502	03/16/2025 1528	03/16/2025 2350
859366	Washington	32	501	03/16/2025 1240	03/16/2025 2101
874828	Fayette	21	500	03/20/2025 0256	03/20/2025 1116
868135	Washington	3	496	03/16/2025 1238	03/16/2025 2054
871703	Westmoreland	29	493	03/17/2025 1602	03/18/2025 0015
861232	Armstrong	33	493	03/16/2025 1327	03/16/2025 2140
859312	Washington	672	486	03/16/2025 1239	03/16/2025 2045
873760	Armstrong	1	486	03/18/2025 1829	03/19/2025 0235
869839	Franklin	1	481	03/17/2025 0949	03/17/2025 1750
860164	Fayette	79	480	03/16/2025 1300	03/16/2025 2100
860318	Allegheny	79	480	03/16/2025 1305	03/16/2025 2105
872551	Westmoreland	1	471	03/18/2025 0924	03/18/2025 1715
874290	Greene	5	470	03/19/2025 1244	03/19/2025 2034
862093	Westmoreland	26	469	03/16/2025 1351	03/16/2025 2140
872550	Westmoreland	7	467	03/18/2025 0924	03/18/2025 1711
867298	Allegheny	4	467	03/16/2025 1908	03/17/2025 0255
865714	Clarion	7	457	03/16/2025 1108	03/16/2025 1845
875099	Butler	3	454	03/20/2025 0714	03/20/2025 1448
867800	Allegheny	331	454	03/16/2025 1226	03/16/2025 2000
868135	Washington	204	452	03/16/2025 1238	03/16/2025 2010
859367	Washington	808	451	03/16/2025 1239	03/16/2025 2010
869905	Westmoreland	1	447	03/17/2025 1003	03/17/2025 1730
859964	Allegheny	7	445	03/16/2025 1255	03/16/2025 2020
867379	Greene	61	440	03/16/2025 1235	03/16/2025 1955
866373	Butler	3	439	03/16/2025 1251	03/16/2025 2010
859235	Allegheny	198	438	03/16/2025 1237	03/16/2025 1955
860524	Elk	215	434	03/16/2025 1312	03/16/2025 2026


West Penn Rate District Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
859080	Greene	5	424	03/16/2025 1234	03/16/2025 1938
862357	Westmoreland	5	423	03/16/2025 1402	03/16/2025 2105
858856	Allegheny	94	420	03/16/2025 1226	03/16/2025 1926
875265	Washington	1	418	03/20/2025 1022	03/20/2025 1720
873207	Westmoreland	1	418	03/18/2025 1547	03/18/2025 2245
867945	Centre	299	416	03/16/2025 1459	03/16/2025 2155
858095	Washington	4	413	03/16/2025 0640	03/16/2025 1333
863339	Potter	5	413	03/16/2025 1457	03/16/2025 2150
875107	Potter	76	412	03/20/2025 0659	03/20/2025 1351
860277	Allegheny	4	411	03/16/2025 1304	03/16/2025 1955
866999	Butler	21	409	03/16/2025 1324	03/16/2025 2013
869887	Greene	1	408	03/16/2025 1234	03/16/2025 1922
873953	Armstrong	55	405	03/19/2025 0858	03/19/2025 1543
874010	Centre	1	405	03/19/2025 0950	03/19/2025 1635
860781	Allegheny	14	397	03/16/2025 1318	03/16/2025 1955
857591	Washington	27	394	03/15/2025 2236	03/16/2025 0510
860493	Westmoreland	6	394	03/16/2025 1311	03/16/2025 1945
869212	Westmoreland	4	388	03/17/2025 0728	03/17/2025 1356
867461	Washington	32	386	03/16/2025 1243	03/16/2025 1909
874598	Greene	1	385	03/19/2025 1645	03/19/2025 2310
874360	Greene	5	384	03/19/2025 1353	03/19/2025 2017
865747	Fayette	47	384	03/16/2025 1246	03/16/2025 1910
868805	Butler	22	383	03/17/2025 0317	03/17/2025 0940
865890	Fayette	150	383	03/16/2025 1254	03/16/2025 1917
866770	Greene	76	382	03/16/2025 1234	03/16/2025 1856
866609	Westmoreland	125	379	03/16/2025 1316	03/16/2025 1935
860779	Westmoreland	69	379	03/16/2025 1316	03/16/2025 1935
870881	Centre	52	374	03/17/2025 0811	03/17/2025 1425
862913	Franklin	2	365	03/16/2025 1430	03/16/2025 2035
868810	Washington	18	365	03/17/2025 0321	03/17/2025 0926
860183	Allegheny	30	365	03/16/2025 1301	03/16/2025 1906
860419	Allegheny	5	364	03/16/2025 1309	03/16/2025 1913
859275	Fayette	721	360	03/16/2025 1239	03/16/2025 1839


Attachment B: Wind, Tornado, and Precipitation Reports

Wind, Tornado, & Precipitation Reports: Graphics 1 through 4 illustrate the maximum wind gusts in the West Penn service territory from March 15, 2025 through March 18, 2025. Graphic 5 illustrates the locations of confirmed tornado touchdowns on Sunday, March 16, 2025. Graphic 6 illustrates the 24-Hour Total Precipitation in the West Penn service territory on Sunday, March 16, 2025. The graphics depict data from the National Oceanic and Atmospheric Administration (“NOAA”).


Graphic 1: Maximum Wind Gusts – Saturday, March 15, 2025




Graphic 2: Maximum Wind Gusts – Sunday, March 16, 2025




Graphic 3: Maximum Wind Gusts – Monday, March 17, 2025




Graphic 4: Maximum Wind Gusts – Tuesday, March 18, 2025




Graphic 5: Tornado Touch Down Locations (“T”) and Damage Reports (“D”) – Sunday, March 16, 2025




Graphic 6: 24-Hour Total Precipitation – Sunday, March 16, 2025



Attachment C: Restoration Curve



Attachment D: Order Restoration Graphs




Attachment E: Meteorologist Reports

Thursday, March 13, 2025 @ 0959

New Issuance:


Non-thunderstorm gusts expected ahead of a frontal passage will be mixed with a threat of some cells forming in the same areas producing generally the same gust threat for two days until the front passes.



Thursday, March 13, 2025 @ 1011

Update:


Clarifying the start time for the Sun gusts in WV/PA/NJ is 11am (ending time still with the frontal passage). Also highlighted the Sat time window in WV.



Friday, March 14, 2025 @ 1001

Changes:


1. Today - added mention in the top left panel (white box) of some nuisance 40 mph gusts this afternoon in west OH
2. Saturday – some timing changes (earlier start times)
3. Sunday – slowed the front’s ETA and had to change timing of gusts - also the heavy rain area in east FE shifted offshore but the slower frontal movement introduces a heavy rain threat in FE West.



Saturday, March 15, 2025 @ 0854

Changes:

1. Today: Limited the damaging thunderstorm threat to extreme south and southwest FE in the evening. Still, non-thunderstorm gusts which will continue in the green areas anyway, some of which have the potential to peak over 55 mph, especially west of the blue line. Also, fine-tuned details of WV/MD/southwest PA gusts.
2. Sunday: Replaced the ETAs of the cold front instead with two potential separate rounds of heavy rain/cells. This is not etched in stone but there is good agreement in the different models for two separated bands. This would likely manifest itself an early runner (in white) well out ahead of the actual cold front which would weaken by late afternoon) then a separate afternoon evening runner (in yellow) more closely tied with the front itself. Regardless, both these potential bands are superimposed on the backdrop of general wind gusts (shaded in green) occurring most of the day. The ETAs aren't tight yet – still a slush of +/- 90 minutes.




Sunday, March 16, 2025 @ 0811

Changes:

Today: Focused on a primary band of cells expected to form late this morning in east OH/WV then move east and is expected to stall and diminish as it reaches NJ. Its best potential for producing multiple heavy storms in a band noon-6pm (west central PA south through MD and WV and then into east central PA). Meanwhile – general non-thunderstorm gusts near 40 mph will continue through 6pm today – although spotty and infrequent – some might reach 50-60 mph.

We will continue to monitor and issue an update early this afternoon only if there is any significant deviation from this forecast, but otherwise this will be the final update on this event.



Sunday, March 16, 2025 @ 1303

Changes:

Updated to better time the primary band of cells moving east. There is some potential for the line to arrive an hour ahead of schedule in east PA and into NJ. Regardless, the damaging storm threat is over in any given area after the main band pushes through, although occasional non-thunderstorm gusts 40-45 mph still be possible through 6pm in the entire green-shaded area, especially with any sunshine.

