

EXHIBIT M

PUBLIC WATER SUPPLY PERMIT

NO. 4388510-MA4

A. PERMITTEE: (Name and Address)

Greenville Municipal Water Authority
 44 Clinton Street
 Greenville, PA 16125

B. PROJECT/PLANT LOCATION

Address West Main Street and Hadley Road
 Municipality Salem Township
 County Mercer

C. THIS PERMIT APPROVES FOR: 1. CONSTRUCTION 2. OPERATION OF FACILITIES

AS INDICATED BELOW:

Approved Under Construction Permit No. 4388510-MA4

Source	Facilities	BVRB
<input type="checkbox"/> Well(s)	<input type="checkbox"/> Impoundment	<input type="checkbox"/> Bottled Water System
<input type="checkbox"/> Spring(s)	<input type="checkbox"/> Settling	<input type="checkbox"/> Bulk Water Hauling System
<input type="checkbox"/> Surface Water	<input type="checkbox"/> Filtration	<input type="checkbox"/> Vended Water System
<input type="checkbox"/> Finished Water	<input type="checkbox"/> Iron and Manganese Treatment	<input type="checkbox"/> Retail Water Facility
	<input type="checkbox"/> Softening	
	<input type="checkbox"/> Fluoridation	
	<input type="checkbox"/> Distribution Facility	
	<input type="checkbox"/> General Corrosion Control	
	<input type="checkbox"/> Corrosion Control for lead/copper	
	<input type="checkbox"/> Disinfection	
	<input type="checkbox"/> Pump Station(s)	
	<input type="checkbox"/> Transmission Lines	
	<input checked="" type="checkbox"/> Finished Water Storage	
	<input type="checkbox"/> Other _____	

KNOWN AS Improvements and GridBee Tank Mixers in West End Storage Tanks (0.75MG Tank 2 & 0.75MG Tank 3) and 1.0MG East Storage Tank 2 and renovations to 0.25 MG East Storage Tank.

LIMIT OF AUTHORIZATION

YOU ARE HEREBY AUTHORIZED TO CONSTRUCT OR OPERATE, AS INDICATED ABOVE, PROVIDED THAT FAILURE TO COMPLY WITH CHAPTER 109, OF THE RULES AND REGULATIONS OF THE DEPARTMENT OF ENVIRONMENTAL PROTECTION OR THE TERMS OR CONDITIONS OF THIS PERMIT SHALL VOID THE AUTHORITY GIVEN TO THE PERMITTEE BY THE ISSUANCE OF THE PERMIT.

THE PLANS, SPECIFICATIONS, REPORTS AND SUPPORTING DOCUMENTS SUBMITTED AS PART OF THE PERMIT APPLICATION BECOME PART OF THE PERMIT.

NO DEVIATIONS FROM APPROVED PLANS OR SPECIFICATIONS AFFECTING THE TREATMENT PROCESS OR QUALITY OF WATERS SHALL BE MADE WITHOUT WRITTEN APPROVAL FROM THE DEPARTMENT.

THIS PERMIT IS ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL PROTECTION UNDER THE AUTHORITY OF THE PENNSYLVANIA SAFE DRINKING WATER ACT, THE ACT OF MAY 1, 1984 (P.L. 206, NO. 43). OPERATION SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 109 ADOPTED UNDER THE AUTHORITY IN SECTIONS 4 AND 6(e) OF THE PENNSYLVANIA SAFE DRINKING WATER ACT.

THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS N/A

PERMIT ISSUED

Date July 9, 2019

DEPARTMENT OF ENVIRONMENTAL PROTECTION

By: 

Brad E. Vanderhoof, P.E.
 Regional Manager

Title Safe Drinking Water Program



PUBLIC WATER SUPPLY PERMIT

NO. 2884-MA2

<p>A. PERMITTEE: (Name and Address)</p> <p>Greenville Municipal Water Authority 44 Clinton Street Greenville, PA 16125</p>	<p>B. PROJECT/PLANT LOCATION</p> <p>Address <u>Main Street, College Ave & Dwyer Court</u> Municipality <u>Greenville Borough</u> County <u>Mercer</u></p>
--	---

C. THIS PERMIT APPROVES FOR: 1. CONSTRUCTION 2. OPERATION OF FACILITIES

AS INDICATED BELOW: Approved Under Construction Permit No. 2884-MA2

<u>Source</u>	<u>Facilities</u>	<u>BVRB</u>
<input type="checkbox"/> Well(s)	<input type="checkbox"/> Impoundment	<input type="checkbox"/> Bottled Water System
<input type="checkbox"/> Spring(s)	<input type="checkbox"/> Settling	<input type="checkbox"/> Bulk Water Hauling System
<input type="checkbox"/> Surface Water	<input type="checkbox"/> Filtration	<input type="checkbox"/> Vended Water System
<input type="checkbox"/> Finished Water	<input type="checkbox"/> Iron and Manganese Treatment	<input type="checkbox"/> Retail Water Facility
	<input type="checkbox"/> Softening	
	<input type="checkbox"/> Fluoridation	
	<input checked="" type="checkbox"/> Distribution Facility	
	<input type="checkbox"/> General Corrosion Control	
	<input type="checkbox"/> Corrosion Control for lead/copper	
	<input type="checkbox"/> Disinfection	
	<input type="checkbox"/> Pump Station(s)	
	<input type="checkbox"/> Transmission Lines	
	<input type="checkbox"/> Finished Water Storage	
	<input type="checkbox"/> Other _____	

KNOWN AS Greenville Municipal Water Authority: Trenchless, Cured-In-Place Pipe (CIPP) Lining of water mains located on Main Street, College Avenue and Dwyer Court. ??

LIMIT OF AUTHORIZATION

YOU ARE HEREBY AUTHORIZED TO CONSTRUCT OR OPERATE, AS INDICATED ABOVE, PROVIDED THAT FAILURE TO COMPLY WITH CHAPTER 109, OF THE RULES AND REGULATIONS OF THE DEPARTMENT OF ENVIRONMENTAL PROTECTION OR THE TERMS OR CONDITIONS OF THIS PERMIT SHALL VOID THE AUTHORITY GIVEN TO THE PERMITTEE BY THE ISSUANCE OF THE PERMIT.

THE PLANS, SPECIFICATIONS, REPORTS AND SUPPORTING DOCUMENTS SUBMITTED AS PART OF THE PERMIT APPLICATION BECOME PART OF THE PERMIT.

NO DEVIATIONS FROM APPROVED PLANS OR SPECIFICATIONS AFFECTING THE TREATMENT PROCESS OR QUALITY OF WATERS SHALL BE MADE WITHOUT WRITTEN APPROVAL FROM THE DEPARTMENT.

THIS PERMIT IS ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL PROTECTION UNDER THE AUTHORITY OF THE PENNSYLVANIA SAFE DRINKING WATER ACT, THE ACT OF MAY 1, 1984 (P.L. 206, NO. 43). OPERATION SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 109 ADOPTED UNDER THE AUTHORITY IN SECTIONS 4 AND 6(e) OF THE PENNSYLVANIA SAFE DRINKING WATER ACT.

THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS N/A

PERMIT ISSUED

Date March 26, 2019

DEPARTMENT OF ENVIRONMENTAL PROTECTION

By:
Brad E. Vanderhoof, P.E.
Regional Manager
Title Safe Drinking Water Program

COPY

PUBLIC WATER SUPPLY PERMIT

NO. 2884-MA1

A. PERMITTEE: (Name and Address)

Greenville Borough Municipal Authority
44 Clinton Street
Greenville, PA 16125

B. PROJECT/PLANT LOCATION

Municipality West Salem Township
County Mercer

C. THIS PERMIT APPROVES FOR:
AS INDICATED BELOW:

1. CONSTRUCTION

2. OPERATION OF FACILITIES

Approved Under Construction Permit No. 2884-MA1

Source

Facilities

BVRB

- | | | | |
|--|--|--|--|
| <input type="checkbox"/> Well(s) | <input type="checkbox"/> Impoundment | <input type="checkbox"/> General Corrosion Control | <input type="checkbox"/> Bottled Water System |
| <input type="checkbox"/> Spring(s) | <input type="checkbox"/> Settling | <input type="checkbox"/> Corrosion Control for lead/copper | <input type="checkbox"/> Bulk Water Hauling System |
| <input type="checkbox"/> Surface Water | <input type="checkbox"/> Filtration | <input type="checkbox"/> Disinfection | <input type="checkbox"/> Vended Water System |
| <input checked="" type="checkbox"/> Finished Water | <input checked="" type="checkbox"/> Iron and Manganese Treatment | <input type="checkbox"/> Pump Station(s) | <input type="checkbox"/> Retail Water Facility |
| | <input checked="" type="checkbox"/> Softening | <input type="checkbox"/> Transmission Lines | |
| | <input checked="" type="checkbox"/> Fluoridation | <input checked="" type="checkbox"/> Finished Water Storage | |
| | <input checked="" type="checkbox"/> Distribution Facility | <input type="checkbox"/> Other _____ | |

KNOWN AS

Repainting of interior and exterior of 0.258 MG West Main Street Water Storage Tank.

LIMIT OF AUTHORIZATION

YOU ARE HEREBY AUTHORIZED TO CONSTRUCT OR OPERATE, AS INDICATED ABOVE, PROVIDED THAT FAILURE TO COMPLY WITH CHAPTER 109 OF THE RULES AND REGULATIONS OF THE DEPARTMENT OF ENVIRONMENTAL PROTECTION OR THE TERMS OR CONDITIONS OF THIS PERMIT SHALL VOID THE AUTHORITY GIVEN TO THE PERMITTEE BY THE ISSUANCE OF THE PERMIT.

THE PLANS, SPECIFICATIONS, REPORTS AND SUPPORTING DOCUMENTS SUBMITTED AS PART OF THE PERMIT APPLICATION BECOME PART OF THE PERMIT.

NO DEVIATIONS FROM APPROVED PLANS OR SPECIFICATIONS AFFECTING THE TREATMENT PROCESS OR QUALITY OF WATERS SHALL BE MADE WITHOUT WRITTEN APPROVAL FROM THE DEPARTMENT.

THIS PERMIT IS ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL PROTECTION UNDER THE AUTHORITY OF THE PENNSYLVANIA SAFE DRINKING WATER ACT, THE ACT OF MAY 1, 1984 (P.L. 206, NO. 43). OPERATION SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 109 ADOPTED UNDER THE AUTHORITY IN SECTIONS 4 AND 6(e) OF THE PENNSYLVANIA SAFE DRINKING WATER ACT.

THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS None

PERMIT ISSUED

DEPARTMENT OF ENVIRONMENTAL PROTECTION

Date DECEMBER 17, 2004

By *Brad E. Vanderhoof*
Brad E. Vanderhoof, P.E.
Regional Manager

Title Water Supply Management

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 WATER SUPPLY MANAGEMENT

APSID No. 489169
 Authorization ID No. 574951
 For Department Use Only

INTERNAL REVIEW AND RECOMMENDATIONS

NAME OF APPLICANT Greenville Borough WTP PROJECT LOCATION West Salem Township, Mercer County APPLICATION NUMBER 2884-MA1

BRIEF DESCRIPTION OF PROJECT AND DISCUSSION (Use additional sheets if necessary)

On November 15, 2004, a pre-operation inspection of the 0.255 MG West Main Street Water Storage Tank was conducted. The inspection found the tank to be painted as per the application and a new vent installed on the tank. The submission of the Certificate of Construction Completion Form was delayed due to a small area that needed repainting and a broken bolt on the manway cover.

CURRENT ESTIMATE OF COMPLETION DATE OF PROJECT

RECOMMENDATION AND ACTION

Approve	Return	Refuse	Signature	Date
✓			MATTHEW D. POSTLEWAITE REVIEWING ENGINEER <i>Matthew D. Postlewaite</i>	12/16/04
✓			ANTHONY TALAK JR., P.E. CHIEF OF TECHNICAL SERVICES <i>Anthony Talak Jr.</i>	12/17/04
✓			BRAD E. VANDERHOOF, P.E. REGIONAL MANAGER <i>Brad E. Vanderhoof</i>	12/17/04

PERMIT CONDITIONS:

1. STANDARD -- None
2. SPECIAL (Use additional sheets if necessary) -- None

COPY

PUBLIC WATER SUPPLY PERMIT

NO. 4307503

A. PERMITTEE: (Name and Address)

Greenville Water Authority
440 Clinton Street
Greenville, PA 16125

B. PROJECT/PLANT LOCATION

Municipality Hempfield Township
County Mercer

C. THIS PERMIT APPROVES FOR:
AS INDICATED BELOW:

1. CONSTRUCTION

2. OPERATION OF FACILITIES

Approved Under Construction Permit No. 4307503

- | <u>Source</u> | <u>Facilities</u> | <u>BVRB</u> |
|---|--|--|
| <input type="checkbox"/> Well(s) | <input type="checkbox"/> Impoundment | <input type="checkbox"/> Bottled Water System |
| <input type="checkbox"/> Spring(s) | <input type="checkbox"/> Settling | <input type="checkbox"/> Bulk Water Hauling System |
| <input type="checkbox"/> Surface Water | <input type="checkbox"/> Filtration | <input type="checkbox"/> Vented Water System |
| <input type="checkbox"/> Finished Water | <input type="checkbox"/> Iron and Manganese Treatment | <input type="checkbox"/> Retail Water Facility |
| | <input type="checkbox"/> Softening | |
| | <input type="checkbox"/> Fluoridation | |
| | <input type="checkbox"/> Distribution Facility | |
| | <input type="checkbox"/> General Corrosion Control | |
| | <input type="checkbox"/> Corrosion Control for lead/copper | |
| | <input type="checkbox"/> Disinfection | |
| | <input type="checkbox"/> Pump Station(s) | |
| | <input type="checkbox"/> Transmission Lines | |
| | <input checked="" type="checkbox"/> Finished Water Storage | |
| | <input type="checkbox"/> Other _____ | |

KNOWN AS A new 1.0 MG Water Storage Tank located along Hadley Road.

LIMIT OF AUTHORIZATION

YOU ARE HEREBY AUTHORIZED TO CONSTRUCT OR OPERATE, AS INDICATED ABOVE, PROVIDED THAT FAILURE TO COMPLY WITH CHAPTER 109, OF THE RULES AND REGULATIONS OF THE DEPARTMENT OF ENVIRONMENTAL PROTECTION OR THE TERMS OR CONDITIONS OF THIS PERMIT SHALL VOID THE AUTHORITY GIVEN TO THE PERMITTEE BY THE ISSUANCE OF THE PERMIT.

THE PLANS, SPECIFICATIONS, REPORTS AND SUPPORTING DOCUMENTS SUBMITTED AS PART OF THE PERMIT APPLICATION BECOME PART OF THE PERMIT.

NO DEVIATIONS FROM APPROVED PLANS OR SPECIFICATIONS AFFECTING THE TREATMENT PROCESS OR QUALITY OF WATERS SHALL BE MADE WITHOUT WRITTEN APPROVAL FROM THE DEPARTMENT.


THIS PERMIT IS ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL PROTECTION UNDER THE AUTHORITY OF THE PENNSYLVANIA SAFE DRINKING WATER ACT, THE ACT OF MAY 1, 1984 (P.L. 208, NO. 43). OPERATION SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 109 ADOPTED UNDER THE AUTHORITY IN SECTIONS 4 AND 6(e) OF THE PENNSYLVANIA SAFE DRINKING WATER ACT.

THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS None

PERMIT ISSUED

DEPARTMENT OF ENVIRONMENTAL PROTECTION

Date December 23, 2010

By 
Brad E. Vanderhoof, P.E.

Title Regional Manager
Water Supply Management

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
WATER SUPPLY MANAGEMENT

For Department Use Only

INTERNAL REVIEW AND RECOMMENDATIONS

NAME OF APPLICANT Greenville Water Authority PROJECT LOCATION Hempfield Township Mercer County APPLICATION NUMBER 4307503

BRIEF DESCRIPTION OF PROJECT AND DISCUSSION (Use additional sheets if necessary)

On November 15, 2010, the Department was notified that construction of the new 1.0 million gallon glass-lined, steel type finished water storage tank was complete. Follow-up documentation also included copies of laboratory test results for bacteriological and VOC samples as required in the special conditions that accompanied the construction permit.

A pre-operation permit inspection was conducted by Jason L. Minnich, of technical services section, on December 9, 2010. The inspection revealed that the facilities were completed in accordance with the construction permit specifications and the eight special conditions accompanying the construction permit.

The original construction permit was issued with the understanding that the storage tank conformed to all requirements of AWWA D103 Standards for Factory Coated Steel Tanks for Water Storage as specified. Also, the construction permit indicated that other portions of the project would conform with ANSI/NSF Standard 61 for all materials that came in contact with the inner surfaces. Also, all chemicals used for the disinfection process conformed to ANSI/NSF Standard 60.

Follow-up documentation, provided with the certificate of construction completion/modification, included copies of laboratory test results for bacteriological and VOC samples as required by the construction permit. The sample results indicated all samples were below their established MCLs. It should also be noted that bacteriological test results did not contain the presence of total or fecal coliform.

Based on the facility being constructed as proposed, and acceptable bacteriological and VOC results, it is recommended that the operation permit for the 1.0 million gallon glass-lined, steel type finished water storage tank be issued.

CURRENT ESTIMATE OF COMPLETION DATE OF PROJECT

RECOMMENDATION AND ACTION

Approve	Return	Refuse	Signature	Date
✓			JASON L. MINNICH REVIEWING ENGINEER <i>Jason L. Minnich</i>	12-23-10
✓			BRAD C. SCHOTT, P.E. ENVIRONMENTAL ENGINEER MANAGER <i>Brad C. Schott</i>	12-23-10
/			BRAD E. VANDERHOOF, P.E. REGIONAL MANAGER <i>Brad E. Vanderhoof</i>	12-23-10

PERMIT CONDITIONS:

- 1. STANDARD - NONE
- 2. SPECIAL (Use additional sheets if necessary) - NONE



PUBLIC WATER SUPPLY PERMIT

NO. 4388510-MA6

<p>A. PERMITTEE:</p> <p>Greenville Municipal Water Authority 44 Clinton Street Greenville, PA 16125</p>	<p>B. PROJECT/PLANT LOCATION</p> <p>Address <u>45 South Water Street</u> Municipality <u>Greenville Borough</u> County <u>Mercer</u></p>
--	---

C. THIS PERMIT APPROVES FOR: 1. CONSTRUCTION 2. OPERATION OF FACILITIES

AS INDICATED BELOW: Approved Under Construction Permit No. 4388510-MA6

Source	Facilities	BVRB	
<input type="checkbox"/> Well(s)	<input type="checkbox"/> Impoundment	<input type="checkbox"/> General Corrosion Control	<input type="checkbox"/> Bottled Water System
<input type="checkbox"/> Spring(s)	<input type="checkbox"/> Settling	<input type="checkbox"/> Corrosion Control for lead/copper	<input type="checkbox"/> Bulk Water Hauling System
<input type="checkbox"/> Surface Water	<input checked="" type="checkbox"/> Filtration	<input type="checkbox"/> Disinfection	<input type="checkbox"/> Vended Water System
<input type="checkbox"/> Finished Water	<input type="checkbox"/> Iron and Manganese Treatment	<input type="checkbox"/> Pump Station(s)	<input type="checkbox"/> Retail Water Facility
	<input type="checkbox"/> Softening	<input type="checkbox"/> Transmission Lines	
	<input type="checkbox"/> Fluoridation	<input type="checkbox"/> Finished Water Storage	
	<input type="checkbox"/> Distribution Facility	<input type="checkbox"/> Other _____	

KNOWN AS Greenville WTP: In-kind Filter Media and Underdrain Nozzle Replacement in all four (4) filter bays

LIMIT OF AUTHORIZATION

YOU ARE HEREBY AUTHORIZED TO CONSTRUCT OR OPERATE, AS INDICATED ABOVE, PROVIDED THAT FAILURE TO COMPLY WITH CHAPTER 109, OF THE RULES AND REGULATIONS OF THE DEPARTMENT OF ENVIRONMENTAL PROTECTION OR THE TERMS OR CONDITIONS OF THIS PERMIT SHALL VOID THE AUTHORITY GIVEN TO THE PERMITTEE BY THE ISSUANCE OF THE PERMIT.

THE PLANS, SPECIFICATIONS, REPORTS AND SUPPORTING DOCUMENTS SUBMITTED AS PART OF THE PERMIT APPLICATION BECOME PART OF THE PERMIT.

NO DEVIATIONS FROM APPROVED PLANS OR SPECIFICATIONS AFFECTING THE TREATMENT PROCESS OR QUALITY OF WATERS SHALL BE MADE WITHOUT WRITTEN APPROVAL FROM THE DEPARTMENT.

THIS PERMIT IS ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL PROTECTION UNDER THE AUTHORITY OF THE PENNSYLVANIA SAFE DRINKING WATER ACT, THE ACT OF MAY 1, 1984 (P.L. 206, NO. 43). OPERATION SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 109 ADOPTED UNDER THE AUTHORITY IN SECTIONS 4 AND 6(e) OF THE PENNSYLVANIA SAFE DRINKING WATER ACT.

THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS None

PERMIT ISSUED

Date June 16, 2022

DEPARTMENT OF ENVIRONMENTAL PROTECTION

By: 
Matthew D. Postlewaite
Regional Manager
Title Safe Drinking Water Program

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
SAFE DRINKING WATER PROGRAM

Date: May 30, 2018

Permit No.: 4303504-MA1

SPECIAL CONDITIONS

Greenville Municipal Water Authority

1. Prior to conducting a planned switch from chloramines to free chlorine (*i.e.*, chlorine burn), the permittee shall notify, the Department, all customers and other persons regularly served by the water supply, and, if applicable, all consecutive water systems served by the water supply. A similar notification, regarding the change in disinfectant, shall be conducted prior to reverting back to use of chloramines. The notification shall be in a form and manner reasonably designed to reach all persons served during the relevant time period and no more than 60 days prior to the chemical switch. If an unplanned chemical switch becomes necessary, the Permittee shall consult with the Department regarding customer notification prior to making the switch.

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES
BUREAU OF COMMUNITY ENVIRONMENTAL CONTROL

PUBLIC WATER SUPPLY PERMIT

NO. 4388510

<p>A. PERMITTEE: (Name and Address)</p> <p>Municipal Authority of the Borough of Greenville P.O. Box 638 44 Clinton Street Greenville, PA 16125</p>	<p>B. PROJECT LOCATION</p> <p>Municipality <u>Greenville</u> County <u>Mercer</u></p>		
<p>C. THIS PERMIT APPROVES FOR: 1. <input checked="" type="checkbox"/> Use as Source of Supply 2. <input type="checkbox"/> Construction 3. <input checked="" type="checkbox"/> Operation</p> <p>AS INDICATED BELOW:</p> <table style="width:100%; border: none;"> <tr> <td style="width:50%; vertical-align: top; padding: 5px;"> <p>4. Source</p> <p><input type="checkbox"/> Well(s) <input type="checkbox"/> Spring(s) <input checked="" type="checkbox"/> Stream <input type="checkbox"/> Lake</p> </td> <td style="width:50%; vertical-align: top; padding: 5px;"> <p>5. Facilities</p> <p><input type="checkbox"/> Impoundment <input checked="" type="checkbox"/> Settling <input checked="" type="checkbox"/> Filtration <input type="checkbox"/> Iron and Manganese Treatment <input type="checkbox"/> Softening <input checked="" type="checkbox"/> Fluoridation <input type="checkbox"/> Other _____</p> </td> </tr> </table>		<p>4. Source</p> <p><input type="checkbox"/> Well(s) <input type="checkbox"/> Spring(s) <input checked="" type="checkbox"/> Stream <input type="checkbox"/> Lake</p>	<p>5. Facilities</p> <p><input type="checkbox"/> Impoundment <input checked="" type="checkbox"/> Settling <input checked="" type="checkbox"/> Filtration <input type="checkbox"/> Iron and Manganese Treatment <input type="checkbox"/> Softening <input checked="" type="checkbox"/> Fluoridation <input type="checkbox"/> Other _____</p>
<p>4. Source</p> <p><input type="checkbox"/> Well(s) <input type="checkbox"/> Spring(s) <input checked="" type="checkbox"/> Stream <input type="checkbox"/> Lake</p>	<p>5. Facilities</p> <p><input type="checkbox"/> Impoundment <input checked="" type="checkbox"/> Settling <input checked="" type="checkbox"/> Filtration <input type="checkbox"/> Iron and Manganese Treatment <input type="checkbox"/> Softening <input checked="" type="checkbox"/> Fluoridation <input type="checkbox"/> Other _____</p>		
<p>KNOWN AS: <u>The Shenango River</u></p>			
<p>YOU ARE HEREBY AUTHORIZED TO USE AS SOURCE(S) OF SUPPLY, CONSTRUCT OR OPERATE, AS INDICATED ABOVE, PROVIDED THAT FAILURE TO COMPLY WITH CHAPTER 109, ARTICLE II, OF THE RULES AND REGULATIONS OF THE DEPARTMENT OF ENVIRONMENTAL RESOURCES OR THE TERMS OR CONDITIONS OF THIS PERMIT SHALL VOID THE AUTHORITY GIVEN TO THE PERMITTEE BY THE ISSUANCE OF THE PERMIT.</p> <p>NO DEVIATIONS FROM APPROVED PLANS OR SPECIFICATIONS AFFECTING THE TREATMENT PROCESS OR QUALITY OF WATERS SHALL BE MADE WITHOUT WRITTEN APPROVAL FROM THE DEPARTMENT.</p> <p>THIS PERMIT IS ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL RESOURCES UNDER THE AUTHORITY OF THE PENNSYLVANIA SAFE DRINKING WATER ACT, THE ACT OF MAY 1, 1984 (P.L. 206, NO. 43). OPERATION SHALL COMPLY WITH THE PROVISIONS OF CHAPTER 109 ADOPTED UNDER THE AUTHORITY IN SECTIONS 4 AND 6(e) OF THE PENNSYLVANIA SAFE DRINKING WATER ACT.</p> <p>THIS PERMIT IS SUBJECT TO THE ATTACHED SPECIAL CONDITIONS <u>#1</u></p> <p>THIS PERMIT IS SUBJECT TO THE FOLLOWING STANDARD CONDITIONS RELATING TO EROSION CONTROL <u>None</u></p>			
<p>PERMIT ISSUED</p> <p>Date <u>November 29, 1990</u></p>	<p>DEPARTMENT OF ENVIRONMENTAL RESOURCES</p> <p>By <u>George Senott</u> George Senott Regional Environmental Title <u>Protection Manager</u></p>		

SPECIAL CONDITION

1. A Hach 1720C turbidity monitor(s) or better shall be installed to monitor the filter to waste turbidities from each of the four (4) filters. It shall be controlled automatically such that the filter to waste will continue until the turbidity is less than 0.5 NTU. The filter to waste period of time may also be controlled by a minimum time as established by the Engineer and permittee for those situations where the turbidity is less than 0.5 NTU and the filter was being backwashed due to headloss. All installation(s) shall be completed within ninety (90) days of the issuance of this permit.