



**COMMONWEALTH OF PENNSYLVANIA**  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
COMMONWEALTH KEYSTONE BUILDING  
400 NORTH STREET  
HARRISBURG, PENNSYLVANIA 17120

April 25, 2025

Docket No. A-2025-3054731

Utility Code: 110550

KENNETH M KULAK  
MORGAN LEWIS & BOCKIUS LLP  
2222 MARKET STREET  
PHILADELPHIA PA 19103-2921

Re: Letter of Notification of PECO Energy Company for the 220-09 230 kV Transmission Line Tap Located in Chester County, Pennsylvania.

Dear Mr. Kulak:

On April 14, 2025, PECO Energy Company (PECO) filed a Letter of Notification for approval to construct the 220-09 230 kV Transmission Line Tap in Chester County, Pennsylvania. In order for us to complete our analysis of the subject application, the Bureau of Technical Utility Services requires answers to the enclosed data requests. This information is necessary for completion of our review of the filing.

Please forward the requested information to the Secretary of the Commission **within ten (10) days** of receipt of this letter. Failure to respond may result in the Letter of Notification being denied. As well, if PECO has decided to withdraw its filing, please reply notifying the Commission of such a decision.

All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilings with the Secretary of the Commission by opening an efilings account through the Commission's website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilings system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response and mark the materials "CONFIDENTIAL" in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

The overnight address for hard-copy or confidential responses is:

Matthew L. Homsher, Secretary  
Pennsylvania Public Utility Commission  
400 North Street, 2<sup>nd</sup> Floor  
Harrisburg, PA 17120


**Your answers should be verified per 52 Pa Code § 1.36.** Accordingly, you must provide the following statement with your responses:

*I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).*

Signature \_\_\_\_\_  
Title \_\_\_\_\_  
Date \_\_\_\_\_

In addition, to expedite analysis of the Letter of Notification, send a copy of your response to Jordan Van Order at [jvanorder@pa.gov](mailto:jvanorder@pa.gov). If any problems arise that prevent a full timely response or if any clarification of these data requests is needed, contact Jordan Van Order, Bureau of Technical Utility Services, at [jvanorder@pa.gov](mailto:jvanorder@pa.gov) (preferred) or 717-787-8763.

Sincerely,



Matthew L. Homsher  
Secretary

Enclosure

**Bureau of Technical Utility Services**

**Data Requests**

Docket No. A-2025-3054731

- A-1 Reference the Letter of Notification, Paragraph 6. Please state separately the transmission costs and distribution costs. Additionally, please provide a detailed explanation as to how PECO differentiates between transmission and distribution for customers taking service at 230 kV.
- A-2 Reference the Letter of Notification, Paragraph 6. Please provide a detailed explanation as to how PECO will recover its investment should the customer decide to cancel the subject project.
- A-3 Reference the Letter of Notification, Paragraph 12. Please state the approximate width of the right-of-way for the proposed 220-09 230 kV line tap.
- A-4 Reference the Letter of Notification, Attachment 2, Section 6. Please state the approximate height of nearby existing transmission line structures.