



AN EXELON COMPANY

**Richard G. Webster, Jr.**  
Vice President  
Regulatory Policy & Strategy

Telephone 215.841.5777  
Fax 215.841.6208  
www.peco.com  
dick.webster@peco-energy.com

PECO  
2301 Market Street  
S15  
Philadelphia, PA 19103

May 6, 2025

**VIA E-Filing**

Matt Homsher, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street  
Harrisburg, Pennsylvania 17120

RE: REVISED Response to TUS Data Request  
PECO Energy Company ("PECO") Request for Exclusion of a Major Outage for Reliability  
Reporting Purposes. Docket No. M-2025-3054158

Dear Secretary Homsher:

Pursuant to the Commission's April 3, 2025 Secretarial Letter in the above referenced docket, enclosed please find PECO Response to the Data Requests of the Bureau of Technical Utility Services ("Data Requests").

PECO requested, and the PUC granted, an extension until April 24, 2025 for the due date of PECO's responses to the Data Requests. On April 24th, PECO filed a confidential version of the responses. It was later determined that there is not confidential information contained within the responses. As such, we are re-filing the responses to the data requests removing the confidential designation. The Company requests the Secretary's Bureau to remove the existing response that was filed on April 24th from the record at Docket No. M-2025-3054158 and replace it with this revised response. We appreciate the opportunity to provide the necessary information and address your questions.

We trust that the information provided addresses your questions comprehensively. Thank you for your assistance in this matter and please direct any questions regarding the above to Megan McDevitt, Senior Manager, Retail Rates at 267-533-1942 or via email: [megan.mcdevitt@exeloncorp.com](mailto:megan.mcdevitt@exeloncorp.com).

A handwritten signature in black ink, appearing to read "R.G.W." followed by a long horizontal flourish.

Attachment

CC: Dan Searforce, Bureau of Technical Utility Services (via e-mail)  
John Van Zant, Bureau of Technical Utility Services (via e-mail)  
Kelly Monaghan, Deputy Executive Director (via e-mail)  
Kathleen Aunkst, Secretary's Bureau (via e-mail)  
Brent Killian, Bureau of Investigation and Enforcement (via e-mail)

**PECO Response to  
TUS Data Request 1  
PECO Energy Company Request to the Pennsylvania Public Utility Commission  
for Exclusion of Major Outage for Reliability Reporting Purposes**

**Docket No. M-2025-3054158**

**April 24, 2025**

1. Reference PECO Energy Company's (PECO) Exclusion Request for reliability reporting purposes.
  - A. PECO states that the first customer service interruption occurred on 2/16/2025, and provided weather forecasts for 2/15/2025, and 2/16/ 2025, respectively.
    - i. For this specific storm event provide the following:
      1. The weather event or cause of the service interruptions that began 2/16/2025.

Weather Report from 02/16/2025

Rain and a slight risk of thunderstorms are expected today as a cold front approaches the area. The front will move through near midday with very gusty winds expected. Showers could linger into the late afternoon to early evening hours. Dry and very breezy conditions will prevail tomorrow into Tuesday, with some snow possible on Wednesday afternoon into Thursday, with dry conditions prevailing from Thursday night into the weekend. [Source: StormGeo]


Preparer: Vincent Cuce, Director of Engineering

2. The total number of customer-minutes-interrupted for this event.

Dates	Customer Minutes
02/16/2025 14:55H – 02/19/2025 06:27H	89,877,112

Preparer: Vincent Cuce, Director of Engineering

3. A restoration curve for the storm event.



Preparer: Vincent Cuce, Director of Engineering

B. PECO states that the first customer service interruption occurred on 2/16/2025 and that the last affected customer was restored on 2/21/2025.

i. For this specific event, provide the following:

1. The total number of customers experiencing interruptions, by day, from 2/16/2025 through 2/21/2025.

Date	Customer Interruptions
2/16/2025*	175,234
2/17/2025	42,991
2/18/2025	17,614
2/19/2025*	3,384

*\*Please note that the customer interruptions listed are exclusively those impacted by the storm event and do not include customers who experienced interruptions unrelated to the storm event.*

Preparer: Vincent Cuce, Director of Engineering

2. The total number of trouble cases, by day, from 2/16/2025 through 2/21/2025.

Date	Trouble Cases
2/16/2025*	872
2/17/2025	300
2/18/2025	111
2/19/2025*	13

*\*Please note that the trouble cases listed are exclusively those impacted by the storm event and do not include trouble cases unrelated to the storm event.*

Preparer: Vincent Cuce, Director of Engineering

3. The total number of affected customers restored, by day, from 2/16/2025 through 2/21/2025.

Date	Number of Customers Restored
2/16/2025	109,800
2/17/2025	98,364
2/18/2025	25,751
2/19/2025	5,194
2/20/2025	105
2/21/2025	9

*\*Please note that the customers restored listed are exclusively those impacted by the storm event and do not include customers who experienced outages unrelated to the storm event.*

Preparer: Vincent Cuce, Director of Engineering

4. The date and time that the longest outage of the event began and the date and time that the longest outage of the event was restored, the number of customers impacted by that outage, the customer-minutes-interrupted for that outage, the cause of that outage, and the approximate location of that outage (i.e., township/municipality and county).


One customer in Wynnewood, PA, Montgomery County, experienced a power outage starting on February 17, 2025, at 07:02 AM, which lasted until February 21, 2025, at 04:46 PM, totaling 6,344 minutes. This outage was part of a larger event affecting numerous customers due to vegetation. However, this particular customer remained without power due to damaged secondaries caused by a fallen tree. The tree damaged the customer's service entrance equipment requiring additional repairs that were outside of PECO's scope. PECO notified the customer on 02/19/2025 at 10:05 AM of the additional work. After the customer made repairs to their equipment, power was restored as soon as access to the customer's property was possible.

Preparer: Vincent Cuce, Director of Engineering

**VERIFICATION**

I, Vincent J. Cuce, hereby declare that I am the Director of Engineering for PECO Energy Company; that, as such, I am authorized to make this verification on its behalf; that the facts set forth in the foregoing Data Responses are true and correct to the best of my knowledge, information and belief; and that I make this verification subject to the penalties of 18 Pa.C.S. §4904 pertaining to false statements to authorities.

Dated: 4/24/2025

  
\_\_\_\_\_  
Vincent J. Cuce