



AN EXELON COMPANY

Richard G. Webster, Jr.
Vice President
Regulatory Policy & Strategy

Telephone 215.841.5777
Fax 215.841.6208
www.peco.com
dick.webster@peco-energy.com

PECO
2301 Market Street
S15
Philadelphia, PA 19103

May 7, 2025

Via E-Filing

Matt Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-00991220
Request for Major Event Exclusion**

Dear Secretary Homsher:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is the Request for Exclusion of a Major Outage for reliability reporting purposes. As directed by Dan Searfoorce of the Bureau of Technical Utility Services, PECO requests this filing be accepted nunc pro tunc so that it will be docketed as if filed on February 9, 2024.

The enclosed report contains the Request for Major Exclusion. The major event occurred **January 9, 2024 – January 14, 2024**, and was caused by heavy wind, and rain that caused downed tree limbs on power lines and interrupted electric service.

Thank you for your assistance in this matter and please direct any questions regarding the above to Megan McDevitt, Senior Manager, Retail Rates at 267-533-1942 or via email: megan.mcdevitt@exeloncorp.com.

Sincerely,

Attachment

CC: Dan Searfoorce, Bureau of Technical Utility Services (via e-mail)
Derek Ruhl, Bureau of Technical Utility Services (via e-mail)
John Van Zant, Bureau of Technical Utility Services (via e-mail)
RA-PUCPEMA@pa.gov

APPENDIX D
 REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
 RELIABILITY REPORTING PURPOSES TO
 PENNSYLVANIA PUBLIC UTILITY COMMISSION
 P O BOX 3265
 HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy
 Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:

Vincent Cuce
(Name)

Director of Engineering
(Title)

3. Telephone number: 215-841-4212
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 194,662

Total number of customers in service territory 1,687,053

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

County	Sustained Customer Interruptions
BUCKS	27,484
CHESTER	89,504
DELAWARE	51,423
MONTGOMERY	18,200
PHILADELPHIA	7,639
YORK	412

(c) Reason for interruption or outage, including weather data where applicable:

Heavy winds, lightning and rain caused downed tree limbs on power lines and interrupted electric service to 194,662 customers

Forecast issued on MONDAY, JANUARY 08, 2024 TIME: 13:00

A strong low pressure system will bring heavy rain and very strong winds to the region tomorrow afternoon into early Wednesday morning. Look for rain to spread into the region by the late morning hours, becoming heavy at times through the afternoon and into the evening.

Very strong winds will also develop by the afternoon and peak from around 6pm Tuesday to 2am Wednesday.

Forecast issued on TUESDAY, JANUARY 09, 2024 TIME: 05:00

A strong low pressure system will bring heavy rain and very strong winds to the region this afternoon into this evening and early Wednesday morning. Look for rain to spread into the region by the late morning hours, becoming heavy at times through the afternoon and into the evening. Very strong winds will also develop by the afternoon with the strongest wind gusts expected this evening into early Wednesday morning.

- (d) The number of utility workers and others assigned specifically to the repair work:

1,388

- (e) The date and time of the first notification of a service interruption: 01/09/2024 14:27

- (f) The actual time that service was restored to the last affected customer: 01/14/2024 14:42

Remarks: _____