

M-2025-3052787

PUC Notification – Major Construction Report PECO Gas Projects Exceeding \$300,000

Notification Date:5/7/2025

| PA §59.38 | Information Requested by PUC | Data Provided by PECO |
|-----------|--|---|
| 1 | Description of Proposed Work (e.g., replace 700' of 4" cast iron, new regulator station, etc.) | <i>Install 2950 ft 8"PL, 500 ft 4"PL, 30 ft 6"PL, 60 ft 2"PL</i> <i>Renew 12, Transfer 26 services</i> <i>Retire 2835 ft 8"CI, 35 ft 4"ST, 20 ft 4"ST, 390 ft 4"CI</i> |
| | City/Borough/Township and County | Upper Darby Twp / Delaware County |
| | Extents of Project (e.g., Main St. from 4th to 7th) | Burmont Rd from US-1 to Marvine Ave, Marvine and Roberts from Burmont to Bond, Bond from Roberts to Addingham |
| 2 | Type of Facility (if other, please describe) | <input checked="" type="checkbox"/> Distribution Main/Services <input type="checkbox"/> Transmission Main <input type="checkbox"/> Regulator/Gate Station <input type="checkbox"/> Other: Click or tap here to enter text. |
| 3 | Estimated Starting Date | 3/31/2025 |
| 4 | Estimated Completion Date | 11/1/2025 |
| 5 | Design Pressure | Medium Pressure |
| 6 | Estimated Cost | \$954,906 |
| 7 | Reporting Company (name and address) | PECO, an Exelon Company 2301 Market St Philadelphia, PA 19103 |
| 8 | Project Contact (name, address and phone number) | Greg Cundari 300 Front Street, Building 2 Conshohocken, PA 19428 267-533-0255 |
| 9 | Actual Completion Date (to be sent after project complete) | Click or tap to enter a date. |