

M-2025-3052787

## PUC Notification – Major Construction Report PECO Gas Projects Exceeding \$300,000

Notification Date:5/8/2025

PA §59.38	Information Requested by PUC	Data Provided by PECO
1	<b>Description of Proposed Work</b> (e.g., replace 700' of 4" cast iron, new regulator station, etc.)	<i>Install 960 ft 6"PL, 1205 ft 4"PL, 200 ft 2"PL Renew 16, Transfer 35 services Retire 530 ft 4"DI, 250 ft 4"CI, 430 ft 4"PL, 190 ft 2"PL</i>
	<b>City/Borough/Township and County</b>	Downingtown Boro / Chester County
	<b>Extents of Project</b> (e.g., Main St. from 4th to 7th)	Stuart Ave from W Pennsylvania Ave to Manor Ave, Webster Ave, Downing Ave
2	<b>Type of Facility</b> (if other, please describe)	<input checked="" type="checkbox"/> Distribution Main/Services <input type="checkbox"/> Transmission Main <input type="checkbox"/> Regulator/Gate Station <input type="checkbox"/> Other: Click or tap here to enter text.
3	<b>Estimated Starting Date</b>	1/22/2025
4	<b>Estimated Completion Date</b>	11/1/2025
5	<b>Design Pressure</b>	High Pressure
6	<b>Estimated Cost</b>	\$569,761
7	<b>Reporting Company</b> (name and address)	PECO, an Exelon Company 2301 Market St Philadelphia, PA 19103
8	<b>Project Contact</b> (name, address and phone number)	Dwight Lasure 300 Front Street, Building 2 Conshohocken, PA 19428 484-947-9686
9	<b>Actual Completion Date</b> (to be sent after project complete)	Click or tap to enter a date.