



COMMONWEALTH OF PENNSYLVANIA  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE  
REFER TO OUR FILE

May 13, 2025

Docket No.: M-2025-3054158  
Utility Code: 110550

RICHARD G. WEBSTER, JR.  
VICE PRESIDENT REGULATORY POLICY & STRATEGY  
PECO ENERGY COMPANY  
2301 MARKET STREET-S15  
PHILADELPHIA, PA 19103  
[dick.webster@peco-energy.com](mailto:dick.webster@peco-energy.com)

RE: Request to the Pennsylvania Public Utility Commission for Exclusion of Major  
Outage for Reliability Reporting Purpose

Dear Mr. Webster:

On March 24, 2025, PECO Energy Company (PECO) filed a request for exclusion of major outage (Exclusion Request) for reliability reporting purposes in accordance with the requirements of the Commission's Order entered May 11, 2004, at M-00991220. On April 3, 2025, via Secretarial Letter, the Commission sent PECO a data request seeking additional information regarding PECO's Exclusion Request and extended the consideration period of PECO's Exclusion Request to April 30, 2025. On April 24, 2025, PECO filed its response and a revised Exclusion Request (Revised Exclusion Request). On April 30, 2025, via Secretarial Letter, the Commission further extended the consideration period of the Exclusion Request to May 30, 2025. On May 6, 2025, PECO filed a Revised Response that revised and replaced the Revised Exclusion Request filed on April 24, 2025.

In supplemental information provided to the Commission, PECO states that heavy winds and rain caused downed tree limbs on power lines that interrupted electric service to 239,223 customers starting on February 16, 2025. PECO states that this event caused an interruption in service to 239,223 customers out of a total of 1,667,008 customers served. PECO reports that there were 89,877,112 customer-minutes-interrupted for this event. PECO states the event caused service interruptions from February 16, 2025, at 14:55 hours to February 19, 2025, at 06:27 hours.

Upon review of the company's Revised Exclusion Request and supplemental information provided, it appears that the service interruptions described by PECO qualify as a major event, as defined in 52 Pa. Code § 57.192(i)(A). Therefore, the Revised Exclusion Request is hereby approved. However, the Commission's approval is contingent upon the possibility that subsequent audits, reviews, and inquiry, in any Commission proceeding, may be conducted, pursuant to 52 Pa. Code §57.197 (relating to reliability investigations and enforcement).

In addition, this approval will apply only to the matter and parties specifically and clearly defined under this instant filing.

If you are dissatisfied with the resolution of this matter, you may, as set forth in 52 Pa. Code §5.44, file a petition with the Commission within 10 days of the date of this letter. If you have any questions on this matter, please contact John Van Zant, Bureau of Technical Utility Services, at [jvanzant@pa.gov](mailto:jvanzant@pa.gov), or (717) 787-3810.

Sincerely,

A handwritten signature in cursive script that reads "Matthew L. Homsher".

Matthew L. Homsher  
Secretary

cc: Dan Searfoorce, TUS  
John Van Zant, TUS  
Kelly Monaghan, AUD  
Kathleen Aunkst, SEC  
Brent Killian, BIE  
Megan McDevitt, PECO, [megan.mcdevitt@exeloncorp.com](mailto:megan.mcdevitt@exeloncorp.com)