



AN EXELON COMPANY

Richard G. Webster, Jr.
Vice President
Regulatory Policy & Strategy

Telephone 215.841.5777
Fax 215.841.6208
www.peco.com
dick.webster@peco-energy.com

PECO
2301 Market Street
S15
Philadelphia, PA 19103

July 11, 2025

Via E-Filing

Matt Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-00991220
Request for Major Event Exclusion**

Dear Secretary Homsher:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is the Request for Exclusion of a Major Outage for reliability reporting purposes.

The enclosed report contains the Request for Major Exclusion. The major event occurred **June 19, 2025 – June 22, 2025**, and was caused by heavy wind, and rain that caused downed tree limbs on power lines and interrupted electric service.

Thank you for your assistance in this matter and please direct any questions regarding the above to Megan McDevitt, Senior Manager, Retail Rates at 267-533-1942 or via email: megan.mcdevitt@exeloncorp.com.

Sincerely,

Attachment

CC: Dan Searfoorce, Bureau of Technical Utility Services (via e-mail)
Derek Ruhl, Bureau of Technical Utility Services (via e-mail)
John Van Zant, Bureau of Technical Utility Services (via e-mail)
RA-PUCPEMA@pa.gov

APPENDIX D
 REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR
 RELIABILITY REPORTING PURPOSES TO
 PENNSYLVANIA PUBLIC UTILITY COMMISSION
 P O BOX 3265
 HARRISBURG, PA 17105-3265

Reports require an original and one copy to be filed with the Secretary's Bureau.

Information Required:

1. Requesting Utility: PECO Energy
 Address: 2301 Market St.
Philadelphia, Pa 19101

2. Name and title of person making request:

Vincent Cuce Director of Engineering
(Name) *(Title)*

3. Telephone number: +1 215 841 4212
(Telephone Number)

4. Interruption or Outage:

(a) Number of customers affected: 377,090

Total number of customers in service territory 1.66 million

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

County	Sustained Customer Interruptions
BUCKS	86,579
CHESTER	69,328
DELAWARE	105,204
MONTGOMERY	80,631
PHILADELPHIA	34,274
YORK	1,074

(c) Reason for interruption or outage, including weather data where applicable:

Heavy winds and rain caused downed tree limbs on power lines and interrupted electric service.

(d) The number of utility workers and others assigned specifically to the repair work:

3,259

(e) The date and time of the first notification of a service interruption: 06/19/2025 15:32

(f) The actual time that service was restored to the last affected customer: 06/26/2025 17:39