



AN EXELON COMPANY

**Richard G. Webster, Jr.**  
Vice President  
Regulatory Policy & Strategy

Telephone 215.841.5777  
Fax 215.841.6208  
www.peco.com  
dick.webster@peco-energy.com

PECO  
2301 Market Street  
S15  
Philadelphia, PA 19103

August 13, 2025

**Via E-Filing**

Matt Homsher, Secretary  
Pennsylvania Public Utility Commission  
Commonwealth Keystone Building  
400 North Street  
Harrisburg, Pennsylvania 17120

**Re: PUC Docket No. M-00991220  
REVISED Request for Major Event  
Exclusion**

Dear Secretary Homsher:

In accordance with the Amended Reliability Benchmark and Standard for the Electric Distribution Companies, enclosed is a REVISED Request for Exclusion of a Major Outage for reliability reporting purposes.

The enclosed report contains the REVISED Request for Major Exclusion. Pursuant to instruction by Technical Utility Staff, PECO requests that this revised report replace the previous request for major exclusion filed on July 11, 2025. The major event occurred **June 19, 2025 – June 23, 2025**, and was caused by heavy wind, and rain that caused downed tree limbs on power lines and interrupted electric service.

Thank you for your assistance in this matter and please direct any questions regarding the above to Megan McDevitt, Senior Manager, Retail Rates at 267-533-1942 or via email: [megan.mcdevitt@exeloncorp.com](mailto:megan.mcdevitt@exeloncorp.com).

Sincerely,

Attachment

CC: Dan Searfoorce, Bureau of Technical Utility Services (via e-mail)  
Derek Ruhl, Bureau of Technical Utility Services (via e-mail)  
John Van Zant, Bureau of Technical Utility Services (via e-mail)  
[RA-PUCPEMA@pa.gov](mailto:RA-PUCPEMA@pa.gov)

APPENDIX D  
 REQUEST FOR EXCLUSION OF MAJOR OUTAGE FOR  
 RELIABILITY REPORTING PURPOSES TO  
 PENNSYLVANIA PUBLIC UTILITY COMMISSION  
 P O BOX 3265  
 HARRISBURG, PA 17105-3265

**Reports require an original and one copy to be filed with the Secretary's Bureau.**

Information Required:

1. Requesting Utility: PECO Energy  
 Address: 2301 Market St.  
Philadelphia, Pa 19101

2. Name and title of person making request:

Vincent Cuce Director of Engineering  
*(Name)* *(Title)*

3. Telephone number: +1 215 841 4212  
*(Telephone Number)*

4. Interruption or Outage:

(a) Number of customers affected: 368,786

Total number of customers in service territory 1.66 million

(b) Number of troubled locations in each geographic area affected listed by county and local political subdivision:

County	Sustained Customer Interruptions
BUCKS	83,972
CHESTER	67,522
DELAWARE	103,182
MONTGOMERY	79,818
PHILADELPHIA	33,216
YORK	1,076

(c) Reason for interruption or outage, including weather data where applicable:

Heavy winds and rain caused downed tree limbs on power lines and interrupted electric service.

(d) The number of utility workers and others assigned specifically to the repair work:

3,259

(e) The date and time of the first notification of a service interruption: 06/19/2025 16:21

(f) The actual time that service was restored to the last affected customer: 06/27/2025 14:04