



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
COMMONWEALTH KEYSTONE BUILDING
400 NORTH STREET
HARRISBURG, PENNSYLVANIA 17120

August 15, 2025

Docket Nos. A-2025-3056806
P-2025-3056867
Utility Code: 110500

GARRETT P LENT
POST & SCHELL P. C.
17 NORTH SECOND STREET 12TH FLOOR
HARRISBURG PA 17101-1601

Re: Letter of Notification of PPL Electric Utilities Corporation for Approval to Construct the Susquehanna 230 kV and 500 kV Transmission Line Project Located in Luzerne County, Pennsylvania.

Dear Mr. Lent:

On August 11, 2025, PPL Electric Utilities Corporation (PPL Electric) filed a Letter of Notification for approval to construct the Susquehanna 230 kV and 500 kV Transmission Line Project in Luzerne County, Pennsylvania. In order for us to complete our analysis of the subject application, the Bureau of Technical Utility Services requires answers to the enclosed data requests. This information is necessary for completion of our review of the filing.

Please forward the requested information to the Secretary of the Commission **within ten (10) days** of receipt of this letter. Failure to respond may result in the Letter of Notification being denied. As well, if PPL Electric has decided to withdraw its filing, please reply notifying the Commission of such a decision.

All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilings with the Secretary of the Commission by opening an efilings account through the Commission's website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilings system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response and mark the materials "CONFIDENTIAL" in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

The overnight address for hard-copy or confidential responses is:

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
400 North Street, 2nd Floor
Harrisburg, PA 17120

Your answers should be verified per 52 Pa Code § 1.36. Accordingly, you must provide the following statement with your responses:

I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Signature _____
Title _____
Date _____

In addition, to expedite analysis of the Letter of Notification, send a copy of your response to Jordan Van Order at jvanorder@pa.gov. If any problems arise that prevent a full timely response or if any clarification of these data requests is needed, contact Jordan Van Order, Bureau of Technical Utility Services, at jvanorder@pa.gov (preferred) or 717-787-8763.

Sincerely,



Matthew L. Homsher
Secretary

Enclosure

Bureau of Technical Utility Services
Data Requests

Docket Nos. A-2025-3056806 and P-2025-3056867

- A-1 Reference the Letter of Notification, page 2. Please file a petition for waiver of the Commission's regulations at 52 Pa. Code § 57.72(d)(1)(vi).
- A-2 Reference the Letter of Notification, page 2. Please provide a detailed explanation as to how each segment of the project would, on its own, meet the Commission's requirements for Letters of Notification. Additionally, please ensure that the explanation addresses work on the Sunbury – Susquehanna #1 230 kV line, Susquehanna – Transformer 21 230 kV line, and Susquehanna T10 – Transformer 10 Tap 230 kV line.
- A-3 Reference the Letter of Notification, page 2. Please state the approximate length of transmission line to be re-worked or modified as part of the re-termination of the Sunbury – Susquehanna #1 230 kV Line.
- A-4 Reference the Letter of Notification, page 2. Please state the approximate length of transmission line to be re-worked or modified as part of the re-termination of the Sunbury – Susquehanna #1 230 kV Line.
- A-5 Reference the Letter of Notification, Paragraph 17. Please explain how the subject project will address the issues related to the proceeding at FERC Docket No. ER24-2172.
- A-6 Reference the Letter of Notification, Paragraph 24. Please provide a detailed explanation as to why the customer is requesting to change its service from behind the meter to become network load.
- A-7 Reference the Letter of Notification, Paragraph 30. Please provide the estimated impact to the rates of PPL Electric's other transmission level customers.
- A-8 Reference the Letter of Notification, Paragraph 39. Please explain whether the increased capacity described is limited to increased available capacity upon project completion or whether it also includes any increase in current carrying capability regardless of available margin upon project completion.
- A-9 Reference the Letter of Notification, Paragraph 39. Please explain whether the lower impedance described is limited to upgrades where the modifications result in lower line losses or whether it also includes upgrades where line losses increase due to the large load addition.
- A-10 Reference the Letter of Notification, Paragraph 40. Please describe the upgrades which are included as part of the \$3.4 million.
- A-11 Reference the Letter of Notification, Paragraph 40. Please provide a detailed explanation as to how PPL Electric will recover its investment should the customer decide to cancel the subject project.

- A-12 Reference the Letter of Notification, Paragraph 43. Please state that approximate size, in terms of acres, of any new easements to be obtained for the subject project.
- A-13 Reference the Letter of Notification, Paragraph 53. Please state the approximate width of new and existing right-of-way for the proposed lines.
- A-14 Reference the Letter of Notification, Paragraph 73. Please describe the measures PPL Electric will take to avoid impacts to the wetland.
- A-15 Reference the Letter of Notification, Attachment 1, page 9. Please explain when PPL Electric anticipates completion PJM's do no harm analysis.
- A-16 Reference the Letter of Notification, Attachment 3, Sheet 1 & Sheet 3. Please provide a copy of the drawings which clearly label the existing transmission lines to be modified as part of the subject project.
- A-17 Reference the Letter of Notification, Attachment 3, Figure 3-1, Sheet 5. Please explain the purpose of the new section of 230 kV line extending from Pole #13 to an existing structure.