



Energy to do more®

PUC Notification of Proposed Major Expenditure

Submit reports to the PA PUC Secretary's Bureau through eFiling at

efiling.puc.pa.gov

Include case: Docket number **M-2025-3052787** in the notification

Also Email To: Safety Division

Email To The Following Addresses: RA-PC-Pipelinesafety@pa.gov & TCSmith@pa.gov

Regional Engineering Office	2121 City Line Rd., Bethlehem, PA 18017-2127
Description of Proposed Work	Replacing existing low pressure facilities with approximately 550' of 6" HDPE and 4,000' of 2" HDPE distribution mains via direct burial.
Location of Proposed Work	1500 5th St, Stroudsburg, Monroe County (5th St from Oakwood Ave to Wiley Ave; Wiley Ave from 5th St to around 641 Wiley Ave; Wallace St from Wiley Ave to Wizac Ave; Wizac Ave from Kind St to 5th St; Oakwood Ave from 5th St to end of main; Spruce St from Oakwood Ave to around 1564 Spruce St).
Type of Facility	Distribution Main
Estimated Starting Date	Estimated Starting Date: 12/8/2025
Design Pressure (MAOP, psi)	60.00
Estimated Cost	Estimated Cost: \$2,100,000
Reporting Gas Company for Project	UGI Central
Project Contact Person(s)	Steward, Timothy;
Project Contact Person(s) Address & Phone	Project Contact Person(s) Address & Phone: 2121 City Line Rd., Bethlehem, PA 18017; 610-807-3162

Estimated Completion Date	Estimated Completion Date: 3/2/2026 
Actual Completion Date	Actual Completion Date: <input type="text"/> 
PA PUC Notification Documentation	
Notified By (Proposed)	<input type="text" value="Steward, Timothy;"/>   
Notifier's Title (Proposed)	Notifier's Title (Proposition): <input type="text" value="Senior Manager Area Engineering"/>
Notification Date (Proposed)	Notification Date (Proposition): 9/18/2025 
Notified By (Actual Completion)	<input type="text"/>  
Notifier's Title (Actual Completion)	Notifier's Title (Actual Completion): <input type="text"/>
Notification Date (Actual Completion)	Notification Date (Actual Completion): <input type="text"/> 