



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE
REFER TO OUR FILE

September 29, 2025

Docket No.: M-2025-3056265
Utility Code: 110550

RICHARD G. WEBSTER
VICE PRESIDENT REGULATORY POLICY & STRATEGY
PECO ENERGY
2301 MARKET STREET
S15
PHILADELPHIA, PA 19101
dick.webster@peco-energy.com

RE: Request for Exclusion of Major Outage for Reliability Reporting Purposes.

Dear Mr. Webster:

On July 11, 2025, PECO Energy Company (PECO) filed a request for exclusion of major outage for reliability reporting purposes (Exclusion Request) in accordance with the requirements of the Commission's Order entered May 11, 2004, at M-00991220. On July 30, 2025, via Secretarial Letter, the Commission sent PECO a data request seeking additional information regarding PECO's Exclusion Request and extended the consideration period of PECO's Exclusion Request to September 30, 2025. On August 13, 2025, PECO filed a revised Exclusion Request (Revised Exclusion Request). On August 20, 2025, PECO filed a response to the data request.


PECO stated that the Revised Exclusion Request relates to service interruptions resulting from a weather event that started on June 19, 2025. PECO reported that heavy winds and rain downed tree limbs onto power lines. In total, 368,786 customers out of approximately 1.66 million customers served were affected. PECO noted that 3,259 utility workers and others specifically assigned to repair work were dispatched. PECO stated that the first customer service interruption occurred at approximately 16:21 hours on June 19, 2025, and that service was restored to the last affected customer at 14:04 hours on June 27, 2025. The incident resulted in a total of 329,497,583 Customer-Minutes-Interrupted.

Upon review of the company's filing, it appears that the service interruptions described by PECO qualify as a major event, as defined in 52 Pa. Code § 57.192(i)(A). Therefore, the Revised Exclusion Request is hereby approved. However, the Commission's approval is contingent upon the possibility that subsequent audits, reviews, and inquiry, in any Commission proceeding, may be conducted, pursuant to 52 Pa. Code §57.197 (relating to Reliability investigations and enforcement).

In addition, this approval will apply only to the matter and parties specifically and clearly defined under this instant filing.

If you are dissatisfied with the resolution of this matter, you may, as set forth in 52 Pa. Code §5.44, file a petition with the Commission within 10 days of the date of this letter. If you have any questions on this matter, please contact Clinton McKinley, Bureau of Technical Utility Services, at cmckinley@pa.gov, or (717) 783-6161.

Sincerely,

A handwritten signature in black ink that reads "Matthew L. Homsher". The signature is written in a cursive style with a large initial "M".

Matthew L. Homsher
Secretary

cc: Dan Searfoorce, TUS
John Van Zant, TUS
Chris Yother, AUD
Kathleen Aunkst, SEC
Brent Killian, BIE