

Morgan Lewis

Kenneth M. Kulak

Partner

+1.215.963.5384

ken.kulak@morganlewis.com

October 17, 2025

VIA ELECTRONIC FILING

Matthew Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
Harrisburg, PA 17120

**Re: Letter of Notification of PECO Energy Company Filed Pursuant to 52 Pa. Code §§ 57.71 *et seq.* for Approval of the Siting and Construction of the 220-80 Line and 220-101 Line Located in Norristown, West Norriton Township, and Upper Merion Township, Montgomery County, Pennsylvania
Docket No. A-2025-3057320**

Dear Secretary Homsher:

On September 9, 2025, PECO Energy Company (“PECO”) filed a Letter of Notification (“LON”) in the above-captioned docket requesting Commission approval to construct two transmission lines and related structures related to the 220-80 Line and 220-101 Line within Norristown, West Norriton Township, and Upper Merion Township, Montgomery County, Pennsylvania to connect to the new Forge Springs Substation (the “Project”).

The LON included Plan and Profile Drawings of the Project (as Attachment 1) reflecting the proposed location for the transmission lines and structures of the Project. Subsequent to filing the LON and based on additional inspections, PECO determined that the proposed location for the new structures 11/3A and 11/3B of the 220-80 Line could pose a safety concern because the 220-80 Line as initially designed would traverse over a nearby set of seven propane storage tanks which could lead to a catastrophic result in the event the conductor was to contact the flammable propane storage tanks. The propane storage tanks are owned by Norfolk Southern and are used to support a nearby railroad track.

In order to reduce the proximity of the 220-80 Line to the propane storage tanks, PECO has revised the design of the proposed Project to locate proposed new structure 11/3B approximately 225 feet to the southeast of the originally proposed location and to increase the proposed height by 15 feet to a total of 105 feet so that the 220-80 Line will still clear the Schuylkill River from the new position. PECO also revised the proposed Project to change the location of the new transmission structure 11/3A approximately 60 feet to the east of the originally proposed location and to increase the proposed height by 25 feet to a total of 175 feet to also clear the Schuylkill River. PECO further revised the proposed

Morgan, Lewis & Bockius LLP

2222 Market Street
Philadelphia, PA 19103
United States

T +1.215.963.5000
F +1.215.963.5001

Project to locate proposed new transmission structure 1/2 of the 220-101 Line approximately 70 feet to the northeast from the originally proposed location and increase the proposed height by 10 feet to 175 feet to provide greater circuit to circuit spacing with the relocated 220-80 Line and maintain clearance over the Schuylkill River. As a result of these minor modifications, the 220-80 Line will not cross over the propane storage tanks. PECO also notes that these revisions provide a secondary benefit by moving proposed new transmission structure 1/2 outside of a wetland.


PECO does not propose any other modifications to the design of the Project. The number and type of proposed transmission structures remains the same as originally described in the LON. In addition, the height of proposed transmission structure 11/3 of the 220-80 Line and proposed transmission structures 1/1 and 1/3 of the 220-101 Line will not increase as a result of these revisions.

PECO is providing the Commission with new plan and profile diagrams as **Attachment 1-Revised** identifying the locations of all proposed transmission structures.

As indicated on the enclosed Certificate of Service, copies of this letter have been served upon all parties of record.

If you have any questions, please call me directly at 215.963.5384.

Very truly yours,



Kenneth M. Kulak

KMK/ap
Enclosure

c: Per Certificate of Service (w/encls.)

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Letter of Notification of PECO Energy :
Company Filed Pursuant to 52 Pa. Code §§ :
57.71 et seq. for Approval of the Siting and :
Construction of the 220-80 Line and 220-101 : Docket No. A-2025-3057320
Line Located in Norristown, West Norriton :
Township, and Upper Merion Township, :
Montgomery County, Pennsylvania :**

CERTIFICATE OF SERVICE

I hereby certify and affirm that I have this day served a copy of the **Letter of Notification Addendum on behalf of PECO Energy Company** on the following persons in the manner specified in accordance with the requirements of 52 Pa. Code § 1.54:

VIA ELECTRONIC MAIL

Darryl A. Lawrence
Office of Consumer Advocate
555 Walnut Street
Forum Place – 5th Floor
Harrisburg, PA 17101-1921
dlawrence@paoca.org

Allison C. Kaster
Bureau of Investigation and Enforcement
PA Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
akaster@pa.gov

Jordan Van Order
Bureau of Technical Utility Services
PA Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
jvanorder@pa.gov

NazAarah Sabree
Commonwealth of Pennsylvania
Office of Small Business Advocate
Forum Place
555 Walnut Street, 1st Floor
Harrisburg, PA 17101
ra-sba@pa.gov

Dated: October 17, 2025



Kenneth M. Kulak
Morgan, Lewis & Bockius LLP
2222 Market Street
Philadelphia, PA 19103-2921
(215) 963-5384
ken.kulak@morganlewis.com