



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE
REFER TO OUR FILE

November 13, 2025

Docket No. M-2025-3057490

Utility Code 110650

BYRON FARNSWORTH JR.
PRESIDENT & CEO
WELLSBORO ELECTRIC COMPANY
P.O. BOX 138
33 AUSTIN STREET
WELLSBORO, PA 16901
barneyf@ctenterprises.org

RE: Request for Exclusion of a Major Outage for Reliability Reporting Purposes.

Dear Mr. Farnsworth:

On November 6, 2025, Wellsboro Electric Company (WECO) filed a request for exclusion of major outage for reliability reporting purposes (Exclusion Request) in accordance with the requirements of the Commission's Order entered May 11, 2004, at M-00991220. To assist the Commission in conducting its review of WECO's Exclusion Request, please respond with the information requested in Attachment 1. To review the additional information requested, the Commission hereby extends the consideration period of WECO's Exclusion Request to December 28, 2025.

Please forward the information to the Secretary of the Commission at the address listed below **within ten (10) business days** from the date of this letter. All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilings with the Secretary of the Commission by opening an efilings account through the Commission website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilings system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response. The overnight address for hard-copy or confidential responses is:

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

Please note your answers must be verified per 52 Pa. Code § 1.36. Accordingly, you must provide the following statement with your responses:

I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Signature _____
Title _____
Date _____

Please contact the below staff person if any problems should arise that prevent a full response within ten business days or if any clarification of these data requests is needed. Please mark the materials “CONFIDENTIAL” in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

In addition, to expedite completion of the review, please send a copy of the response to Clinton McKinley, in the Reliability Section of the Bureau of Technical Utility Services via e-mail at cmckinley@pa.gov. Please also direct any questions to Clinton McKinley at telephone number (717) 783-6161. Thank you in advance for your cooperation.

Sincerely,



Matthew L. Homsher
Secretary

Enclosure: Attachment 1

cc: Dan Searfoorce, TUS
John Van Zant, TUS
Christian Yother, AUD
Kathleen Aunkst, SEC
Brent Killian, BIE

Attachment 1
TUS Data Request Set 1
Wellsboro Electric Company Request for Exclusion of Major Outage
Docket No. M-2025-3058363

Note: Please restate the data request prior to providing a response. In addition, provide the name and title of the person(s) providing the response and/or information for each data request.

- M-1. In the Exclusion Request, WECO indicated that service to 1,100 customers was interrupted at 16:35 on 11/5/25 and that service was restored to the last affected customer at 05:00 on 11/6/25. Please provide responses to the following:
- a. Confirm that service was restored simultaneously to all 1,100 affected customers;
or
 - b. If service was not restored simultaneously to all 1,100 affected customers, provide a restoration curve for this specific event.
- M-2. In the Exclusion Request, WECO experienced an outage due to a high wind event that caused several trees to fall, down conductor, and break two poles. WECO identified four circuits on the WECO system as trouble locations. Please provide responses to the following:
- a. Identify if any of the affected circuits are included on WECO's worst performing circuits list; and
 - b. State if the trees that caused the damage were identified as outside-right-of-way trees or if these trees originated within the right-of-way; and
 - c. Identify the date that each of the four affected circuits was last inspected.