



COMMONWEALTH OF PENNSYLVANIA  
PENNSYLVANIA PUBLIC UTILITY COMMISSION  
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE  
REFER TO OUR FILE

November 13, 2025

Docket No.: M-2025-3058252  
Utility Code: 1126015

ANGELINA UMSTEAD, ESQUIRE  
FIRSTENERGY PENNSYLVANIA ELECTRIC COMPANY  
341 WHITE POND DRIVE  
AKRON, OH 44320  
[aumstead@firstenergycorp.com](mailto:aumstead@firstenergycorp.com)

RE: FirstEnergy Pennsylvania Electric Company Request for Exclusion of Major Outage for Reliability Reporting Purposes at Docket No. M-2025-3058252

Dear Ms. Umstead:

On October 31, 2025, on behalf of its Penelec Rate District, FirstEnergy Pennsylvania Electric Company (FE PA) filed a request for exclusion of major outage (Exclusion Request) for reliability reporting purposes in accordance with the requirements of the Pennsylvania Public Utility Commission's (Commission's) Order entered May 11, 2004, at M-00991220. To assist the Commission in conducting the review of FE PA's Exclusion Request, please respond with the information requested in Attachment 1. To review the information requested, the Commission is hereby extending its review period until December 31, 2025.

Please forward the information to the Secretary of the Commission at the address listed below **within ten (10) business days** from the date of this letter. All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilings with the Secretary of the Commission by opening an efilings account through the Commission website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilings system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response. The overnight address for hard-copy or confidential responses is:

Matthew L. Homsher, Secretary  
Pennsylvania Public Utility Commission  
400 North Street  
Harrisburg, PA 17120

Please note your answers must be verified per 52 Pa. Code § 1.36. Accordingly, you must provide the following statement with your responses:


*I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).*

Signature \_\_\_\_\_  
Title \_\_\_\_\_  
Date \_\_\_\_\_

Please contact the below staff person if any problems should arise that prevent a full response within ten business days or if any clarification of these data requests is needed. Please mark the materials “CONFIDENTIAL” in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

In addition, to expedite completion of the review, please send a copy of the response to Clinton McKinley, in the Reliability Section of the Bureau of Technical Utility Services via e-mail at [cmckinley@pa.gov](mailto:cmckinley@pa.gov). Please also direct any questions to Clinton McKinley at telephone number (717) 783-6161. Thank you in advance for your cooperation.

Sincerely,



Matthew L. Homsher  
Secretary

cc: Dan Searfoorce, TUS  
John Van Zant, TUS  
Allison Kaster, BIE  
Brent Killian, BIE  
Bret Young, FE PA, [bretyoung@firstenergycorp.com](mailto:bretyoung@firstenergycorp.com)

Attachment 1  
TUS Data Request Set 1  
FirstEnergy Pennsylvania Electric Company Request for Exclusion of Major Outage for  
Reliability Reporting Purposes at Docket No. M-2025-3058252

Note: Please restate the data request prior to providing a response. In addition, provide the name and title of the person(s) providing the response and/or information for each data request.

- M-1. In the Exclusion Request, FE PA noted that an intense line of storms crossed Pennsylvania on July 3, 2025, with a second round of scattered storms on July 7, 2025. Please provide a restoration curve for each storm event.
- M-2. In the Exclusion Request, FE PA indicated that 7,755 or 1.3% of Penelec's total customers were affected. Please explain how this event qualifies as a major event as defined in Section 57.192 of Commission regulations at 52 Pa. Code § 57.192.
- M-3. Please confirm that a service outage report was filed with the Commission within 10 business days after the total restoration of service pursuant to Section 67.1(b) of Commission regulations at 52 Pa. Code § 67.1(b) and provide a copy of said report.
- M-4. For each outage that exceeded six or more hours in duration, please provide the following:
  - a. Duration of the outage;
  - b. Initial date and time of the outage; and
  - c. Restoration time and date.