



Attachment 1
TUS Data Request Set 1
Wellsboro Electric Company Request for Exclusion of Major Outage
Docket No. M-2025-3058363

Note: Please restate the data request prior to providing a response. In addition, provide the name and title of the person(s) providing the response and/or information for each data request.

- M-1. In the Exclusion Request, WECO indicated that service to 1,100 customers was interrupted at 16:35 on 11/5/25 and that service was restored to the last affected customer at 05:00 on 11/6/25. Please provide responses to the following:
- a. Confirm that service was restored simultaneously to all 1,100 affected customers;
or
 - b. If service was not restored simultaneously to all 1,100 affected customers, provide a restoration curve for this specific event.
 - 11/05 19:00 - 13 customers
 - 20:00 - 1 customer
 - 21:00 - 740 customers
 - 22:00 - 59 customers
 - 23:00 - 228 customers
 - 11/6 01:00 - 30 customers
 - 02:00 - 15 customers
 - 03:00 - 13 customers
 - 05:00 - 1 customer
- M-2. In the Exclusion Request, WECO experienced an outage due to a high wind event that caused several trees to fall, down conductor, and break two poles. WECO identified four circuits on the WECO system as trouble locations. Please provide responses to the following:
- a. Identify if any of the affected circuits are included on WECO's worst performing circuits list; and
 - Based on 2024 data we evaluated each circuits performance the list below shows where the 4 circuits were ranked 1-8, 1 being the worst circuit and 8 being the best.
 - Stony fork - 1
 - Dresser - 3
 - Charleston OOT - 4
 - Charleston In - 7
 - b. State if the trees that caused the damage were identified as outside-right-of-way trees or if these trees originated within the right-of-way; and
 - 1 outage was due to an On-ROW tree and 19 other outages were caused by Off ROW trees.

- c. Identify the date that each of the four affected circuits was last inspected
- The 4 circuits were visually inspected per our PUC approved I&M plan
 - Stony fork - 2024
 - Charleston In - 2025
 - Charleston OOT - 2024
 - Dresser circuit - 2024

I, Tyler Mead, hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to penalties of 18 Pa. C.S. 4904 (relating to unsworn falsification to authorities).

Signature 
Title Director of E + O
Date 11/17/25