



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE
REFER TO OUR FILE

November 17, 2025

Docket No. M-2009-2094773

VINCENT DEGIUSTO
SENIOR DIRECTOR – ELECTRIC DIVISION
UGI UTILITIES, INC.
1 UGI DRIVE
DENVER, PA 17517
vdeguisto@ugi.com

Re: UGI Utilities, Inc. – Electric Division’s Biennial Inspection, Maintenance, Repair and Replacement January 1, 2027, through December 31, 2028, Inspection and Maintenance Plan at Docket No. M-2009-2094773

Dear Mr. Deguisto:

On October 1, 2025, UGI Utilities, Inc. – Electric Division (UGI-ED) filed its Biennial Inspection, Maintenance, Repair and Replacement Plan (I&M Plan) for the period of January 1, 2027, through December 31, 2028. To assist the Commission in conducting the review of UGI-ED’s 2027 – 2028 I&M Plan, please respond with the information requested in Attachment 1.

Please forward the information to the Secretary of the Commission **within ten (10) business days** from the date of this letter. All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilng with the Secretary of the Commission by opening an efilng account through the Commission’s website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilng system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary’s Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary’s Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response. The overnight address for hard-copy or confidential responses is:

Matthew Homsher, Secretary
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

Your answers should be verified per 52 Pa Code § 1.36. Accordingly, you must provide the following statement with your responses:

I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Signature _____

Title _____

Date _____

Please contact the below staff person if any problems should arise that prevent a full response within ten business days or if any clarification of these data requests is needed. Please mark the materials “CONFIDENTIAL” in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

In addition, to expedite completion of the review, please send a copy of your response to Clinton McKinley in the Reliability and Emergency Preparedness Section of the Bureau of Technical Utility Services via e-mail at cmckinley@pa.gov. Thank you in advance for your cooperation.

Sincerely,



Matthew Homsher
Secretary

Enclosure: Attachment 1

cc: Kriss Brown, LAW
Dan Searfoorce, TUS
John Van Zant, TUS
Brent Killian, BIE

Attachment 1
TUS Data Request Set I

UGI Utilities, Inc. – Electric Division’s Biennial Inspection, Maintenance, Repair and Replacement 2027 – 2028
I&M Plan January 1, 2027, through December 31, 2028, at Docket No. M 2009 2094773

- M-1. UGI-ED’s I&M Plan at Page 11 indicated that, “Further details can be found in UGI Electric’s T&D Engineering Instruction Manual, Section 02-02.” Please provide a copy of Section 02-02 of UGI-ED’s T&D Engineering Instruction Manual (Instruction Manual).
- M-2. UGI-ED’s I&M Plan at Page 15 indicated that, “Further details can be found in UGI Electric’s T&D Utilities Engineering Instruction Manual, Section 02-08.” Please provide a copy of Section 02-08 of UGI-ED’s Instruction Manual.
- M-3. UGI-ED’s I&M Plan at Page 15 indicated that inspection information is documented. Please explain how this information is documented and provide an example of the documentation completed for a distribution transformer inspection.
- M-4. UGI-ED’s I&M Plan at Page 18 indicated that, “Further details can be found in UGI Electric’s T&D Engineering Instruction Manual, Section 02-13.” Please provide a copy of Section 02-13 of UGI-ED’s Instruction Manual.
- M-5. The Chart provided on Page 18 of UGI-ED’s I&M Plan identified 134 three phase reclosers and 201 single phase reclosers (134+201=335). However, the number of reclosers to be inspected per year on the same charts indicates 346 reclosers. Please clarify this discrepancy.
- M-6. UGI-ED’s I&M Plan at Page 19 indicated that a description of UGI-ED’s Substation Inspection Program can be found in UGI-ED’s Instruction Manual, Section 4.2. Please provide a copy of Section 4.2 of UGI-ED’s Instruction Manual.