



COMMONWEALTH OF PENNSYLVANIA
PENNSYLVANIA PUBLIC UTILITY COMMISSION
400 NORTH STREET, HARRISBURG, PA 17120

IN REPLY PLEASE
REFER TO OUR FILE

November 18, 2025

Docket No.: M-2009-2094773

ANGELINA UMSTEAD, ESQUIRE
FIRSTENERGY PENNSYLVANIA ELECTRIC COMPANY
341 WHITE POND DRIVE
AKRON, OHIO 44320
aumstead@firstenergycorp.com

Re: Biennial Inspection, Maintenance, Repair and Replacement Plan for FirstEnergy Pennsylvania Electric Company for the period of January 1, 2027, through December 31, 2028, at Docket No. M-2009-2094773

Dear Attorney Umstead:

On October 1, 2025, First Energy Pennsylvania Electric Company (FE PA) filed its Biennial Inspection, Maintenance, Repair and Replacement Plan (I&M Plan) for the period of January 1, 2027, through December 31, 2028. To assist the Commission in conducting the review of FE PA's 2027 – 2028 I&M Plan, please respond with the information requested in Attachment 1.

Please forward the information to the Secretary of the Commission **within ten (10) business days** from the date of this letter. All documents requiring notary stamps must have original signatures. The Commission strongly encourages submission through efilings with the Secretary of the Commission by opening an efilings account through the Commission's website and accepting eservice at <https://efiling.puc.pa.gov>. The Commission is accepting all public documents through our efilings system at this time.

If your filing contains confidential material, you are required to either file by overnight delivery or submit to the Secretary's Share Point File system to ensure the timely filing of your submission. Filers should contact the Secretary's Bureau in advance to gain access to the Share Point File system. Make sure to reference the Docket Number listed above when filing your response. The overnight address for hard-copy or confidential responses is:

Matthew Homsher, Secretary
Pennsylvania Public Utility Commission
400 North Street
Harrisburg, PA 17120

Your answers should be verified per 52 Pa Code § 1.36. Accordingly, you must provide the following statement with your responses:

I, [print name of appropriate company representative], hereby state that the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

Signature _____

Title _____

Date _____

Please contact the below staff person if any problems should arise that prevent a full response within ten business days or if any clarification of these data requests is needed. Please mark the materials “CONFIDENTIAL” in bold or highlighted manner if any of the requested information is deemed to be of a confidential nature.

In addition, to expedite completion of the review, please send a copy of your response to Clinton McKinley in the Reliability and Emergency Preparedness Section of the Bureau of Technical Utility Services via e-mail at cmckinley@pa.gov. Thank you in advance for your cooperation.

Sincerely,



Matthew Homsher
Secretary

Enclosure: Attachment 1

cc: Kriss Brown, LAW
Dan Searfoorce, TUS
John Van Zant, TUS
Brent Killian, BIE

Attachment 1
TUS Data Request 1

Biennial Inspection, Maintenance, Repair and Replacement Plan for FirstEnergy Pennsylvania Electric Company for the period of January 1, 2027, through December 31, 2028, at Docket No. M-2009-2094773

Note: Please restate the data request prior to providing a response. In addition, provide the name and title of the person(s) providing the response and/or information for each data request.

- M-1. FE PA's I&M Plan, at Page 8, indicated that, "Further detailed information regarding the Company's vegetation management program may be found in the Vegetation Management Distribution Specifications." Please provide a copy of the specifications referenced.
- M-2. FE PA's I&M Plan, at Page 12, indicated that, "Further detailed information regarding the Company's inspection of wood poles may be found in the Distribution Inspection & Maintenance Practice – Wood Pole Groundline." Please provide a copy of the document referenced.
- M-3. FE PA's I&M Plan, at Page 18, indicated that, "Further detailed information regarding the Company's inspection of distribution transformers may be found in the Distribution Inspection & Maintenance Practice – Underground Equipment. Please provide a copy of the document referenced.
- M-4. FE PA's I&M Plan, at Page 20, indicated that, "Further detailed information regarding the Company's inspection of reclosers may be found in the Distribution Inspection & Maintenance Practice – Line Reclosers." Please provide a copy of the document referenced.
- M-5. FE PA's I&M Plan, at Pages 20 - 21, indicated that, "The Company visually inspects hydraulic distribution line reclosers annually." And, "New, electronic reclosers such as Vipers that the Company is installing can be remotely monitored for alarms, thereby eliminating the main driver for an annual visual inspection." Please identify the inspection cycle for FE PA's electronic distribution line reclosers or clarify that FE PA is requesting a waiver of the inspection cycle timeframes identified in Section 57.198(n)(7) of Commission Regulations at 52 Pa. Code § 57.198(n)(7).
- M-6. FE PA's I&M Plan, at Page 23, indicated that, "Further detailed information regarding the Company's inspection of substations may be found in Section 20P – Substation Patrol Inspection of the Substation Maintenance Practice and Methods." Please provide a copy of the document referenced.