

November 25, 2025

VIA ELECTRONIC FILING

Matthew Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

***Re: Completed Restoration of Momentary and Sustained Interruptions –
FirstEnergy Pennsylvania Electric Company; Docket No. M-2025-3052814***


Dear Secretary Homsher:

Pursuant to 52 Pa. Code § 67.1, FirstEnergy Pennsylvania Electric Company on behalf of West Penn Rate District (“West Penn”) submits written notification of completed restoration efforts following storm conditions that began on November 5, 2025 that caused multiple service interruptions in the West Penn service territory.

Attached please find the details relative to the impact of this recent outage event and the restoration activities that took place. It should be noted that the review and approval process of this outage information is still in progress at the time of filing this report and as such, all outage information contained in this report should be considered preliminary.

If you have any questions, please contact me at (610) 921-6202.

Sincerely,



Angelina Umstead

Enclosures

c: Dan Searfoorce - PaPUC Bureau of Technical Utility Services (via electronic mail)
Derek Ruhl - PaPUC Bureau of Technical Utility Services (via electronic mail)
John Van Zant - PaPUC Bureau of Technical Utility Services (via electronic mail)

ELECTRIC UTILITY REPORT OF OUTAGE TO
PENNSYLVANIA PUBLIC UTILITY COMMISSION
SECRETARY'S BUREAU
P O BOX 3265
HARRISBURG, PA 17105-3265

1. Reporting Utility: FirstEnergy Pennsylvania Electric Company ("FE PA")
on behalf of its West Penn Rate District ("West Penn")
Address: 800 Cabin Hill Drive
Greensburg, PA 15601

2. Name and title of person making report:
Karen M. Kinslow Vice President Pennsylvania Operations
(Name) *(Title)*

3. Telephone number: (610) 921-6311
(Telephone Number)

4. Date and time report was made to Commission:
November 5, 2025 2211
(Date) *(Time)*

5. Interruption or Outage:
(a) Number of customers affected: 12,268 (represents 1.7% of West Penn's total customers).
(b) Approximate number of outage cases and trouble cases for each county affected during event: See response to 5(c).

- (c) Approximate number of outages for each county affected during the event:

County	Outages	Outage Cases	Trouble Cases
Allegheny	129	8	16
Armstrong	1,004	22	13
Bedford	203	15	6
Butler	796	6	18
Centre	2,747	24	18
Clarion	44	3	2
Elk	1,403	13	10
Fayette	35	3	17
Franklin	429	22	19
Fulton	74	5	2
Greene	28	3	5
Indiana	445	2	0
Lycoming	6	1	1
McKean	848	1	1
Potter	463	6	3
Washington	1,242	32	21
Westmoreland	2,372	49	64
Total	12,268	215	216

- (d) Approximate number of outage cases exceeding 6 or more hours in duration: 103

- (e) A listing of each outage case exceeding 6 or more hours in duration: See Attachment A.

- (f) Reason for the interruption or outages: Beginning the morning of Wednesday, November 5, 2025, a weather system began moving through Pennsylvania including FE PA's service territory, producing wind gusts of approximately 61 miles per hour. See Attachment B for the maximum wind gusts for November 5, 2025, and November 6, 2025, and 24-hour total precipitation for November 5, 2025.

Damage as a result of high winds included downed wires, damaged or broken poles, trees, branches, transformers, and crossarms. The State College and St. Mary's areas were the hardest hit areas. Approximately 56.7% of the total outages that occurred were tree related and an additional 8.8% were wind related.

Preliminary data indicates the reliability impact of the storm was 5.1 minutes of SAIDI, 0.02 of SAIFI, and an overall storm CAIDI of 301.3 minutes.

- (g) Projected time of restoration: Due to the length of this event, a global estimated

time of restoration was not set. Individual estimated times of restoration were assigned to orders.

See Attachment C for the restoration curve and Attachment D for the order restoration graphs.

- (h) The number of utility workers, contract workers, and workers received as mutual aid assigned specifically to the repair work by general function:

Company	# of Workers	General Function
Asplundh Tree Expert, LLC	88	Forestry
Davey	9	Forestry
Penn Line Services, Inc.	21	Forestry
Subtotal	118	Forestry
FE PA	207	Line
I.B Abel	8	Line
JW Didado	7	Line
Thompson Electric	8	Line
Subtotal	230	Line
FE PA	52	Support
FirstEnergy Service Co.	43	Support
Subtotal	95	Support
Grand Total	443	

- (i) The date and time of the first information of a service interruption: November 5, 2025, at 1111.
- (j) The date and time that repair crews were assembled: November 5, 2025, at 0600.
- (k) The actual time that service was restored to the last affected customer: November 6, 2025, at 2100.

- (l) A general description of the physical damage sustained by the utility facilities as a result of the interruption/outage:

Equipment	Number
Primary Spans	121
Secondary Spans	27
Crossarms Replaced	48
Cutouts Replaced	24
Poles Replaced	8
Transformers Replaced	11
Wire & Cable Replaced (feet)	14,825

- (m) If the interruption/outage event was weather-related, the utility’s weather reports, outlooks, or scenarios for the day before and the day of the interruption/outage event:

See Attachment E for the weather forecast reports.

- (n) If the interruption/outage event caused approximate outages that exceed 10% or more of the number of customers in the utility’s entire service territory, rank the event in terms of the number and duration of outages and provide 2 comparable events, including the number and duration of outages for those comparable events.

The outages that were a result of this event did not exceed 10% or more of customers in the utility’s entire service territory.

Remarks: The storm statistics contained in this report are preliminary. The review and approval of the storm statistics were still in progress as of the time this report was filed.

Attachment A: A listing of each outage case exceeding six or more hours in duration, including the following information¹:

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
1163266	Bedford	1	1,561	11/05/2025 1330	11/06/2025 1531
1163148	Elk	1	1,361	11/05/2025 1919	11/06/2025 1800
1160988	Fulton	14	1,354	11/05/2025 2014	11/06/2025 1848
1161706	Fulton	1	1,328	11/05/2025 2157	11/06/2025 2005
1162236	Bedford	1	1,305	11/05/2025 2038	11/06/2025 1823
1163506	Elk	1	1,297	11/05/2025 1923	11/06/2025 1700
1160970	Westmoreland	2	1,271	11/05/2025 2009	11/06/2025 1720
1163254	Centre	8	1,206	11/05/2025 1912	11/06/2025 1518
1161242	Franklin	57	1,183	11/05/2025 2037	11/06/2025 1620
1160709	Centre	33	1,182	11/05/2025 1912	11/06/2025 1454
1160941	Bedford	2	1,169	11/05/2025 2000	11/06/2025 1529
1160958	Bedford	11	1,165	11/05/2025 2006	11/06/2025 1531
1160920	Elk	78	1,146	11/05/2025 1957	11/06/2025 1503
1160568	Potter	23	1,138	11/05/2025 1850	11/06/2025 1348
1161158	Fulton	13	1,135	11/05/2025 2028	11/06/2025 1523
1162414	Westmoreland	4	1,110	11/05/2025 1959	11/06/2025 1429
1160944	Allegheny	3	1,093	11/05/2025 2001	11/06/2025 1414
1161122	Fulton	3	1,092	11/05/2025 2025	11/06/2025 1437
1162961	Elk	5	1,060	11/05/2025 1946	11/06/2025 1326
1160733	Elk	6	1,046	11/05/2025 1914	11/06/2025 1240
1160851	Fayette	28	1,046	11/05/2025 1937	11/06/2025 1303
1161651	Bedford	8	1,024	11/05/2025 2145	11/06/2025 1449
1160993	Westmoreland	1	1,014	11/05/2025 1906	11/06/2025 1200
1161739	Franklin	2	1,004	11/05/2025 2050	11/06/2025 1334
1162331	Franklin	4	991	11/05/2025 2242	11/06/2025 1513
1162619	Franklin	2	989	11/05/2025 2201	11/06/2025 1430
1161045	Bedford	17	984	11/05/2025 2019	11/06/2025 1243
1162415	Centre	7	975	11/05/2025 2045	11/06/2025 1300
1163216	Centre	505	965	11/05/2025 2020	11/06/2025 1225
1163217	Centre	79	960	11/05/2025 2020	11/06/2025 1220
1162108	Centre	15	955	11/05/2025 2020	11/06/2025 1215

¹ When applicable, the individual restoration steps for an order are provided for those customers that were out of service for 6 hours or more.

FE PA Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
1160555	Washington	4	953	11/05/2025 1842	11/06/2025 1035
1160955	Greene	26	947	11/05/2025 2005	11/06/2025 1152
1161377	Franklin	2	942	11/05/2025 2053	11/06/2025 1235
1162701	Elk	41	938	11/05/2025 2203	11/06/2025 1341
1161105	Centre	50	926	11/05/2025 2024	11/06/2025 1150
1160792	Centre	28	920	11/05/2025 1925	11/06/2025 1045
1161069	Centre	22	918	11/05/2025 2022	11/06/2025 1140
1161575	Bedford	5	909	11/05/2025 2127	11/06/2025 1236
1161270	Washington	72	896	11/05/2025 2042	11/06/2025 1138
1160265	Armstrong	4	895	11/05/2025 1238	11/06/2025 0333
1160664	Elk	16	894	11/05/2025 1906	11/06/2025 1000
1161271	Franklin	20	894	11/05/2025 2026	11/06/2025 1120
1163046	Westmoreland	4	885	11/05/2025 2049	11/06/2025 1134
1160569	Washington	1	873	11/05/2025 1852	11/06/2025 0925
1161206	Franklin	8	858	11/05/2025 2032	11/06/2025 1050
1162097	Westmoreland	4	858	11/05/2025 2012	11/06/2025 1030
1160868	Elk	149	855	11/05/2025 1946	11/06/2025 1001
1160534	Westmoreland	3	851	11/05/2025 1825	11/06/2025 0836
1160963	Allegheny	9	850	11/05/2025 2007	11/06/2025 1017
1162481	Bedford	40	841	11/05/2025 2036	11/06/2025 1037
1160751	Westmoreland	25	837	11/05/2025 1917	11/06/2025 0914
1161708	Westmoreland	1	834	11/05/2025 2010	11/06/2025 1004
1161259	Fayette	5	832	11/05/2025 2038	11/06/2025 1030
1162235	Westmoreland	8	827	11/05/2025 1941	11/06/2025 0928
1161199	Franklin	20	823	11/05/2025 2032	11/06/2025 1015
1162246	Franklin	2	818	11/06/2025 0035	11/06/2025 1413
1160913	Westmoreland	10	813	11/05/2025 1954	11/06/2025 0927
1160856	Westmoreland	12	801	11/05/2025 1939	11/06/2025 0900
1160945	Westmoreland	7	799	11/05/2025 2001	11/06/2025 0920
1160756	Centre	2	797	11/05/2025 1918	11/06/2025 0835
1161140	Franklin	29	796	11/05/2025 2026	11/06/2025 0942
1162393	Washington	1	786	11/05/2025 2115	11/06/2025 1021
1161315	Washington	6	757	11/05/2025 2046	11/06/2025 0923
1162214	Bedford	26	755	11/06/2025 0008	11/06/2025 1243
1161243	Westmoreland	6	742	11/05/2025 2037	11/06/2025 0859
1161083	Franklin	27	742	11/05/2025 2023	11/06/2025 0845


FE PA Storm Report

Order #	Approximate Location (County)	Total Number of Customers Affected	Duration of the Outage (minutes)	Initial Date and Time of the Outage	Restoration Date and Time
1161655	Westmoreland	46	729	11/05/2025 2149	11/06/2025 0958
1162521	Bedford	58	712	11/05/2025 2021	11/06/2025 0813
1160800	Westmoreland	1	697	11/05/2025 1927	11/06/2025 0704
1162869	Westmoreland	4	695	11/05/2025 2155	11/06/2025 0930
1162488	Potter	114	687	11/05/2025 1855	11/06/2025 0622
1162225	Armstrong	28	687	11/06/2025 0017	11/06/2025 1144
1161406	Centre	12	683	11/05/2025 2057	11/06/2025 0820
1161217	Washington	4	641	11/05/2025 2033	11/06/2025 0714
1161795	Armstrong	4	638	11/05/2025 1932	11/06/2025 0610
1160530	Clarion	2	634	11/05/2025 1819	11/06/2025 0453
1160631	Potter	21	632	11/05/2025 1855	11/06/2025 0527
1162224	Allegheny	2	620	11/05/2025 1854	11/06/2025 0514
1161212	Westmoreland	1	617	11/05/2025 2033	11/06/2025 0650
1162230	Butler	48	607	11/06/2025 0150	11/06/2025 1157
1161717	Elk	90	602	11/05/2025 2203	11/06/2025 0805
1160565	Potter	115	575	11/05/2025 1849	11/06/2025 0424
1161234	Bedford	16	529	11/05/2025 2036	11/06/2025 0525
1160811	Armstrong	14	503	11/05/2025 1930	11/06/2025 0353
1160940	Westmoreland	3	496	11/05/2025 1959	11/06/2025 0415
1161217	Washington	10	489	11/05/2025 2305	11/06/2025 0714
1161679	Washington	18	488	11/05/2025 2150	11/06/2025 0558
1162337	Potter	76	472	11/05/2025 1850	11/06/2025 0242
1163103	Franklin	3	463	11/06/2025 0502	11/06/2025 1245
1160849	Allegheny	15	454	11/05/2025 1937	11/06/2025 0311
1161309	Centre	3	445	11/05/2025 2045	11/06/2025 0410
1160826	Armstrong	63	431	11/05/2025 1932	11/06/2025 0243
1160685	Westmoreland	22	414	11/05/2025 1909	11/06/2025 0203
1162778	Franklin	2	405	11/06/2025 0845	11/06/2025 1530
1162029	Centre	8	392	11/05/2025 2313	11/06/2025 0545
1160475	Armstrong	4	390	11/05/2025 1735	11/06/2025 0005
1160986	Armstrong	9	390	11/05/2025 1735	11/06/2025 0005
1160684	Westmoreland	9	387	11/05/2025 1909	11/06/2025 0136
1161156	Centre	37	377	11/05/2025 2028	11/06/2025 0245
1161518	Washington	3	373	11/05/2025 2115	11/06/2025 0328
1160572	McKean	848	372	11/05/2025 1853	11/06/2025 0105
1160508	Washington	3	369	11/05/2025 1751	11/06/2025 0000


Attachment B: Wind and Precipitation Reports

Wind and Precipitation Reports: Graphics 1 and 2 illustrate the maximum wind gusts in the FE PA service territory on November 5, 2025, and November 6, 2025. Graphic 3 illustrates the 24-Hour Total Precipitation in the FE PA service territory on November 5, 2025. The graphics depict data from the National Oceanic and Atmospheric Administration (“NOAA”).


Graphic 1 – Maximum Wind Gusts – Wednesday, November 5, 2025




Graphic 2 – Maximum Wind Gusts – Thursday, November 6, 2025




Graphic 3: Precipitation – Wednesday, November 5, 2025



Attachment C: Restoration Curve



Attachment D: Order Restoration Graphs




Attachment E: Meteorologist Reports

Monday, November 3, 2025 @ 0851

New Issuance:

Series of fronts bringing gust threats approximately every other day starting today. Prolonged significant rains not expected with any of the fronts except we will keep our eyes on the late Wednesday frontal passage for any potential to be accompanied by a brief passing band of heavy rain with isolated lightning strikes.




Tuesday, November 4, 2025 @ 0816

Changes:

Today: Added two brief very localized areas of nuisance gusts. Wed-Fri: Added mention of potential for frontal passage Wed to be accompanied by brief heavy showers and isolated lightning strikes. otherwise, some fine-tuning of threat areas and timing.

We are also monitoring the potential for nuisance-level wet snow accumulations Sun into Mon for both the lake effect areas of OH and the typical terrain areas of WV.



Wednesday, November 5, 2025 @ 0819

Changes:

Today: Decreased peak gusts by 5 mph, reduced 50+ mph areas, reduced duration of post-frontal gusts by 1 hour, and fine-tuned timing. Friday: Added details of nuisance gust threat. Late Weekend: Introduced depiction of threats being monitored for Sunday night into Monday.

