

**Application of Pennsylvania-American Water Company for Acquisition of
the Wastewater Assets of East Coventry Township
66 Pa. C.S. §1329
Application Filing Checklist – Water/Wastewater**

Docket No. A-2025-3053487

15. Plant In Service

- c. State the DEP-permitted productive or treatment capacity of sources or treatment facility and the pipe sizes and material used for construction for all transmission and distribution or collection facilities.

RESPONSE: c. See Direct Testimony of Michael J. Guntrum, P.E., PAWC Statement No. 2, at pp. 2-3 enclosed at **Appendix A-14-a**.

AMENDED RESPONSE:

- c. The DEP permitted capacity for each pump station is as follows:

Pump Station	Permitted Peak Capacity with 1 pump out of service (gpd)
PS-1 *	1,728,000
PS-2	72,000
PS-3	410,400
PS-4	144,000
PS-5	44,100

* PS –1 has three (3) pumps and was designed and permitted to have two (2) operating simultaneously with the third pump as stand-by.