



Regulation is a maze. We can show you the way!

Whitney E. Snyder
717.703.0807
wesnyder@hmslegal.com

501 Corporate Circle, Suite 302, Harrisburg, PA 17110 Phone: 717.236.1300 Fax: 717.236.4841 www.hmslegal.com

December 4, 2025

By Electronic Filing

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street – Second Floor North
Harrisburg, PA 17120

RE: **Pike County Light & Power Company's Request for Exclusion of Major Outage for Reliability Reporting Purposes to Pennsylvania Public Utility Commission; Docket No. _____**

Dear Secretary Homsher:

Enclosed for filing is Pike County Light & Power Company's Request for Exclusion of Major Outage for Reliability Reporting Purposes for an outage occurring November 16, 2025.

If you have any questions concerning this filing, please contact me.

Very truly yours,

/s/ Whitney E. Snyder

Whitney E. Snyder (Attorney ID No. 316625)

Counsel for Pike County Light & Power Company

WES/das
Enclosures



Pike County Light & Power Co.
105 Schneider Ln.
Milford Pa. 18337

Nancy Karlovich
General Manager
570-832-2988 Ext. 354
FAX:(570) 832-2989

December 3, 2025

Honorable Matthew L. Homsher
Secretary
Commonwealth of Pennsylvania
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17120

Re: Request for Exclusion of Major Outage for Reliability Reporting Purposes

Dear Secretary Homsher:

By this letter, Pike County Light & Power Company ("PCL&P") sets forth a 'Request for Exclusion of Major Outage For Reliability Reporting Purposes', in accordance with the Pennsylvania Public Utility Commission ("PAPUC") Order entered May 11, 2004, at M-00991220. This request relates to interruptions to PCL&P customers that occurred on November 16, 2025. This incident meets the 10% customer threshold identified in Pa. Code §57.192, and was the result of an equipment failure.

On November 16, 2025, sections of Circuit 116-4-34 were de-energized to facilitate the replacement of a defective pole. As a result, 1,531 customers were interrupted. Since the number of customers affected exceeds the criteria for exclusion, PCL&P respectfully requests that the PAPUC accept this interruption as a Major Event.

Sincerely,

Nancy Karlovich

Attachment (1)

- (c) Reason for interruption or outage, including weather data where applicable:

On Friday, November 15, during a routine drone inspection, a distribution pole was found to be rotted and in imminent danger of failing. The assessed condition of the pole resulted in a "priority reject" classification and a decision was made to initiate an immediate replacement of the pole. The lack of structural integrity rendered the pole unsafe to transfer the primary conductors while energized necessitating an outage for crew safety. The weather conditions, at the time, did not have any impact on the outage.

- (d) The number of utility workers and others assigned specifically to the repair work:

There was a total of eight utility workers specifically assigned to the repair work. Staffing included: the Electric Manager, one Designer, one General Foreman, one Working Foreman, two First Class Journeyman Linemen and two apprentice Linemen.

- | | |
|--|--------------------------|
| (e) The date and time of the first notification of a service interruption: | 11/16/2025 12:08 a.m. |
| (f) The actual time that service was restored to the last affected customer: | 11/16/2025 3:42 a.m. |

CERTIFICATE OF SERVICE

I hereby certify that I have this day served a true copy of the foregoing document upon the parties, listed below, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a party).

BY ELECTRONIC MAIL ONLY

| | |
|--|--|
| <p>Kelly A. Monaghan, Director Bureau of Audits Pennsylvania Public Utility Commission Commonwealth Keystone Building 400 North Street, 3rd Floor East Harrisburg, PA 17120 kmonaghan@pa.gov</p> | <p>Paul Diskin, Director Bureau of Technical Utility Services Pennsylvania Public Utility Commission Commonwealth Keystone Building 400 North Street, 3rd Floor East Harrisburg, PA 17120 pdiskin@pa.gov</p> |
|--|--|

/s/ Whitney E. Snyder
Whitney E. Snyder

Dated this 4th day of December, 2025.