UGI
Energy to do more®

PUC Notification of Proposed Major Expenditure

Submit reports to the PA PUC Secretary's Bureau through eFiling at

efiling.puc.pa.gov

Include case: Docket number **M-2025-3052787**in the notification

Also Email To: Safety Division

Email To The Following Addresses: RA-PC-Pipelinesafety@pa.gov & TCSmith@pa.gov

Regional Engineering Office	2121 City Line Rd., Bethlehem, PA 18017-2127 ⌄
Description of Proposed Work	Replace approximately 2100 ft of 4" ST and 4" PE main with approximately 615 ft of new 6", 740 ft of 4" and 745 ft of 2" HDPE distribution main. The method of installation would mainly be direct burial along Alter St, W 19th St and W 18th St, and insertion along Lafayette Ct.
Location of Proposed Work	800 Blk Alter St, Hazleton, Luzerne County - Alter St, from W 20th St to W 18th St. - W 19th St, from Emerald Ct to Lafayette Ct. - W 18th St, from Emerald Ct to approximately 100 ft West of Lafayette Ct. - Lafayette Ct, from W 19th St to W 17th St.
Type of Facility	Distribution
Estimated Starting Date	Estimated Starting Date: 2/2/2026
Design Pressure (MAOP, psi)	60.00
Estimated Cost	Estimated Cost: $500,000
Reporting Gas Company for Project	UGI South ⌄

Project Contact Person(s)	Steward, Timothy;
Project Contact Person(s) Address & Phone	Project Contact Person(s) Address & Phone: § Tim - 2121 City Line Rd., Bethlehem, PA 18017; 610-80...
Estimated Completion Date	Estimated Completion Date: 3/2/2026
Actual Completion Date	Actual Completion Date:

PA PUC Notification Documentation

Notified By (Proposed)	Steward, Timothy;
Notifier's Title (Proposed)	Notifier's Title (Proposition): Senior Manager Area Engineering
Notification Date (Proposed)	Notification Date (Proposition): 12/15/2025
Notified By (Actual Completion)	
Notifier's Title (Actual Completion)	Notifier's Title (Actual Completion):
Notification Date (Actual Completion)	Notification Date (Actual Completion):