



January 9, 2026

Office of Consumer Advocate
555 Walnut Street
Forum Place, 5th Floor
Harrisburg, PA 17101-1923

Bureau of Investigation & Enforcement
Commonwealth Keystone Building
PO Box 3265
Harrisburg, PA 17105-3265

Office of Small Business Advocate
Forum Place
555 Walnut Street, 1st Floor
Harrisburg, PA 17101-1923

RE: Annual Valve Exercising Report; Columbia Water Company
Docket No. R-2017-2598203

Dear Sir or Madam:

In compliance with the Order entered on March 1, 2018 at Docket No. R-2017-2598203, Columbia Water Company submits the following annual valve exercising report for the period ending 12/31/25.

Number of system isolation valves:	3,562
Number of valves exercised:	1,058
Number of critical isolation valves:	151
Number of critical valves exercised:	78
Number of valves that could not be exercised:	3
Remedial steps taken:	All three (3) valves were replaced with new valves.

If you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "David T. Lewis".

David T. Lewis, P.E.
President and
General Manager

Copy: Matthew L. Homsher, Secretary, Pa Public Utility Commission

Columbia Water Company

220 Locust Street ■ P.O. Box 350 ■ Columbia, PA 17512
Phone: 717-684-2188 ■ Fax: 717-684-4566