

Morgan Lewis

Kenneth M. Kulak

Partner

+1.215.963.5384

ken.kulak@morganlewis.com

January 16, 2026

VIA ELECTRONIC FILING

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor North
Harrisburg, PA 17120

**Re: Letter of Notification of PECO Energy Company Filed Pursuant to 52 Pa. Code §§ 57.71 *et seq.* for Approval of the Siting and Construction of the Conowingo 220-69 Line Located in Plymouth Township and Upper Merion Township, Montgomery County, Pennsylvania
Docket No. A-2025-3057875**

Dear Secretary Homsher:

Enclosed for filing in the above-captioned proceeding is PECO Energy Company's Response to the Data Request of the Bureau of Technical Utility Services, Question No. A-4.

As indicated on the enclosed Certificate of Service, copies have been served upon all parties of record.

If you have any questions, please call me directly at 215.963.5384.

Very truly yours,



Kenneth M. Kulak

KMK/ap

Enclosure

c: Per Certificate of Service (w/encls.)

Morgan, Lewis & Bockius LLP

2222 Market Street
Philadelphia, PA 19103
United States

T +1.215.963.5000
F +1.215.963.5001

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Letter of Notification of PECO Energy :
Company Filed Pursuant to 52 Pa. Code §§ :
57.71 et seq. for Approval of the Siting and :
Construction of the Conowingo 220-69 Line : Docket No. A-2025-3057875
Located in Plymouth Township and Upper :
Merion Township, Montgomery County, :
Pennsylvania :**

**RESPONSE OF PECO ENERGY COMPANY
TO DATA REQUEST OF THE BUREAU OF TECHNICAL UTILITY SERVICES**

TUS-A-4:

Reference TUS Data Requests, Response to A-1. Please provide the basis for the anticipated load growth.

RESPONSE:

As demonstrated in the Exelon Large Load Adjustment Proposal for the 2026 PJM Load Forecast submitted to the PJM Load Analysis Subcommittee for the committee's September 2025 meeting, PECO anticipates an additional 1.7 GW of load in its service territory over the accepted 2025 large load additions.¹ The proposed load forecast was preliminarily accepted by PJM for inclusion into the PJM 2026 load forecast.²

As explained in response to Data Request A-1, the large capacity conductors PECO proposes to install on the rebuilt 220-69 Line are heavier than the existing conductors on the current line and will help support the anticipated increased load conditions.

¹ See Exelon Large Load Adjustment Proposal – 2026 PJM Load Forecast (Sep. 16, 2025) at 4, 7, available at: <https://www.pjm.com/-/media/DotCom/committees-groups/subcommittees/las/2025/20250916/20250916-item-04d---exelon-large-load-request.pdf>.

² See PJM Load Adjustment Requests Summary for 2026 Load Forecast – Preliminary at 12 (Nov. 24, 2025), available at: <https://www.pjm.com/-/media/DotCom/committees-groups/subcommittees/las/2025/20251124/20251124-item-03---large-load-adjustment-requests-summary.pdf>.

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

**Letter of Notification of PECO Energy :
Company Filed Pursuant to 52 Pa. Code §§ :
57.71 et seq. for Approval of the Siting and : Docket No. A-2025-3057875
Construction of Conowingo 220-69 Line :
Located in Plymouth Township and Upper :
Merion Township, Montgomery County, :
Pennsylvania :**

VERIFICATION

I, Drew T. Davis, hereby state the facts above set forth are true and correct to the best of my knowledge, information and belief, and that I expect to be able to prove the same at a hearing held in this matter. I understand that the statements herein are made subject to the penalties of 18 Pa. C.S. § 4904 (relating to unsworn falsification to authorities).

DATE: 01/16/2026



Drew T. Davis
Vice President, Transmission and Substation

**BEFORE THE
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Letter of Notification of PECO Energy :
Company Filed Pursuant to 52 Pa. Code §§ :
57.71 et seq. for Approval of the Siting and :
Construction of the Conowingo 220-69 Line : **Docket No. A-2025-3057875**
Located in Plymouth Township and Upper :
Merion Township, Montgomery County, :
Pennsylvania :

CERTIFICATE OF SERVICE

I hereby certify and affirm that I have this day served a copy of the **Responses of PECO Energy Company to Data Requests of the Bureau of Technical Utility Services** on the following persons in the manner specified in accordance with the requirements of 52 Pa. Code § 1.54:

VIA ELECTRONIC MAIL

Darryl A. Lawrence
Office of Consumer Advocate
555 Walnut Street
Forum Place – 5th Floor
Harrisburg, PA 17101-1921
dlawrence@paoca.org

Allison C. Kaster
Bureau of Investigation and Enforcement
PA Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
akaster@pa.gov

Jordan Van Order
Bureau of Technical Utility Services
PA Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor West
Harrisburg, PA 17120
jvanorder@pa.gov

NazAarah Sabree
Commonwealth of Pennsylvania
Office of Small Business Advocate
Forum Place
555 Walnut Street, 1st Floor
Harrisburg, PA 17101
ra-sba@pa.gov

Dated: January 16, 2026



Kenneth M. Kulak
Morgan, Lewis & Bockius LLP
2222 Market Street
Philadelphia, PA 19103-3007
(215) 963-5384
ken.kulak@morganlewis.com