
Garrett P. Lent

glent@postschell.com
717-612-6032 Direct
717-731-1985 Direct Fax
File #: 216477

January 20, 2026

VIA ELECTRONIC FILING

Matthew L. Homsher, Secretary
Pennsylvania Public Utility Commission
Commonwealth Keystone Building
400 North Street, 2nd Floor
Harrisburg, PA 17120

**Re: Joint Letter Of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for Approval to Tap the Existing Dutch Fork–Windsor 138 Kilovolt Transmission Line to the New MPLX Grahek Substation in Donegal Township, Washington County, Pennsylvania.
Docket No. A-2025-3059423
Docket No. A-2025-3059434**

Dear Secretary Homsher:

Enclosed, on behalf of Keystone Appalachia Transmission Company (“KATCo”) and FirstEnergy Pennsylvania Electric Company (“FE PA”), is information being supplied to the Pennsylvania Public Utility Commission’s (“Commission”) Bureau of Technical Utility Services (“TUS”) in response to Data Requests issued on January 15, 2026, in the above-referenced proceedings.

Respectfully submitted,


Garrett P. Lent

GPL/dmc
Enclosure

cc: Jordan Van Order, Bureau of Technical Utility Services (*via email; w/attachment*)

Bureau of Technical Utility Services – Data Requests

Docket Nos. A-2025-3059423
A-2025-3059434

Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Dutch Fork – Windsor 138 kV Transmission Line Tap in Washington County, Pennsylvania

January 20, 2026

QUESTION A-5

Reference the Letter of Notification, paragraph 10. Please explain whether MPLX Grahek currently receives electric distribution service from FE PA. If so, please provide a detailed explanation as to why the current service is inadequate to meet the needs of MPLX Grahek.

Response:

MPLX Grahek does not currently receive electric distribution service from FE PA as this is a new substation and will be connected via a new transmission line tap.

Bureau of Technical Utility Services – Data Requests

Docket Nos. A-2025-3059423
A-2025-3059434

Joint Letter of Notification of Keystone Appalachian Transmission Company and FirstEnergy Pennsylvania Electric Company for the Dutch Fork – Windsor 138 kV Transmission Line Tap in Washington County, Pennsylvania

January 20, 2026

QUESTION A-6

Reference the Letter of Notification, paragraph 18. Please explain whether the do no harm analysis is complete. If so, please provide the supplemental project number.

Response:

FirstEnergy's Transmission Planning Department received a response from PJM on January 7, 2026, regarding the completion of the do no harm analysis. PJM stated that it has concluded all but one analysis. Once the final analysis is complete, the supplemental numbers will be issued soon afterwards. When this information is available, KATCo will supplement this response and/or provide the same to TUS.

