

January 30, 2026

**Via Electronic Filing**

Matthew Homsher, Esquire  
Secretary  
PA Public Utility Commission  
P.O. Box 3265  
Harrisburg, PA 17105-3265

**Re: Docket No. C-2025-3056210  
Donna Combs v. FirstEnergy Pennsylvania Electric Company  
Status Report of FE PA (Penelec Rate District)**

Dear Secretary Homsher:

Attached for filing is the Status Report of FirstEnergy Pennsylvania Electric Company (Penelec Rate District) in connection with the above-referenced proceeding.

A copy of the enclosed Status Report has been provided to the Complainant in the manner indicated on the attached Certificate of Service.

If there are any questions, please do not hesitate to contact me.

Very truly yours,

Reger Rizzo & Darnall LLP



Margaret A. Morris

MAM/co  
Enclosures

cc: The Hon. Emily A. Farren, PA Public Utility Commission [w/encls.]  
Tori Giesler, Esquire, FirstEnergy Service Company [w/encls.]  
Donna Combs [w/encls.]

**Re: Docket No. C-2025-3056210  
Donna Combs v. FirstEnergy Pennsylvania Electric Company  
Status Report of FE PA (Penelec Rate District)**


**CERTIFICATE OF SERVICE**

I hereby certify that a true and correct copy of the foregoing document has been served upon the following person(s), in the manner indicated, in accordance with the requirements of 52 Pa. Code § 1.54 (relating to service by a participant).

**Via Electronic Mail**

Donna Combs  
[combsdonna72@gmail.com](mailto:combsdonna72@gmail.com)

Dated: January 30, 2026

  
\_\_\_\_\_  
Margaret A. Morris, Esquire

January 30, 2026

**Via Electronic Mail**

The Honorable Emily A. Farren  
[efarren@pa.gov](mailto:efarren@pa.gov)

**Re: Docket No. C-2025-3056210  
Donna Combs v. FirstEnergy Pennsylvania Electric Company  
Status Report of FE PA (Penelec Rate District)**

Your Honor:

As agreed, FirstEnergy Pennsylvania Electric Company, Penelec Rate District, (Company) respectfully submits this Status Report.

**2-Year Outage History**

Per the Company's database, the Complainant has experienced 1 sustained outage on their service in the past two years. The outage occurred on December 29, 2025, during a high wind event that ultimately caused a line failure. The outage was successfully isolated by a TripSaver Recloser at Pole 9-630983 that was installed under the 2025 PARC Program.

Per the Complainant's smart meter history, the Complainant experienced 2 momentary outage since the beginning of October 2025. The first momentary outage was on October 1, 2025 and the second occurred on December 29, 2025 (the same day as the high wind event that later caused a sustained outage).

**Work Updates**

- On October 11, 2025, the Lewistown and Relay crew finished the recloser/settings install at Honey Grove Substation.
- On December 31, 2025, animal guarding was added to 22 locations across the Circuit to help prevent future recloser operations caused by wildlife.
- On January 8, 2026, three regulators were installed outside of the Honey Grove Substation to help regulate and mitigate high voltage seen on the Circuit in the past.

The Hon. Emily A. Farren

**Re: Status Report**

January 30, 2026


Page 2

- Scheduled for Fall 2026, the Company has scheduled the installation of a new SCADA controlled Viper recloser in the Honey Grove Substation.

**The parties respectfully request that the matter be continued until after July 1, 2026, so that the Complainant can be assured that the actions taken by the Company have improved the reliability of the service provided. Thank you for considering the joint request.**

Very truly yours,

Reger Rizzo & Darnall LLP

A handwritten signature in blue ink, appearing to read "Margaret A. Morris".

Margaret A. Morris, Esquire

MAM/mam

cc: Tori Giesler, Esquire, FirstEnergy Service Company  
Donna Combs